

**ELECTRIC SERVICE SCHEDULE NO. 140 - Continued**  
**Table 9 – Farm and Dairy Equipment Incentives**

<b>Equipment Type</b>	<b>Equipment Category</b>	<b>Minimum Efficiency Requirements</b>	<b>Customer Incentive "up to"</b>
Automatic Milker Takeoff (Retrofit Only)	--	Equipment must be able to sense milk flow and remove milker when flow reaches a pre-set level. The vacuum pump serving the affected milking units must be equipped with a VFD. Incentive is available for adding automatic milker takeoffs to existing milking systems, not for takeoffs on a brand new system where there were none before. Replacement of existing automatic milker takeoffs is not eligible for this listed incentive, but may qualify for a Custom Energy Efficiency incentive.	\$235 each
Agricultural Engine Block Heater Timer	--	Timer must be a UL-listed device and rated for a minimum of 15 amps continuous duty.	\$10 each
High-efficiency Circulating fan (See Note 2)	12-23" Diameter	Fan must achieve an efficiency level of 11 cfm/w	\$25/fan
	24-35" Diameter	Fan must achieve an efficiency level of 18 cfm/w	\$35/fan
	36-47" Diameter	Fans must achieve an efficiency level of 18 cfm/w	\$50/fan
	≥48" Diameter	Fans must achieve an efficiency level of 25 cfm/w	\$75/fan
Heat Recovery	--	Heat recovery unit must use heat rejected from milk cooling refrigeration system to heat water. Customer must use electricity for water heating.	\$0.15/kWh annual energy savings
High-efficiency Ventilation Fan (See Note 2)	12-23" Diameter	Fan must achieve an efficiency level of 11 cfm/w	\$45/fan
	24-35" Diameter	Fan must achieve an efficiency level of 13 cfm/w	\$75/fan
	36-47" Diameter	Fan must achieve an efficiency level of 17 cfm/w	\$125/fan
	≥48" Diameter	Fan must achieve an efficiency level of 19.5 cfm/w	\$150/fan
Milk Pre-cooler (Retrofit Only)	--	The equipment must cool milk with well-water before it reaches the bulk cooling tank. <u>New construction not eligible.</u>	\$0.15/kWh annual energy savings

Issued by authority of Report and Order of the Public Service Commission of Utah in Advice Docket No. 16-033-035-184

**FILED:** February~~September~~ 95, 20164  
104, 20164

**EFFECTIVE:** March~~September~~



P.S.C.U. No. 50

First Revision of Sheet No. 140.21  
Canceling Original Sheet No. 140.21

---

**ELECTRIC SERVICE SCHEDULE NO. 140 - Continued**  
(Continued)

---

Issued by authority of Report and Order of the Public Service Commission of Utah in Advice Docket No. 16-033-035-184

**FILED:** February~~September~~ 95, 20164  
101, 20164

**EFFECTIVE:** March~~September~~