

Selendy & Gay PLLC  
Jennifer M. Selendy  
Philippe Z. Selendy  
Joshua S. Margolin  
Margaret M. Siller  
1290 Avenue of the Americas  
New York, NY 10104  
212-390-9000  
jselendy@selendygay.com  
pselendy@selendygay.com  
jmargolin@selendygay.com  
msiller@selendygay.com

*Attorneys for Vote Solar*

**BEFORE THE PUBLIC SERVICE COMMISSION OF UTAH**

In the Matter of the Application of Rocky Mountain Power to Establish Export Credits for Customer Generated Electricity	<b>Docket No. 17-035-61 Phase 2</b>
---	-------------------------------------

**REBUTTAL TESTIMONY OF CURT VOLKMANN**

**ON BEHALF OF**

**VOTE SOLAR**

July 15, 2020

## **Table of Contents**

I. INTRODUCTION	3
II. PURPOSE OF TESTIMONY	4
III. THE CG EXPORT CREDIT SHOULD INCLUDE AVOIDED LINE TRANSFORMER LOSSES	5
IV. THERE IS NO EVIDENCE THAT RMP IS EXPERIENCING CG-RELATED “WEAR-AND-TEAR” OF DISTRIBUTION EQUIPMENT	9
V. DESPITE ITS VARIABILITY, CG OUTPUT REDUCES THE NEED FOR T&D CAPACITY INVESTMENTS	11
VI. RMP CAN MITIGATE VOLTAGE ISSUES WITH ADVANCED INVERTERS	16
VII. RMP’S PROPOSED CG METERING FEE IS ARBITRARY AND EXCESSIVE	24
VIII. CONCLUSIONS AND SUMMARY OF RECOMMENDATIONS	27

1 **I. Introduction**

2 **Q. Please state your name and business address.**

3 A. My name is Curt Volkmann. My business address is 132 Lake Vista Circle, Fontana,  
4 Wisconsin, 53125.

5 **Q. On whose behalf are you submitting this rebuttal testimony?**

6 A. I am submitting this rebuttal testimony on behalf of Vote Solar.

7 **Q. Did you submit affirmative testimony in this proceeding?**

8 A. Yes. My Revised Affirmative Testimony dated May 8, 2020 includes a summary of my  
9 education and professional experience.<sup>1</sup>

10 **Q. Please provide a brief overview of your background and qualifications.**

11 A. I am President and founder of New Energy Advisors, LLC, an independent consulting firm.  
12 I have a BS in Electrical Engineering from the University of Illinois with a concentration  
13 in Electrical Power Systems. I also have an MBA from the University of California at  
14 Berkeley with a concentration in Finance. I have 36 years of experience in the utilities  
15 industry, primarily in electric transmission and distribution. I have testified and  
16 commented before regulatory commissions in various distribution planning, grid  
17 modernization, and distributed energy resources proceedings in eleven states.

---

<sup>1</sup> Vote Solar, *Revised Affirmative Testimony of Curt Volkmann*, May 8, 2020, lines 11-21.

18 **II. Purpose of Testimony**

19 **Q. What is the purpose of your rebuttal testimony?**

20 A. I am rebutting the testimony of Rocky Mountain Power (“RMP”) witness Daniel J.  
21 MacNeil and Department of Commerce, Division of Public Utilities (“DPU”) witness  
22 Robert A. Davis. My rebuttal testimony will:

- 23 1) Explain why avoided line transformer losses should be included in the customer  
24 generation (“CG”) export credit.
- 25 2) Explain that there is no evidence that CG variability is causing “wear-and-tear” on  
26 RMP’s distribution equipment.
- 27 3) Explain the growing evidence that CG output reduces the need for transmission and  
28 distribution capacity additions.
- 29 4) Explain how advanced inverters can mitigate voltage concerns related to CG output.
- 30 5) Explain why RMP’s proposed CG metering fee is arbitrary and excessive.

31 My lack of comments on any components of other parties’ direct testimony should not be  
32 interpreted as acquiescence or agreement. I reserve the right to express additional opinions,  
33 to amend or supplement the opinions in this testimony, or to provide additional rationale  
34 for these opinions as additional documents are produced and new facts are introduced  
35 during discovery and trial. I also reserve the right to express additional opinions in  
36 response to any opinions or testimony offered by other parties in this proceeding.

37 **III. The CG Export Credit Should Include Avoided Line Transformer Losses**

38 **Q. How has RMP quantified losses on its transmission and distribution (“T&D”)**  
39 **system?**

40 A. RMP has quantified loss expansion factors for six segments of its T&D system. Figure 1  
41 shows the individual and cumulative energy loss expansion factors for each segment.

	Energy (MWh)	
<u>Segment</u>	<u>Factor</u>	<u>Cumulative</u>
1) Transmission System	1.04527	1.04527
2) Distribution Substation	1.00665	1.05222
3) Primary Line	1.01342	1.06635
4) Line Transformer	1.01863	1.08621
5) Secondary	1.00141	1.08774
6) Service Drop	1.00504	1.09322

42  
43 **Figure 1<sup>2</sup>**

44 **Q. How has the Company proposed to credit CG exports for avoided losses?**

45 A. RMP proposes to credit CG exports for avoided line losses at the transmission and primary  
46 levels, which includes the distribution substation and primary line segments. RMP  
47 explains: “The Company expects to apply the export credit to resources interconnected at  
48 secondary voltage levels. However, the exported energy must be transferred across the  
49 secondary distribution system to other customers. As a result, they will incur some line  
50 losses and will not be avoiding the entire line losses associated with serving load on the  
51 secondary distribution system. Therefore, the Company proposes crediting exports for  
52 only avoiding the next higher level, i.e. primary line losses.”<sup>3</sup>

---

<sup>2</sup> Exhibit 1-CV, PacifiCorp Utah 2009 Analysis of System Losses November 2011.pdf, Appendix B, Exhibit 9, RMP’s Responses to Vote Solar 6th Set Data Requests – Attach 6.8 (Aug. 16, 2019).

<sup>3</sup> RMP, *Direct Testimony of Daniel J. MacNeil*, Feb. 3, 2020, lines 148–53.

53 **Q. Do other parties agree with this approach?**

54 A. Yes, DPU witness Abdinasir M. Abdulle states: “First, RMP proposes to adjust the avoided  
55 energy costs for line losses. Customers under this program take service at the secondary  
56 level. Private generation customers export energy back to the grid across the secondary  
57 grid to other customers. RMP proposes to include in export credit rates avoided line losses  
58 for transmission and primary levels. This is a reasonable line loss calculation because  
59 energy from other generation resources would experience line losses at the transmission,  
60 primary, and secondary levels. Private generation customer exports must still transfer  
61 across the secondary circuits and will experience line losses in the secondary circuits.  
62 Therefore, the appropriate adjustment for line losses is for the transmission and primary  
63 levels.”<sup>4</sup>

64 **Q. Do you agree with this approach?**

65 A. I agree with RMP and DPU that CG exports avoid losses at the transmission, distribution  
66 substation, and primary line segments. However, as I explained in my Revised Affirmative  
67 Testimony filed on May 8, 2020, CG exports also avoid line transformer losses.<sup>5</sup> RMP’s  
68 proposed CG export credit fails to include the line transformer segment.

---

<sup>4</sup> DPU, *Direct Testimony of Abdinasir M. Abdulle*, Mar. 3, 2020, lines 45–54.

<sup>5</sup> *Volkman Affirmative*, lines 240–52.

69 **Q. Please explain how RMP’s proposed CG export credit fails to include the line**  
70 **transformer segment.**

71 A. RMP witness MacNeil states that the Company has identified line losses in Utah at the  
72 primary interconnection level to be 6.635%.<sup>6</sup> Figure 1 shows that cumulative energy losses  
73 of 6.635% only take into account losses on the Transmission System, Distribution  
74 Substation, and Primary Line segments. RMP’s proposed CG export credit does not include  
75 avoided line transformer losses.

76 **Q. How do CG exports avoid line transformer losses?**

77 A. As I explained in my Revised Affirmative Testimony filed on May 8, 2020, the majority  
78 of CG exports flow to serve other customers connected to the same distribution line  
79 transformer (i.e., via the secondary distribution system)<sup>7</sup>, resulting in reduced energy  
80 flowing through the transmission and primary distribution systems, including the line  
81 transformers. In response to an OCS data request, RMP explains:

82 When a customer being served at the secondary voltage level has on-site  
83 generation in excess of their load, that generation is transferred through the  
84 customer meter and up the service drop. To reach another secondary customer,  
85 the generation must at least pass across secondary voltage lines, back down a  
86 service drop, and through another customer’s meter. Losses are incurred at  
87 each stage of this process. The losses across the exporting customer’s service  
88 drop will be incremental to what would otherwise be required to serve another  
89 customer. The losses on another customer’s service drop would be the same  
90 whether that power is sourced from exported customer generation or utility  
91 assets. Losses on secondary voltage lines could be higher or lower depending  
92 on the specific circumstances. Additional losses would be incurred to the  
93 extent generation must be converted from secondary to primary voltage by the  
94 line transformer or from primary to transmission voltage in the distribution  
95 substation ... Given that exported customer generation uses the secondary  
96 distribution system, it will incur losses on the secondary system, so the

---

<sup>6</sup> *MacNeil Direct*, line 140.

<sup>7</sup> *Volkman Affirmative*, lines 71–75.

97 Company's proposal does not credit exported generation with avoided  
98 secondary losses.<sup>8</sup>

99 **Q. RMP's response above indicates that, in addition to losses on the secondary**  
100 **distribution system, there could be additional losses if excess generation flows through**  
101 **the line transformer or even the distribution substation. Do you agree?**

102 A. I agree that there are some scenarios where CG exports may flow across line transformers  
103 to serve adjacent load and incur losses. In extreme cases of high CG penetration on a  
104 circuit, when aggregate CG output exceeds the circuit load, excess generation may flow  
105 through a utility's distribution substation. However, I believe that with RMP's current CG  
106 penetration of only 1.7%,<sup>9</sup> the majority of exports flow to serve other customers connected  
107 to the same secondary distribution system. It is therefore reasonable to assume that CG  
108 exports avoid line transformer losses.

109 **Q. What do you recommend?**

110 A. I agree that CG exports do not avoid losses on the secondary and service drop segments.  
111 However, I continue to recommend that the CG export credit include avoided energy losses  
112 from the transmission, distribution substation, primary line, and line transformer segments  
113 with cumulative energy losses of 8.621% as shown in Figure 1. Vote Solar witness  
114 Milligan quantifies the impact of this recommendation on the CG export credit in his  
115 Revised Affirmative Testimony dated May 8, 2020.<sup>10</sup>

---

<sup>8</sup> Exhibit 2-CV, *Response to OCS Data Request 3.3*, RMP's Responses to OCS 3rd Set Data Requests (Mar. 10, 2020).

<sup>9</sup> *Volkman Affirmative*, lines 287–89.

<sup>10</sup> Vote Solar, *Revised Affirmative Testimony of Michael Milligan*, May 8, 2020, lines 347–50.



116 **IV. There Is No Evidence That RMP Is Experiencing CG-related “Wear-**  
117 **and-Tear” of Distribution Equipment**

118 **Q. Did any party raise concerns about the impact of CG variability?**

119 A. Yes. DPU witness Robert A. Davis explains:

120 Electricity, by its very nature, has to have a demand for supplied generation.  
121 Customer generation is either consumed on-site or exported to the grid. Many  
122 factors, from weather systems, the time-of-day, system failures, etc., can lead  
123 to solar customer delivery and export variability throughout the day, month,  
124 and year. In real time, solar customers might be pulling from the grid and  
125 within an instant exporting to the grid for whatever reason. Of course, such  
126 instant changes might be localized to a few customers or spread more broadly.  
127 The distribution system and fleet generation resources have to be available and  
128 adjust accordingly to keep the system reliable. This likely leads to additional  
129 wear- and-tear.<sup>11</sup>

130 Mr. Davis further states: “It is a reasonable assumption that additional variability has the  
131 potential to wear out certain distribution equipment at a faster rate than otherwise would  
132 occur.”<sup>12</sup> He also states: “Although distribution equipment is designed to meet load under  
133 such variable conditions, the addition of weather related or other solar induced variability  
134 attributes likely cause additional wear-and-tear on system components.”<sup>13</sup>

135 **Q. Did Vote Solar request additional information from the DPU on this alleged issue?**

136 A. Yes. In response to Vote Solar data requests seeking documents or other evidence  
137 supporting this concern, the DPU stated: “The Division has not compiled a comprehensive  
138 list of every published work on the topic as there are too many studies, white papers, and  
139 articles on this topic to cite or mention here.”<sup>14</sup> In the same data request response, the DPU

---

<sup>11</sup> DPU, *Direct Testimony of Robert A. Davis*, Mar. 3, 2020, lines 339–47.

<sup>12</sup> *Id.* at lines 186–88.

<sup>13</sup> *Id.* at lines 226–29.

<sup>14</sup> Exhibit 3-CV, *Response to Vote Solar Data Request 2-1.1*, DPU’s Responses to Vote Solar 2nd Set Data Requests (June 8, 2020).

140 provided various presentations and links to additional documents, none of which provide  
141 evidence of “wear-and-tear” on RMP’s distribution system.<sup>15</sup> Oddly, the DPU also cited a  
142 2013 technical white paper, which concludes that high penetrations of PV can significantly  
143 extend distribution transformer life.<sup>16</sup> This directly contradicts the DPU’s concern about  
144 “wear-and-tear.”

145 **Q. Did DPU witness Davis provide an estimate of how significant this issue is?**

146 A. No. DPU witness Davis expressly acknowledges that any “wear-and-tear” cannot be  
147 quantified, stating: “The wear-and-tear is difficult to estimate with any accuracy because  
148 the equipment in question is designed to operate for sometimes 50-70 years or thousands  
149 of cycles,”<sup>17</sup> and, “The Division cannot quantify how the variability impacts the system at  
150 this time[.]”<sup>18</sup>

---

<sup>15</sup> The documents provided by the DPU include four presentations from the Utah PSC’s July 11, 2019 technical workshop on distributed solar grid impacts conducted by Lawrence Berkley National Laboratory and Pacific Northwest National Laboratory, and a 2017 NERC report on DER reliability considerations, which does not mention the issue of distribution equipment “wear-and-tear”. See Exhibit 3-CV.

<sup>16</sup> Exhibit 3-CV (citing H. Pezeshki, P. J. Wolfs and G. Ledwich, *Impact of High PV Penetration on Distribution Transformer Insulation Life*, IEEE Transactions on Power Delivery, vol. 29, no. 3, pp. 1212-1220, June 2014, available at <https://core.ac.uk/download/pdf/19541682.pdf>).

<sup>17</sup> *Davis Direct*, line 188 n. 14.

<sup>18</sup> *Id.* at lines 188–89.

151 **Q. Can RMP provide evidence of distribution equipment “wear-and-tear” from CG**  
152 **variability?**

153 A. No. In response to Vote Solar data requests, RMP provided no evidence that the variability  
154 of CG output reduces equipment life.<sup>19</sup> RMP also acknowledges that it does not track any  
155 increases in line equipment maintenance costs due to the variable output of CG.<sup>20</sup>

156 **Q. What do you conclude?**

157 A. There is no evidence that RMP is experiencing “wear-and-tear” of distribution equipment  
158 due to CG variability. DPU witness Davis acknowledges this fact, stating: “I have no  
159 evidence at the time of this filing to indicate if there are system issues at the current  
160 penetration level because of customer generation.”<sup>21</sup>

161 **V. Despite its Variability, CG Output Reduces the Need for T&D Capacity**  
162 **Investments**

163 **Q. Has RMP included a T&D capacity deferral or avoidance value in its proposed CG**  
164 **export credit methodology?**

165 A. No.

---

<sup>19</sup> Exhibit 4-CV, *Response to Vote Solar Data Request 6.24(19)*, RMP’s Responses to Vote Solar 6th Set Data Requests (Aug. 23, 2019). RMP’s response consists of user manuals for single-phase voltage regulators and pole-mounted three-phase capacitor banks, neither of which mentions the issue of reduced equipment life from CG.

<sup>20</sup> Exhibit 4-CV, *Response to Vote Solar Data Request 6.24(20)*, RMP’s Responses to Vote Solar 6th Set Data Requests (Aug. 23, 2019).

<sup>21</sup> *Davis Direct*, lines 349–50.

166 **Q. Did any party testify about the impact of CG on T&D capacity?**

167 A. Yes. DPU witness Davis states: “Solar generation is an intermittent resource that produces  
168 during daylight hours. The downside to the technology is that it can drop off and return  
169 over short periods of time or remain marginal for longer periods of time. It is a challenge  
170 to forecast when these cycles might occur making its capacity contribution low.”<sup>22</sup>

171 **Q. Do you agree?**

172 A. I agree that CG is an intermittent resource. However, despite its variability, there is  
173 growing evidence that CG materially reduces peak loads and the associated need for  
174 capacity-related capital investments.

175 **Q. Please provide an example of this.**

176 A. The California Public Utilities Commission (“CPUC”) has established an Avoided Cost  
177 Calculator to determine the primary benefits of distributed energy resources (“DER”). The  
178 Avoided Cost Calculator calculates six types of avoided costs: energy, generation capacity,  
179 T&D capacity, ancillary services, renewable portfolio standard compliance, and  
180 greenhouse gas emissions. The outputs of the Avoided Cost Calculator feed into the  
181 utilities’ cost-benefit analysis for DER across various CPUC proceedings.<sup>23</sup>

182 In its April 2020 decision, the CPUC acknowledged that DER avoid both specified and  
183 unspecified transmission investments. Specified transmission investments are those tied  
184 to specific capital projects. Unspecified transmission investments refer to future capacity

---

<sup>22</sup> *Davis Direct*, lines 321–24.

<sup>23</sup> CPUC, *2020 Policy Updates to the Avoided Cost Calculator*, California Public Utilities Commission, D.20-04-010, at 4, Apr. 16, 2020, <https://docs.cpuc.ca.gov/PublishedDocs/Published/G000/M334/K734/334734544.PDF>.

185 upgrades across the system that are no longer needed due to shifts or decreases in load from  
186 DER. The CPUC confirmed that, while difficult to quantify, the value for unspecified  
187 transmission avoided costs is not zero and directed staff to develop a common methodology  
188 for quantifying the values across the state’s investor-owned utilities.<sup>24</sup>

189 **Q. Please provide another example of how CG reduces the need for T&D capacity**  
190 **investments.**

191 A. In the current Southern California Edison (“SCE”) General Rate Case (“GRC”)  
192 proceeding, SCE applied a new methodology for “PV Dependability” resulting in  
193 significant reductions in its distribution load forecasts and associated distribution capital  
194 investments.

195 **Q. What is PV Dependability?**

196 A. PV Dependability is the amount of CG (measured in percentage of nameplate rating) that  
197 SCE can reasonably rely on each hour of the day to reduce distribution circuit peak loads,  
198 taking into account local conditions such as solar insolation, cloud cover, and temperature.

199 **Q. How does this differ from the Resource Capacity Value calculated by Vote Solar**  
200 **witness Milligan in this proceeding?**

201 A. As Vote Solar witness Milligan explains, the Resource Capacity Value is a measure of the  
202 contribution of a generation resource to system-wide generation planning reserves.<sup>25</sup> Dr.

---

<sup>24</sup> *Id.* at 3.

<sup>25</sup> *Milligan Affirmative*, lines 372–74.

203 Milligan appropriately determined that the Resource Capacity Value of CG exports across  
204 RMP's system averages 29.51% of the rated installed capacity.<sup>26</sup>

205 PV Dependability measures the hourly contribution of CG to reducing local distribution  
206 peak loads. Because PV Dependability is strongly influenced by local conditions, SCE has  
207 established eight regional curves for each of its distribution planning regions.

208 **Q. What is the impact of SCE's new PV Dependability methodology?**

209 A. SCE explains, "[the] updated methodology applied to the 10-year forecast results in a  
210 greater amount of solar PV output considered dependable for planning purposes, an  
211 increase in the load-modifying impacts, and a corresponding decrease in net load  
212 growth."<sup>27</sup> Figure 2 shows that SCE now considers 45% of the installed nameplate of CG  
213 as dependable at 12:00 p.m. for its San Jacinto Region and 11.6% at 5:00 p.m., a significant  
214 increase from the assumptions in its 2018 GRC application.

---

<sup>26</sup> *Id.* at lines 534–35.

<sup>27</sup> Solar Energy Industries Association and Vote Solar, *Direct Testimony of Curt Volkmann*, California Public Utilities Commission, Docket No. A.19-08-013, lines 9:15-10:2, May 5, 2020, [http://www3.sce.com/sscc/law/dis/dbattach5e.nsf/0/AD6EA44AD9798A5588258591004D91C0/\\$FILE/SEIA%20VoteSolar%20Direct%20Testimony%20C.%20Volkmann.pdf](http://www3.sce.com/sscc/law/dis/dbattach5e.nsf/0/AD6EA44AD9798A5588258591004D91C0/$FILE/SEIA%20VoteSolar%20Direct%20Testimony%20C.%20Volkmann.pdf).




Figure 2<sup>28</sup>

215  
216

217 SCE further explains, “The result of increased PV output as dependable is a further  
218 reduction in forecasted [distribution] peak loading.”<sup>29</sup>

219 **Q. What is the impact of the reduction in forecasted distribution peak loading?**

220 A. The reduction in forecasted distribution peak loading from CG adoption resulted in  
221 significant reductions in the need for capacity-related capital investments. As one example,

222 SCE explains:

223 The Circle City 66/12 kV Substation Project was originally proposed as a  
224 single project that combined two primary scope elements: 1) a new 66/12 kV  
225 distribution substation (Circle City Substation), and 2) a new 66 kV  
226 subtransmission line (Mira Loma-Jefferson 66kV Line) .... In recent  
227 planning cycles, the anticipated load growth in the area has not materialized  
228 at the rate previously expected and may be attributed to a reduction in the  
229 forecast due to increased DER<sup>30</sup> adoption .... The amount of load growth-  
230 reducing DER adoption that is included in its 2019-2028 forecast resulted in  
231 a total of 35.24 MW over the 10 years. This amount alone is enough to

<sup>28</sup> Southern California Edison, *SCE’s Dependable Photovoltaic Generation Methodology*, California Public Utilities Commission, Docket No. A.19-08-013, Workpaper - Exhibit No. SCE-02 Vol.04 Pt 02 Ch II Bk A, at 12, [http://www3.sce.com/sscc/law/dis/dbattach5e.nsf/0/DD4E0AE29C3D2FCF8825846600789C18/\\$FILE/WPSCE02V04Pt02ChIIBkA.pdf](http://www3.sce.com/sscc/law/dis/dbattach5e.nsf/0/DD4E0AE29C3D2FCF8825846600789C18/$FILE/WPSCE02V04Pt02ChIIBkA.pdf).

<sup>29</sup> *Volkman*, California Public Utilities Commission, Docket No. A.19-08-013, lines 16:17-18.

<sup>30</sup> In SCE’s service territory, the vast majority of DER is PV CG.

232 suppress the projected peak demand to levels that do not support the need for  
233 the Circle City Substation scope of the proposed project within the 10-year  
234 horizon. Accordingly, SCE has informed the [Commission] of this portion  
235 of scope being removed from the project.<sup>31</sup>

236 **Q. What are the associated savings from the reduced project scope?**

237 A. The original project cost was approximately \$154 million. Excluding the Circle City  
238 Substation, the project cost is now \$89.6 million, meaning the load-reducing CG adoption  
239 has saved approximately \$64 million of capital costs.<sup>32</sup>

240 **Q. What do you conclude?**

241 A. RMP has failed to consider the impact of CG exports on the deferral or avoidance of capital  
242 expenditures in its proposed export credit methodology. CG's impact on reducing peak  
243 loads and the associated need for T&D capital expenditures can be significant, and the CG  
244 capacity deferral value should be included in the export credit. As Vote Solar witness Yang  
245 explains, the value of avoided T&D capacity costs due to CG exports in RMP's service  
246 territory is at least 2.02 cents/kWh in 2021 dollars.<sup>33</sup>

## 247 **VI. RMP Can Mitigate Voltage Issues with Advanced Inverters**

248 **Q. Did any party raise concerns about CG's impact on circuit voltage?**

249 A. Yes. DPU witness Davis raises a concern about increased voltages from CG output. He  
250 states: "The National Renewable Energy Laboratory studies distributed generation to gain  
251 an understanding of bi-directional power flows on traditional distribution systems. When

---

<sup>31</sup> *Volkman*, California Public Utilities Commission, Docket No. A.19-08-013, lines 16:22-17:13.

<sup>32</sup> *Id.* at lines 17:15-18.

<sup>33</sup> Vote Solar, *Revised Affirmative Testimony of Spencer S. Yang*, Mar. 3, 2020, lines 42-46.



252 power is injected into the electric system, the voltage at the location increases such that  
253 high penetrations of Distributed Generation Photo Voltaic (“DGPV”) might raise the  
254 voltage beyond the acceptable range, requiring the addition of voltage-regulating  
255 equipment.”<sup>34</sup> Mr. Davis did not quantify how much additional voltage-regulating  
256 equipment may be required.

257 **Q. Do you share this concern?**

258 A. I agree that CG output can raise circuit voltages; however, advanced (or “smart”) inverters  
259 have the ability to effectively mitigate voltage concerns and reduce or eliminate the need  
260 for additional conventional voltage-regulating equipment.

261 **Q. What is an inverter?**

262 A. An inverter is an electronic device that converts direct current (“DC”) electricity to  
263 alternating current (“AC”) electricity. Some DER, such as PV and batteries, require  
264 inverters to interconnect to the distribution system. PV systems convert solar energy into  
265 DC electricity. Batteries produce and absorb energy in the form of DC electricity. Because  
266 the North American electricity system is AC, inverters are necessary for energy from PV  
267 solar and batteries to be delivered into the distribution grid or used on site.

268 Conventional inverters have very limited activated functionality beyond converting DC to  
269 AC. They are required to quickly disconnect from the grid when they detect system  
270 disturbances such as high/low voltage or frequency.

---

<sup>34</sup> *Davis Direct*, lines 358–63.

271 **Q. What is an advanced or smart inverter?**

272 A. In markets where PV penetrations are high (i.e., Germany, Hawaii, California), the  
273 automatic disconnection of large numbers of inverters during system disturbances became  
274 or could become problematic and actually worsen system stability. To address this issue,  
275 the industry developed new technical requirements and a revised industry standard for  
276 inverters to stay connected or “ride-through” system disturbances within certain ranges to  
277 enhance system stability. Advanced or smart inverters are those compliant with the new  
278 industry standard and also include new capabilities.

279 **Q. What is the new industry standard, and how does it define new smart inverter**  
280 **capabilities?**

281 A. The new industry standard is the revised Institute of Electrical and Electronics Engineers  
282 (“IEEE”) Standard 1547-2018, titled the *IEEE Standard for Interconnection and*  
283 *Interoperability of Distributed Energy Resources with Associated Electric Power Systems*  
284 *Interfaces* (“IEEE Standard”). The IEEE Standard was approved on February 15, 2018  
285 and published in April of that year.<sup>35</sup>

286 The IEEE Standard includes categories of DER performance during normal operating  
287 conditions<sup>36</sup> and categories of performance for addressing reliability/stability needs during  
288 abnormal operating conditions.

---

<sup>35</sup> IEEE Standards Association, *1547-2018 - IEEE Standard for Interconnection and Interoperability of Distributed Energy Resources with Associated Electric Power Systems Interfaces*, Feb. 15, 2018, <https://standards.ieee.org/standard/1547-2018.html>.

<sup>36</sup> The IEEE Standard defines normal operating conditions as the continuous operation region when the voltage is between 0.88 and 1.1 times the nominal voltage. In North America, the nominal distribution voltage is 120 volts (“V”). Applying the definition of the IEEE Standard means normal operating conditions in North America are when the distribution voltage is between 105.6 V and 132 V.

289 **Q. What are the IEEE Standard’s required functions during normal operating**  
290 **conditions?**

291 A. Among other functions, the IEEE Standard requires DER to be able to inject or absorb  
292 reactive power to keep voltages within an allowable range during normal operating  
293 conditions and to curtail real power<sup>37</sup> output if needed to meet apparent power<sup>38</sup>  
294 constraints.

295 **Q. What is RMP’s allowable range of distribution voltages?**

296 A. RMP’s single-phase service voltage Range A (Favorable Zone), in which the voltage level  
297 is near optimal, is between 114-126 V. The Company’s Range B (Tolerable Zone), in  
298 which the voltage level is acceptable but not optimal, is between 110-127 V. RMP states  
299 that its “supply systems are designed and operated so that most service voltage levels are  
300 within the limits specified for Range A. The occurrence of steady-state service voltages  
301 outside these limits shall be infrequent.”<sup>39</sup>

---

<sup>37</sup> AC electricity systems must serve loads that consume real and reactive power. Real power, measured in watts (“W”), does useful work and is consumed by loads such as incandescent light bulbs and resistance heating elements. Reactive power, which is unique to AC power systems and measured in Volt-Amperes Reactive (“var”), performs no useful work and is required due to the characteristics of inductive or capacitive circuit loads. Many common AC devices such as fluorescent lights, motors, air conditioning compressors, and power supplies are reactive power loads. Utilities must continuously balance the supply and demand of both real and reactive power. An imbalance in the supply and demand of real power results in fluctuations above or below the system’s nominal frequency. An imbalance in the supply and demand of reactive power results in fluctuations above or below nominal system voltage.

<sup>38</sup> Distribution utilities deliver what is called apparent power, measured in Volt-Amperes (“VA”), to supply the real and reactive power consumption in various loads. Manufacturers provide sizes or ratings of AC power equipment in terms of apparent power, often in thousands of Volt-Amperes (“kVA”), or millions of Volt-Amperes (“MVA”).

<sup>39</sup> *PacifiCorp Engineering Handbook, 1C.2.1 - Voltage Level and Range*, at 3-4, Apr. 8, 2013, [https://www.rockymountainpower.net/content/dam/pcorp/documents/en/pp-rmp/power-quality-standards/1C\\_2\\_1\\_PF.pdf](https://www.rockymountainpower.net/content/dam/pcorp/documents/en/pp-rmp/power-quality-standards/1C_2_1_PF.pdf).

302 **Q. Is it common for distribution system voltages to fluctuate within the allowable**  
303 **range?**

304 A. Yes, it is very common for distribution circuit voltages to fluctuate within this range, or  
305 even temporarily outside the range, as circuit loads increase and decrease. Distribution  
306 systems are designed and constructed to adjust for these fluctuations and remain within the  
307 allowable range or to maintain a target voltage level.

308 **Q. How do utilities ensure that distribution voltages remain within the allowable**  
309 **range?**

310 A. Distribution utilities typically install transformer load tap changers, voltage regulators, and  
311 capacitors to manually or automatically adjust voltages and power factor, an activity  
312 referred to as voltage regulation. When automated, this conventional equipment can adjust  
313 voltages to acceptable ranges or pre-determined levels within minutes.

314 **Q. Will smart inverters help utilities regulate voltage during normal operating**  
315 **conditions?**

316 A. Yes. By injecting or absorbing reactive power within seconds at the location of a grid need,  
317 smart inverters and other advanced power electronics can significantly improve the speed  
318 and level of precision of distribution voltage regulation.

319 **Q. How do smart inverters perform these functions?**

320 A. Smart inverters perform these functions autonomously, meaning no communications or  
321 control is required. The functions are activated, and settings established, at the time of  
322 initial DER installation, and no additional interactions with the inverters are necessary.

323 **Q. Is RMP aware of these smart inverter capabilities?**

324 A. Yes. RMP conducted a study in 2018 with the Electric Power Research Institute (“EPRI”)  
325 to determine the potential impact of advanced inverters on its distribution circuits. The  
326 final report states: “By absorbing or injecting reactive power, smart inverters may be able  
327 to increase hosting capacity on certain feeders by reducing voltage variations resulting  
328 from increased generation.”<sup>40</sup>

329 **Q. What are the preferred smart inverter modes and settings for voltage regulation?**

330 A. A 2019 GridLab publication<sup>41</sup> (which I co-authored) recommends the Voltage-reactive  
331 power (“volt-var”) mode with reactive power priority using the IEEE Standard Category  
332 B<sup>42</sup> default volt-var settings.

333 **Q. What is volt-var mode?**

334 A. The volt-var mode means the autonomous control of reactive power as a function of  
335 voltage. The IEEE Standard default volt-var settings for Category B DER are shown in  
336 Figure 3 below. When the voltage at the inverter is between 98% and 102% of the nominal  
337 voltage (called the dead band), the inverter does not supply or absorb reactive power.  
338 Outside these voltage ranges, the DER inverter begins supplying or absorbing reactive  
339 power up to a maximum of 44% of the DER’s apparent power rating. This is an


---

<sup>40</sup> *Advancing Smart Inverter Integration in Utah: Final Report*, EPRI, Palo Alto, CA: 2019, 3002015334, at 1-1, <https://pscdocs.utah.gov/electric/19docs/1903517/307937RMPAttach8-4-30-19.pdf>.

<sup>41</sup> R. O’Connell, C. Volkmann, & P. Brucke, *Regulating Voltage: Recommendations for Smart Inverters*, at 9. GridLab, Sept. 12, 2019, [http://gridlab.org/wp-content/uploads/2019/09/GridLab\\_Regulating-Voltage-report.pdf](http://gridlab.org/wp-content/uploads/2019/09/GridLab_Regulating-Voltage-report.pdf).

<sup>42</sup> The IEEE Standard defines Category B to be where the DER penetration is higher or where the DER power output is subject to frequent large variations.

340 autonomous response from the smart inverter, and it provides this voltage regulation  
 341 service continuously during normal operating conditions.



342  
 343 **Figure 3 – IEEE 1547-2018 Default Volt-Var Settings for Category B DER<sup>43</sup>**

344 **Q. Can you further describe how volt-var works?**

345 A. Yes. Consider a 10 kW CG system with a smart inverter that has an apparent power AC  
 346 nameplate rating of 10 kVA. When the voltage at the inverter terminal is between 117.6  
 347 V and 122.4 V (or between 98% and 102% of the nominal voltage of 120 V), the CG system  
 348 will produce only real power, up to a maximum of 10 kW. If the voltage at the inverter  
 349 terminal rises above 122.4 V, the inverter begins absorbing reactive power. In the extreme  
 350 case of the voltage rising to 129.6 V (108% of the nominal voltage of 120 V), the inverter  
 351 would be absorbing 4.4 kVAR (44% of the nameplate rating), according to Figure 3.

<sup>43</sup> IEEE Standard 1547-2018, Table 8, p. 39.

352 **Q. What does it mean to have volt-var with reactive power priority?**

353 A. Reactive power priority means that the inverter must provide or absorb the required level  
354 of reactive power, curtailing real power as needed, due to the apparent power limits of the  
355 inverter.

356 **Q. Has RMP established its required modes/settings for advanced inverters?**

357 A. No. In response to a Vote Solar data request, RMP indicated that it has not determined the  
358 specific modes/settings it will require for advanced inverters.<sup>44</sup>

359 **Q. Who will bear the cost of transitioning to advanced inverters?**

360 A. Customers who have installed or will install CG will bear any additional cost for a smart  
361 or advanced inverter.

362 **Q. What do you recommend?**

363 A. Once smart inverters are fully available in the market,<sup>45</sup> RMP should take advantage of  
364 these new capabilities to defer or eliminate the need to invest in conventional voltage  
365 regulation equipment. RMP's policy and requirements for interconnecting DER to its  
366 distribution system is called Policy 138. I recommend that RMP update its interconnection  
367 Policy 138 to require volt-var mode with reactive power priority and the IEEE Standard  
368 Category B default settings for inverter-based CG.

---

<sup>44</sup> Exhibit 4-CV, *Response to Vote Solar Data Request 6.1(7)*, RMP's Responses to Vote Solar 6th Set Data Requests (Aug. 16, 2019).

<sup>45</sup> IEEE Standard 1547.1-2020, Test Procedures for Conformance with IEEE 1547-2018, was published on May 21, 2020. Updates to the associated UL 1741 test procedures are underway, and UL 1741 / 1547-2018 compliant inverters will be available in late 2020 or early 2021.

369 **VII. RMP’s Proposed CG Metering Fee is Arbitrary and Excessive**

370 **Q. What metering technologies has RMP used for CG customers?**

371 A. The Company explains:

372 Rocky Mountain Power completed the installation of a mobile  
373 automated meter reading (AMR) system in the state of Utah in 2010  
374 .... The meters installed during, and subsequent to, the project are  
375 read once per month and provide energy and demand billing  
376 determinants for all residential and small commercial customers.

377 Meters for large commercial and industrial customers, as well as  
378 meters where interval data is required (e.g. load research, Schedule  
379 136, etc.) cannot be read by the mobile AMR solution currently  
380 deployed. These meters have not been replaced and continue to be  
381 read manually. These are the most expensive meters to read. The  
382 number of installations requiring interval data for billing purposes  
383 continues to increase dramatically and the need to find a cost  
384 effective solution for reading these meters is important to control  
385 costs.

386 To address this need, in late 2017, the Company issued a request for  
387 proposal for the installation of an AMI network. This network is  
388 designed to avoid the high cost of manually reading large  
389 commercial, industrial and interval meters. The network will  
390 mitigate the associated increase in manpower as interval meter  
391 numbers continue to increase.

392 In October 2018 the Company awarded a contract to Itron for their  
393 OpenWay Riva AMI solution ... The installation of an Itron AMI  
394 system in Utah will provide the basic field area network required to  
395 automate approximately 18,000 manually read meters as well as all  
396 current and future meters associated with Schedule 136 (customer  
397 generators).<sup>46</sup>

---

<sup>46</sup> RMP, *An Investment Appraisal for Advanced Resiliency Management System (ARMS)*, at 3, Mar. 7, 2019, [https://www.rockymountainpower.net/content/dam/pcorp/documents/en/rockymountainpower/rates-regulation/utah/filings/docket-16-035-36/03-08-19\\_application\\_and\\_direct\\_testimony/05\\_Direct\\_Testimony\\_of\\_Rohit\\_P\\_Nair\\_-\\_Exhibit\\_RMP\\_RPN-1.pdf](https://www.rockymountainpower.net/content/dam/pcorp/documents/en/rockymountainpower/rates-regulation/utah/filings/docket-16-035-36/03-08-19_application_and_direct_testimony/05_Direct_Testimony_of_Rohit_P_Nair_-_Exhibit_RMP_RPN-1.pdf).



398 **Q. How many AMI meters is RMP planning to install?**

399 A. RMP plans to replace approximately 170,000 existing meters with AMI meters throughout  
400 its service territory by the end of 2022.<sup>47</sup> Additionally, the Company will install AMI  
401 meters for all new customer connections and meter replacements that occur after project  
402 completion.<sup>48</sup>

403 **Q. How will the Company recover the costs of the AMI deployment?**

404 A. In response to a data request, RMP states: “Costs will be recovered through the standard  
405 rate filings and processes.”<sup>49</sup> This means that all RMP ratepayers will share the costs of  
406 the AMI deployment. RMP is requesting approval of \$77.9 million of capital and \$4.3  
407 million of operations and maintenance costs for AMI in its current general rate case.<sup>50</sup>

408 **Q. What metering fee is RMP proposing for new Schedule 137<sup>51</sup> CG customers?**

409 A. RMP proposes a \$160 metering fee for new Schedule 137 participants and explains:

410 The Company is planning a partial deployment of advanced metering  
411 infrastructure (“AMI”) in Utah in 2020 and 2021. For customers who  
412 have an AMI meter installed, the cost to re-program the customer’s  
413 meter to begin recording delivered and exported energy will be  
414 substantially less than it was in the past. The Company estimates that  
415 it will expend about \$20 to re-program the meter for a new customer-  
416 generator with AMI. New customer generators who do not have AMI  
417 will be equipped with an AMI meter that will be programmed to  
418 measure delivered and exported energy, which the Company  
419 estimates will cost \$193.26 to install ... (T)aking a weighted average  
420 of the \$20 cost for customers with AMI and the \$193.26 cost for  
421 customers without AMI by the anticipated customer counts with and

---

<sup>47</sup> Exhibit 5-CV, *Response to Vote Solar Data Request 11.5(9.2)*, RMP’s Responses to Vote Solar 11th Set Data Requests (Apr. 17, 2020).

<sup>48</sup> *Id.*

<sup>49</sup> *Id.*

<sup>50</sup> RMP, *Direct Testimony of Curtis B. Mansfield*, Utah Public Service Commission, Docket No. 20-035-04, lines 586–87, May 8, 2020.

<sup>51</sup> Schedule 137 is RMP’s proposed successor tariff to Schedule 136, its transition program for customer generators.

422 without AMI after deployment at the end of 2021 yields an estimated  
423 metering cost of \$160.34. The Company rounded this value down to  
424 \$160 for its proposed fee.<sup>52</sup>

425 **Q. Is RMP proposing the \$160 fee for all new Schedule 137 customers?**

426 A. Yes. RMP explains: “The Company is proposing to charge all new Schedule 137  
427 customers a \$160 customer generation metering fee, whether they have an AMI meter or  
428 not.”<sup>53</sup>

429 **Q. Does RMP currently charge customers for meter upgrades?**

430 A. No. RMP does not currently charge customers for meter repair or upgrade services under  
431 any of RMP’s electric service schedules in Utah.<sup>54</sup>

432 **Q. Does RMP charge customers to reprogram meters under any of RMP’s electric  
433 service schedules in Utah?**

434 A. No.<sup>55</sup>

435 **Q. After the initial AMI deployment in 2020-2021, will RMP charge a metering fee to  
436 customers who receive an AMI meter for new connections or meter replacements?**

437 A. No.<sup>56</sup>

---

<sup>52</sup> RMP, *Direct Testimony of Robert M. Meredith*, Feb. 3, 2020, lines 235–50.

<sup>53</sup> Exhibit 5-CV, *Response to Vote Solar Data Request 11.5(9.3)*, RMP’s Responses to Vote Solar 11th Set Data Requests (Apr. 17, 2020).

<sup>54</sup> Exhibit 5-CV, *Response to Vote Solar Data Request 11.5(10.4)*, RMP’s Responses to Vote Solar 11th Set Data Requests (Apr. 17, 2020).

<sup>55</sup> Exhibit 5-CV, *Response to Vote Solar Data Request 11.5(10.3)*, RMP’s Responses to Vote Solar 11th Set Data Requests (Apr. 17, 2020).

<sup>56</sup> Exhibit 6-CV, *Response to Vote Solar Data Request 14.1(2)*, RMP’s Responses to Vote Solar 14th Set Data Requests (June 24, 2020).

438 **Q. What do you recommend?**

439 A. RMP's proposed \$160 meter fee for new Schedule 137 customers is arbitrary and  
440 inconsistent with what the Company charges non-CG customers who have a reprogrammed  
441 AMI meter or receive a new AMI meter. I recommend that the Commission reduce the  
442 proposed metering fee for new Schedule 137 customers from \$160 to \$0.

## 443 **VIII. Conclusions and Summary of Recommendations**

444 **Q. What do you conclude?**

445 A. I conclude that CG has a positive impact for RMP's customers by reducing T&D losses  
446 and contributing to the deferral or avoidance of T&D capital investment. The evidence in  
447 this proceeding does not support the alleged negative impacts from CG (i.e., high CG  
448 integration costs, wear-and-tear of distribution equipment). As CG penetrations increase  
449 across RMP's service territory, the Company can cost-effectively manage potential  
450 negative impacts by taking advantage of new smart inverter capabilities.

451 **Q. Please provide a summary of your recommendations.**

452 A. I recommend that:

453 1) The CG export credit include avoided energy losses from the transmission, distribution  
454 substation, primary line, and line transformer segments with cumulative avoided  
455 losses of 8.621%.

456 2) The CG export credit exclude any component related to alleged "wear-and-tear" on  
457 RMP's distribution equipment.

458 3) The CG export credit include the T&D capacity deferral value of at least 2.02  
459 cents/kWh in 2021 dollars.

460 4) RMP take advantage of new smart inverter capabilities to defer or eliminate the need  
461 to invest in conventional voltage regulation equipment and update its interconnection  
462 Policy 138 to require volt-var mode with reactive power priority and the IEEE  
463 Standard Category B default settings for inverter-based CG.

464 5) The Commission reduce the proposed metering fee for new Schedule 137 customers  
465 from \$160 to \$0.

466 **Q. Does this conclude your testimony?**

467 A. Yes.

**CERTIFICATE OF SERVICE**

I hereby certify that on this 15th day of July, 2020 a true and correct copy of the foregoing was served by email upon the following:

**DIVISION OF PUBLIC UTILITIES:**

Chris Parker	chrisparker@utah.gov
William Powell	wpowell@utah.gov
Patricia Schmid	pschmid@agutah.gov
Justin Jetter	jjetter@agutah.gov
Erika Tedder	etedder@utah.gov
	dpudatarequest@utah.gov

**OFFICE OF CONSUMER SERVICES:**

Alex Ware	aware@utah.gov
Philip Hayet	phayet@jkenn.com
Samuel WYROBECK	swyrobeck@jkenn.com
Michele Beck	mbeck@utah.gov
Cheryl Murray	cmurray@utah.gov
Robert Moore	rmoore@agutah.gov
Victor Copeland	vcopeland@agutah.gov
Bela Vastag	bvastag@utah.gov

**SALT LAKE CITY CORPORATION:**

Christopher Thomas	christopher.thomas@slcgov.com
Megan DePaulis	megan.depaulis@slcgov.com

**UTAH SOLAR ENERGY ASSOCIATION:**

Amanda Smith	asmith@hollandhart.com
Ryan Evans	revans@utsolar.org
Engels J. Tejada	ejtejada@hollandhart.com
Chelsea J. Davis	cjdavis@hollandhart.com

**WESTERN RESOURCE ADVOCATES:**

Nancy Kelly	nkelly@westernresources.org
Steven S. Michel	smichel@westernresources.org
Sophie Hayes	sophie.hayes@westernresources.org

**UTAH CLEAN ENERGY:**

Sarah Wright	sarah@utahcleanenergy.org
Kate Bowman	kate@utahcleanenergy.org
Hunter Holman	hunter@utahcleanenergy.org

**VOTE SOLAR:**

Sachu Constantine  
Claudine Custodio  
Jennifer M. Selendy  
Philippe Z. Selendy  
Joshua Margolin  
Margaret M. Siller

sachu@votesolar.org  
claudine@votesolar.org  
jselendy@selendygay.com  
pselendy@selendygay.com  
jmargolin@selendygay.com  
msiller@selendygay.com

**AURIC SOLAR:**

Elias Bishop

elias.bishop@auricsolar.com

**ROCKY MOUNTAIN POWER:**

Richard Garlish  
Emily Wegener  
Jana Saba  
Joelle Steward

Richard.garlish@pacificorp.com  
Emily.Wegener@pacificorp.com  
jana.saba@pacificorp.com  
joelle.steward@pacificorp.com  
datarequest@pacificorp.com  
utahdockets@pacificorp.com

**VIVINT SOLAR, INC.:**

Stephan F. Mecham

sfmecham@gmail.com

/s/ Joshua S. Margolin