

ELECTRIC SERVICE SCHEDULE NO. 140 - Continued
Table 3a – HVAC Incentives

Equipment Type	Category	Minimum Efficiency Requirements	Customer Incentive "up to"
Unitary Commercial Air Conditioners	Air-Cooled – Split Systems Only	As defined in CEE Commercial Unitary Air-conditioning and Heat Pumps Specification	\$75/ton
	Water Cooled	As defined in CEE Commercial Unitary Air-conditioning and Heat Pumps Specification	\$75/ton
	Evaporatively Cooled	As defined in CEE Commercial Unitary Air-conditioning and Heat Pumps Specification	\$75/ton
Packaged Terminal Air Conditioners (PTAC)	≤ 8,000 Btu/hr	12.2 EER	\$25/ton
	> 8,000 Btu/hr and < 10,500 Btu/hr	11.9 EER	
	≥ 10,500 Btu/hr and ≤ 13,500 Btu/hr	10.7 EER	
	> 13,500 Btu/hr	9.9 EER	
Packaged Terminal Heat Pumps (PTHP) (Heating & Cooling Mode)	≤ 8,000 Btu/hr	12.2 EER and 3.4 COP	\$50/ton
	> 8,000 Btu/hr and < 10,500 Btu/hr	11.5 EER and 3.3 COP	
	≥ 10,500 Btu/hr and ≤ 13,500 Btu/hr	10.7 EER and 3.1 COP	
	> 13,500 Btu/hr	9.8 EER and 3.0 COP	
Unitary Commercial Heat Pumps (See Note 3)	Air-Cooled	As defined in CEE Commercial Unitary Air-conditioning and Heat Pumps Specification	\$75/ton
	Water Cooled	As defined in CEE Commercial Unitary Air-conditioning and Heat Pumps Specification	\$75/ton
	Ground Source	As defined in ENERGY STAR Program Requirements for Geothermal Heat Pumps	\$50/ton
	Groundwater Source	As defined in ENERGY STAR Program Requirements for Geothermal Heat Pumps	\$50/ton
Heat Pump Loop (See Note 7)	Ground Source, Closed Loop	--	\$25/ton
	Groundwater Source, Open Loop	--	\$25/ton

(Continued)

Issued by authority of Report and Order of the Public Service Commission of Utah in Advice No. 17-04

FILED: February 27, 2017

EFFECTIVE: April 1, 2017