

April 28, 2021

VIA ELECTRONIC FILING

Utah Public Service Commission
Heber M. Wells Building, 4th Floor
160 East 300 South
Salt Lake City, UT 84114

Attention: Gary Widerburg
Commission Administrator

RE: Docket No. 21-035-28 – Rocky Mountain Power’s Service Quality Review Report

In compliance with the Commission’s June 11, 2009 order in Docket No. 08-035-55 and December 20, 2016 order in Docket Nos. 13-035-01 and 15-035-72, and pursuant to the requirements of Rule R746-313, PacifiCorp d.b.a. Rocky Mountain Power (“RMP” or “Company”) submits the Service Quality Review Report for the period January through December, 2020.

The Company respectfully requests that all formal correspondence and requests for additional information regarding this filing be addressed to the following:

By E-mail (preferred): datarequest@pacificorp.com
utahdockets@pacificorp.com
Jana.saba@pacificorp.com

By regular mail: Data Request Response Center
PacifiCorp
825 NE Multnomah, Suite 2000
Portland, OR 97232

Informal inquiries may be directed to Jana Saba at (801) 220-2823.

Sincerely,



Joelle Steward
Vice President, Regulation

Enclosures



UTAH SERVICE QUALITY REVIEW

**January 1 – December 31, 2020
Report**

Table of Contents

<i>Table of Contents</i>	2
<i>Executive Summary</i>	3
1 Reliability Performance	4
1.1 System Average Interruption Duration Index (SAIDI)	4
1.2 System Average Interruption Frequency Index (SAIFI)	5
1.3 Major and Significant Event Days	6
1.4 Restore Service to 80% of Customers within 3 Hours.....	8
1.5 CAIDI Performance.....	8
2 Reliability History	9
2.1 Utah Reliability Historical Performance	9
2.2 Controllable, Non-Controllable and Underlying Performance Review	10
2.3 Baseline Performance	12
2.4 Reliability Reporting Post-Rule R.746-313 Modifications	13
3 Improve Reliability Performance in Areas of Concern	15
3.1 Reliability Work Plans.....	15
3.2 Project approvals by district.....	15
4 Customer Response	17
4.1 Telephone Service and Response to Commission Complaints	17
4.2 Utah Commitment U1	17
4.3 Utah State Customer Guarantee Summary Status	23
5 Maintenance Compliance to Annual Plan	24
5.1 T&D Preventive and Corrective Maintenance Programs	24
5.2 Maintenance Spending - RMV	25
5.2.1 Maintenance Historical Spending - RMV	25
5.3 Distribution Priority “A” Conditions Correction History.....	26
6 Capital Investment	27
6.1 Capital Spending - Distribution and General Plant	27
6.2 Capital Spending – Transmission/Interconnections.....	28
6.3 New Connects	29
7 Vegetation Management	30
7.1 Production	30
7.2 Budget	31
7.2.1 Vegetation Historical Spending	31
8 Standard Guarantees/Program Summary	32
8.1 Service Standards Program Summary	32
8.1.1 Rocky Mountain Power Customer Guarantees	32
8.1.2 Rocky Mountain Power Performance Standards.....	33
8.1.3 Utah Distribution Service Area Map with Operating Areas/Districts	34
8.2 Cause Code Analysis.....	35
8.3 Reliability Definitions	36

Executive Summary

Rocky Mountain Power developed its Customer Service Standards and Service Quality Measures nearly 20 years ago. The standards were developed as a way to demonstrate to customers that the Company is serious about serving them well and willing to back its commitments with cash payments in cases where the Company falls short. The standards also help remind employees about the importance of good customer service. The Company developed these standards by benchmarking its performance against relevant industry reliability and customer service standards. In some cases, Rocky Mountain Power has expanded upon these standards. In other cases, largely where the industry has no established standard, Rocky Mountain Power developed its own metrics, targets and reporting methods.

Rocky Mountain Power continues to deliver favorable network performance as measured by System Average Interruption Duration Index (SAIDI) and System Average Interruption Frequency Index (SAIFI). The Company extended its year-on-year improvement achieved by completion of reliability projects and efforts that have been put in place. In Docket No. 20-035-22, the Division of Public Utilities (DPU) reviewed Rocky Mountain Power's 2019 service quality and recommended the Public Service Commission of Utah (Commission) establish a work group to review RMP's reliability baseline standards related to SAIDI and SAIFI and make recommendations. The Commission accepted this recommendation and directed RMP and DPU to convene a work group, open to interested parties, to examine RMP's reliability baseline standards and to make recommendations. In accordance with the Commission directive, the parties convened a workgroup that met to discuss new baseline performance standards, which are reflected in this report.

Rocky Mountain Power recognizes the continued impact of any outage to its customers. Utah customers experienced three major outage events involving a 5.7 magnitude earthquake, severe weather and a catastrophic windstorm. While these represent extreme events, Rocky Mountain Power recognizes the significant negative impacts to our customers, communities and other important stakeholders.

Our goal continues to be supplying safe, reliable power to Utah. We are dedicated to learning from our past service experiences and continuing to make improvements to our operations and customer service to ensure we meet Utah's needs.

Below is a summary of our year-end 2020 performance serving the customers of Utah.


1 Reliability Performance

For the reporting period, the Company’s performance was on target for delivering System Average Interruption Duration Index (SAIDI) and System Average Interruption Frequency Index (SAIFI). The Company met with the Commission and modified the baseline performance range. It was determined, based on historical performance, that the range should be reduced (SAIDI reduced from 137-187 to 107-157 minutes and SAIFI reduced from 1.0-1.6 to 0.9-1.2 events). These changes can be seen in sections 1.1 and 1.2. In addition, section 1.3 provides details regarding major event and significant event customers experienced. Finally, sections 1.4 and 1.5 shows Company outage response performance.

1.1 System Average Interruption Duration Index (SAIDI)


Over time the Company has made system changes to minimize how many customers are affected for any given outage. This approach has resulted in improvements to both outage duration and outage frequency, and has yielded improved performance as delivered to customers, as generally shown in the graphic below and in 1.2. The total value includes underlying and major events.

SAIDI	Reporting Period
Total	683
Underlying	106
Controllable Distribution	36



1.2 System Average Interruption Frequency Index (SAIFI)

SAIFI	Reporting Period
Total	1.430
Underlying	0.925
Controllable Distribution	0.254



1.3 Major and Significant Event Days

There were three major events¹ and six significant event days² during the reporting period. New to the report this year, Rocky Mountain Power has included regional major events to show events that are statistical outliers that may not show up on a state level. These events are still included in the underlying metrics and are found in section 1.1. Finally, sections 1.4 and 1.5 shows company outage response performance.

Major Event Descriptions

Major Events				
Date	Cause	Status	Docket	SAIDI
March 18, 2020	Earthquake	Approved	20-035-19	14.6
June 5-8, 2020	Weather - Windstorm	Approved	20-035-36	12.8
September 7-16, 2020	Weather – Windstorm	Approved	21-035-15	548.7
Total				576.1

- March 18, 2020**
 On March 18, 2020, at 7:09 AM, a 5.7 magnitude earthquake in Magna, Utah shook the Wasatch Front and caused widespread outages to Rocky Mountain Power customers across the Salt Lake and Tooele Valleys. The earthquake triggered multiple substation protective relays to operate and isolate transformers to prevent further damage. Moreover, the earthquake caused numerous distribution lines to fall or twist together. The damage to company facilities resulted in 56,421 customer interruptions.
- June 5-8, 2020**
 A storm system moved across the state of Utah beginning June 5, 2020 and extending over a three day period. The storm brought strong winds and precipitation to the region causing widespread outages to Rocky Mountain Power customers. The damage to company facilities resulted in 50,451 customer interruptions.
- September 7-16, 2020**
 On the afternoon of September 7, 2020, a surge of cold air from Canada unleashed damaging winds in northern Utah. Wind gusts measured 99 mph in Farmington and 112 mph in Salt Lake City at the University of Utah, with east downslope winds of 60 to 90 mph that continued throughout the day September 8, 2020. The high winds caused trees to fall, lines to tangle and equipment to fail. The event impacted 373,674 customers in northern Utah and outages lasted multiple days due to the widespread damage. The peak of the outages occurred the morning of September 8, 2020 when 203,930 Rocky Mountain Power customers were without service.

¹ A Major Event (ME) is defined as a 24-hour period where SAIDI exceeds a statistically derived threshold value (Reliability Standard IEEE 1366-2012) based on the 2.5 beta methodology. The values used for the reporting period are shown below:

Effective Date	Customer Count	ME Threshold SAIDI	ME Customer Minutes Lost
1/1-12/31/2020	954,372	4.84	4,614,733

² Significant event days are 1.75 times the standard deviation of the company's natural log daily SAIDI results (by state or appropriate reliability reporting region).

UTAH

January 1 – December 31, 2020

Regional Major Events

Beginning in 2020, Rocky Mountain Power began categorizing regions where outages in a diverse operating area can be identified as statistical outliers, which would otherwise be hidden by the statistical weighting of some districts. This is in accordance with IEEE Standard 1366-2012 which notes, “[the purpose of major event classification] is to allow major events to be studied separately from daily operation, and in the process, to better reveal trends in daily operation that would be hidden by the large statistical effect of major events.” The regional major event listed below is still included in the underlying metrics and is stated in this report for informational purposes.

Regional Major Events		
Date	Cause	SAIDI
June 28, 2020	Loss of Transmission – Wildfire	3.3
Total		3.3

- **June 28, 2020**

On June 28, 2020, a fast-moving wildfire caused a loss of transmission line event affecting customers in Southern Salt Lake County and Northern Utah County. The event resulted in 22,997 customer interruptions with outage durations ranging from eight minutes to four hours 46 minutes. The event is classified as a regional major event and is still included in the underlying metrics.

Significant Events

Significant event days add substantially to year-on-year cumulative performance results; fewer significant event days generally result in better reliability for the reporting period, while more significant event days generally mean poorer reliability results. During the reporting period six significant event days were recorded, which account for 17.5 SAIDI minutes, or about 17 percent of the reporting period’s underlying 106 SAIDI minutes. The leading cause of these events are included in the table below.

Significant Event Days					
Dates	Cause: General Description	Underlying SAIDI	Underlying SAIFI	% of Total Underlying SAIDI (106)	% of Total Underlying SAIFI (0.925)
May 22, 2020	Weather - Windstorm	2.9	0.013	3%	3%
May 30, 2020	Weather – Windstorm	1.8	0.013	2%	3%
June 28, 2020	Loss of Transmission – Wildfire	4.5	0.029	4%	7%
August 3, 2020	Loss of Transmission Line	2.2	0.021	2%	2%
October 11, 2020	Loss of Transmission Line and Pole Fire	3.9	0.015	4%	2%
November 6, 2020	Trees Non-Preventable/Loss of Substation	2.2	0.013	2%	1%
TOTAL		17.5	0.104	17%	11%

1.4 Restore Service to 80% of Customers within 3 Hours

RESTORATIONS WITHIN 3 HOURS					
Reporting Period Cumulative = 89%					
January	February	March	April	May	June
94%	91%	96%	95%	86%	75%
July	August	September	October	November	December
93%	88%	94%	94%	94%	92%

1.5 CAIDI Performance

The table below shows the average time, during the reporting period, for outage restoration. This augments previous reporting for the percent of customers whose power was restored within 3 hours of notification of an outage event and uses IEEE industry indices.



CAIDI (Average Outage Duration)	
Underlying Performance	478 minutes
Total Performance	115 minutes

2 Reliability History

Historically the Company has improved reliability as measured by SAIDI and SAIFI reliability indices; at the same time outage response performance (CAIDI) has varied from year to year with no specific trend apparent. The SAIDI and SAIFI trends are further evidenced in Sections 2.2 and 2.3, where 365-day rolling performance trends are depicted. These indices demonstrate the efficacy of the long-term improvement strategies targeted toward reducing the frequency of interruptions that the company under-took after the implementation of its automated outage management system. As previously discussed, this report reflects the updated baselines, which are detailed further in Section 2.3.

It is particularly noteworthy that these two metrics show durable improvement for both underlying and major event performance within the state, meaning that the system is more resilient on a day-to-day basis as well as when extreme weather or other system impacting events occur.


2.1 Utah Reliability Historical Performance





2.2 Controllable, Non-Controllable and Underlying Performance Review

In 2008, the Company introduced a further categorization of outage causes, which it subsequently used to develop improvement programs as developed by engineering resources. This categorization was titled Controllable Distribution Outages and recognized that certain types of outages can be cost-effectively avoided. As an example, animal-caused or equipment failure interruptions have a less random nature than lightning caused interruptions; other causes have also been determined and are specified in Section 2.4 Engineers can develop plans to mitigate against controllable distribution outages and provide better future reliability at the lowest possible cost. At that time, there was concern that the Company would lose focus on non-controllable outages. In order to provide insight into the response and history for those outages, the charts below distinguish amongst the outage groupings.

The graphic history demonstrates controllable, non-controllable, and underlying performance on a rolling 365-day basis. Analysis of the trends displayed in the charts below shows a general improving trend for all charts. In order to also focus on non-controllable outages, the Company has continued to improve its resilience to extreme weather using such programs as its visual assurance program to evaluate facility condition. It also has undertaken efforts to establish impacts of loss of supply events on its customers and deliver appropriate improvements when identified. It uses its web-based notification tool for alerting field engineering and operational resources when devices have exceeded performance thresholds in order to react as quickly as possible to trends in declining reliability. These notifications are conducted regardless of whether the outage cause was controllable or not.







2.3 Baseline Performance

In compliance with Utah Reliability Reporting Rules, the Company developed performance baselines that it subsequently filed for approval (based on 2008-2012 history). The baseline values were calculated using the 12-month moving average data for SAIDI and SAIFI over a 5-year period as the mean, plus or minus approximately two standard deviations. These baselines were approved, but stakeholders advocated that periodically refreshing baseline levels would be beneficial. As a result, on December 20, 2016, the Public Service Commission of Utah approved modified electric service reliability performance baseline notification levels (Docket No. 13-035-01 and 15-035-72). On June 23, 2020, the Commission directed the Company to work with parties to review the baselines. The original and modified baselines are shown below.

	SAIDI (Minutes)		SAIFI (Events)	
	Lower Value Control Zone	Upper Value Control Zone	Lower Value Control Zone	Upper Value Control Zone
Prior Baseline	151	201	1.3	1.9
2016 Modified Baseline	137	187	1.0	1.6
2020 Modified Baseline	107	157	0.9	1.2



2.4 Reliability Reporting Post-Rule R.746-313 Modifications




In 2012, the Company and stakeholders developed reliability reporting rules that are codified in Utah Administrative Code R746.313. Certain reliability reporting details were outlined in these rules that had not been previously required in the Company’s Service Quality Review Report. Certain elements may be at least partially redundant or segmented differently than has been provided in the past.

The final rule required five-year history at an operating area level for SAIDI, SAIFI and CAIDI. At a state level, these metrics in addition to MAIFI³ are required.

Major Events and Prearranged Excluded*	2016				2017				2018				2019				2020			
STATE	SAIDI	SAIFI	CAIDI	MAIFI _e	SAIDI	SAIFI	CAIDI	MAIFI _e	SAIDI	SAIFI	CAIDI	MAIFI _e	SAIDI	SAIFI	CAIDI	MAIFI _e	SAIDI	SAIFI	CAIDI	MAIFI _e
Utah	120	1.0	115	1.76	129	1.0	127	1.11	124	1.1	118	2.17	116	1.0	118	2.64	106	0.9	114	3.46
OP AREA																				
AMERICAN FORK	92	1.0	93		77	0.8	102		85	0.8	109		59	0.6	100		65	0.7	91	
CEDAR CITY	174	1.5	116		183	1.7	109		157	1.2	136		160	1.4	114		149	1.3	111	
CEDAR CITY (MILFORD)	650	4.9	132		565	2.5	230		226	1.4	164		563	3.2	177		296	1.9	154	
EVANSTON	16	0.1	199		49	0.2	219		23	0.2	96		9	0.1	76		12	0.1	192	
JORDAN VALLEY	100	0.8	131		109	0.8	139		137	1.1	121		100	0.8	118		99	0.8	121	
LAYTON	90	0.9	103		115	0.8	149		90	0.9	101		83	0.9	90		71	0.8	93	
MOAB	278	3.0	93		190	2.4	80		111	1.1	103		171	2.0	87		239	1.9	123	
MONTPELIER	43	0.5	93		452	0.7	624		34	0.4	94		13	0.2	75		33	0.2	142	
OGDEN	120	1.0	120		119	0.9	138		116	1.0	114		153	1.1	139		116	0.9	128	
PARK CITY	183	1.6	117		227	1.4	159		165	1.2	143		187	1.1	171		251	1.9	132	
PRICE	340	3.3	104		171	2.5	69		203	2.3	90		101	1.9	53		140	1.3	109	
RICHFIELD	132	1.3	101		187	2.0	95		173	1.4	125		222	2.2	103		135	1.5	92	
RICHFIELD (DELTA)	215	2.1	103		139	1.3	105		171	1.0	163		100	0.7	136		203	1.0	197	
SLC METRO	104	0.9	113		114	1.0	111		120	1.0	118		113	0.9	125		95	0.9	108	
SMITHFIELD	117	1.0	118		139	0.9	149		96	1.0	99		127	1.5	83		88	0.9	100	
TOOELE	161	1.1	151		140	1.4	100		196	1.5	135		146	1.3	110		137	1.0	137	
TREMONTON	399	3.1	129		200	2.0	99		151	1.1	137		259	1.6	167		178	1.3	140	
VERNAL	53	0.6	84		77	0.8	96		48	0.6	82		58	0.6	98		68	0.7	94	

Utah Cause Category	2016		2017		2018		2019		2020	
	SAIDI	SAIFI	SAIDI	SAIFI	SAIDI	SAIFI	SAIDI	SAIFI	SAIDI	SAIFI
Environment	1	0.0	1	0.0	1	0.0	0	0.0	1	0.0
Equipment Failure	45	0.2	44	0.2	48	0.3	40	0.2	39	0.2
Lightning	3	0.0	3	0.0	3	0.0	3	0.0	1	0.0
Loss of Supply - Generation/Transmission	13	0.2	13	0.1	13	0.2	9	0.1	15	0.2
Loss of Supply - Substation	13	0.1	11	0.1	9	0.1	11	0.1	6	0.1
Operational	1	0.0	1	0.0	0	0.0	0	0.0	1	0.0
Other	0	0.0	0	0.0	0	0.0	1	0.0	1	0.0
Planned (excl. Prearranged)	11	0.2	8	0.1	10	0.1	9	0.1	6	0.1
Public	14	0.1	15	0.1	15	0.1	16	0.1	16	0.1
Unknown	7	0.1	6	0.1	6	0.1	5	0.1	5	0.1
Vegetation	5	0.0	6	0.0	5	0.0	7	0.0	7	0.0
Weather	5	0.0	16	0.1	9	0.1	11	0.1	7	0.1
Wildlife	2	0.0	3	0.0	3	0.0	2	0.0	3	0.0
UTAH Underlying	120	1.0	129	1.0	124	1.1	116	1.0	106	0.9

³ MAIFI_e events are measured using the circuit customer count for those circuits where a trip and reclose occurred during the reporting period, and do not include customer counts for circuits where no event was recorded.



3 Improve Reliability Performance in Areas of Concern

Over the past decade the Company has developed approaches, including tools, automated and manual processes and methods to improve reliability. As it has done so, the Company's ability to diagnose portions of the system requiring improvement has improved, which yields its legacy "Worst Performing Circuit" program obsolete. As a result, it devised a more contemporary approach to identifying improvement plans, determining the value of those plans and monitoring to ensure that results delivered meet or exceed expected targets. This program was named Open Reliability Reporting (ORR).

The ORR process shifts the Company's reliability program from a circuit-based view reliant on blended reliability metrics (using circuit SAIDI, SAIFI and MAIFI) to a more strategic and targeted approach based upon recent trends in performance of the local area, as measured by customer minutes interrupted (from which SAIDI is derived). The decision to fund one performance improvement project versus another is based on cost effectiveness as measured by the cost per avoided annual customer minute interrupted. However, the cost effectiveness measure will not limit funding of improvement projects in areas of low customer density where cost effectiveness per customer may not be as high as projects in more densely populated areas.

3.1 Reliability Work Plans

The Company has worked to improve reliability through Reliability Work Plans. To assist in identification of problem areas, Area Improvement Teams (AIT) meetings and Frequent Interrupters Requiring Evaluation (FIRE) reports have been established. On a daily basis, the Company's system alerts operations and engineering team members regarding outages experienced at interrupting devices (circuit breakers, line reclosers and fuses). When repetition occurs, it is an indicator that system improvements may be needed. On a routine basis, local operations and engineering team members review the performance of the network using geospatial and tabular tools to look for opportunities to improve reliability. As system improvement projects are identified, cost estimates of reliability improvement and costs to deliver that improvement are prepared. If the project's cost effectiveness metrics are favorable, i.e. low cost and high avoidance of future customer minutes interrupted, the project is approved for funding and the forecast customer minutes interrupted are recorded for subsequent comparison. This process allows individual districts to take ownership and identify the greatest impact to their customers. Rather than focusing on a large area at high costs, districts can focus on problem areas or devices.

3.2 Project Approvals by District

The identification of projects is an ongoing process throughout the year. An approval team reviews projects weekly and once approved, design and construction begins. Upon completion of the construction, the project is identified for follow up review of effectiveness. One year after completion, routine assessments of performance are prepared. This comparison is summarized for all projects for each year's plans, and actual versus forecast results are assessed to determine whether targets were met or if additional work may be required. The table below is provided to demonstrate the measures the Company believes represents cost/effectiveness measures that are important in determining the success of the projects that have been completed.

UTAH

January 1 – December 31, 2020

2018-2020 District Projects*									
Approval Metrics			Effectiveness Metrics						In Progress
District	Project count	Budgeted Cost/CML	Plans Meeting Goals (>1 year since project completion)	Estimated Avoided annual CML	Actual Avoided annual CML	Budgeted Cost per annual avoided CML	Actual Cost per annual avoided CML	Plans Not Meeting Goals (not included in metrics)	Plans waiting for information
American Fork	11	\$1.40	4	102,529	181,348	\$2.12	\$0.74	0	7
Cedar City	1	\$3.39	0	0	0	\$0.00	\$0.00	0	1
Jordan Valley	44	\$1.60	28	1,532,659	4,725,963	\$1.44	\$0.52	0	16
Layton	5	\$0.53	3	253,428	1,022,889	\$0.30	\$0.26	1	1
Moab	4	\$4.57	1	5,754	11,508	\$7.78	\$10.91	0	3
Montpelier	1	\$0.53	0	0	0	\$0.00	\$0.00	0	1
Ogden	21	\$1.16	13	1,212,082	3,996,332	\$0.91	\$0.20	1	7
Park City	14	\$0.53	6	358,037	1,044,263	\$0.41	\$0.20	0	8
Price	2	\$7.20	1	156,189	446,255	\$7.04	\$2.34	0	1
Richfield	4	\$22.20	2	125,844	172,202	\$7.00	\$4.29	0	2
SLC Metro	36	\$2.94	17	811,924	2,728,056	\$2.24	\$0.71	0	19
Smithfield	2	\$0.88	1	138,377	395,363	\$0.23	\$0.12	0	1
Tooele	11	\$0.97	4	705,661	1,546,001	\$1.90	\$0.45	0	7
Tremonton	2	\$28.26	1	6,485	9,977	\$2.31	\$2.39	0	1
Total	158	\$2.13	81	5,408,969	16,280,158	\$1.66	\$0.52	2	75

*Metrics cover RWP's approved between 1/1/2018 and 12/31/2020

4 Customer Response

4.1 Telephone Service and Response to Commission Complaints

COMMITMENT	GOAL	PERFORMANCE
PS5-Answer calls within 30 seconds	80%	85%
PS6a) Respond to commission complaints within 3 days	95%	100%
PS6b) Respond to commission complaints regarding service disconnects within 4 hours	95%	100%
PS6c) Address commission ⁴ complaints within 30 days	100%	100%

4.2 Utah Commitment U1

To identify when a ‘wide-scale’ outage has occurred, the company examines call data for customers who have selected either the power emergency or power outage option within the company’s call menu. However, in order to report on performance during a ‘wide-scale’ outage, the company must use network information, which provides information for all call types, not just outage calls. Therefore, using the menu level data the company has identified the time intervals that exceed the agreed upon standard 2,000 calls/hour, and reports the network level statistics for the same intervals.

For the reporting period, there were six days identified as wide-scale outage days; call statistics are shown in the table below. On January 15th the Roseburg and Myrtle Creek areas in Oregon experienced an outage as the result of a Loss of Transmission Line causing outages to over 10,000 customers. On July 21st the Portland area in Oregon experienced an outage as the result of a Loss of Transmission Line causing outages to over 34,000 customers. From September 8th through 11th, a catastrophic windstorm caused outages to approximately 220,000 Rocky Mountain Power Customers and 60,000 Pacific Power customers at peak and caused extended restoration times due to the extent of damages across all six states.

Date	Interval start/finish (MT Time)		Network Total Calls*	Calls received but not delivered**	# of Calls Abandoned from Agent Queue	Max Delay Time Seconds***	ASA Seconds
1/15/2020	12:00	12:14	996	0	115	579	176
	12:15	12:29	669	0	29	365	55
	12:30	12:44	504	0	3	79	16
	12:45	12:59	508	0	7	173	24
7/21/2020	14:00	14:14	1225	388	69	123.0753	37
	14:15	14:29	1218	327	63	157.2704	67

⁴ Rocky Mountain Power follows the definitions for informal and formal complaints as set forth in the Utah Code, Title 54, Public Utilities Statutes and Public Service Commission Rules, R746-200-8 Informal review (A) and Commission review (D).

UTAH

January 1 – December 31, 2020

Date	Interval start/finish (MT Time)		Network Total Calls*	Calls received but not delivered**	# of Calls Abandoned from Agent Queue	Max Delay Time Seconds***	ASA Seconds
	14:30	14:44	370	0	2	91.00433	16
	14:45	14:59	304	0	3	96.12299	14
9/8/2020	8:00	8:15	2253	1723	289	6335	560
	8:15	8:29	2191	1669	291	5542	586
	8:30	8:44	2177	1628	260	5175	484
	8:45	8:59	2159	1583	255	4482	539
	9:00	9:15	2126	1578	221	3780	399
	9:15	9:29	2157	1610	198	3031	439
	9:30	9:44	2098	1491	193	2988	255
	9:45	9:59	2080	1471	171	583	64
	10:00	10:14	2393	1688	169	779	48
	10:15	10:29	1678	1209	101	295	31
	10:30	10:44	2116	1233	164	2916	305
	10:45	10:59	1976	930	129	2643	249
	11:00	11:14	2064	1062	171	1981	264
	11:15	11:29	2110	1132	155	1114	287
	11:30	11:44	1947	1072	241	1370	380
	11:45	11:59	1919	956	191	941	328
	12:00	12:14	1890	898	151	1524	332
	12:15	12:29	1797	720	179	870	304
	12:30	12:44	1840	726	148	685	248
	12:45	12:59	1977	804	164	732	252
	13:00	13:14	1913	827	173	1101	336
	13:15	13:29	1880	789	163	1181	274
	13:30	13:44	1931	816	190	1161	225
	13:45	13:59	1978	814	140	1103	189
	14:00	14:14	1798	701	122	940	251
	14:15	14:29	1868	724	132	1325	237
	14:30	14:44	1879	759	113	794	254
	14:45	14:59	1950	826	160	789	250
	15:00	15:14	2028	846	158	777	257
	15:15	15:29	2093	927	121	1005	239
15:30	15:44	1995	882	112	764	237	
15:45	15:59	1839	645	97	669	190	

UTAH

January 1 – December 31, 2020

Date	Interval start/finish (MT Time)		Network Total Calls*	Calls received but not delivered**	# of Calls Abandoned from Agent Queue	Max Delay Time Seconds***	ASA Seconds
	16:00	16:14	1858	667	85	553	184
	16:15	16:29	1886	686	87	725	164
	16:30	16:44	1977	712	82	748	161
	16:45	16:59	2060	815	50	667	137
9/9/2020	8:00	8:15	575	0	34	914	114
	8:15	8:29	552	0	48	697	139
	8:30	8:44	591	0	65	1203	186
	8:45	8:59	610	0	52	953	214
	9:00	9:15	715	0	47	1420	203
	9:15	9:29	719	0	69	1245	182
	9:30	9:44	746	0	85	1576	251
	9:45	9:59	677	0	62	663	249
	10:00	10:14	719	0	49	631	187
	10:15	10:29	779	0	44	801	158
	10:30	10:44	771	0	43	794	154
	10:45	10:59	749	0	53	1511	211
	11:00	11:14	776	0	93	769	223
	11:15	11:29	741	0	53	1281	205
	11:30	11:44	683	0	41	635	167
	11:45	11:59	634	0	55	645	198
	12:00	12:14	700	0	81	1001	230
	12:15	12:29	641	0	69	923	179
	12:30	12:44	664	0	50	573	146
	12:45	12:59	961	38	57	779	240
	13:00	13:14	887	27	93	575	305
	13:15	13:29	737	0	64	1731	249
	13:30	13:44	770	0	59	649	170
	13:45	13:59	721	0	72	1058	173
	14:00	14:14	669	0	42	1079	183
	14:15	14:29	689	0	32	598	138
	14:30	14:44	664	0	48	463	160
	14:45	14:59	723	0	67	751	198
15:00	15:14	699	0	68	1599	213	
15:15	15:29	737	0	90	706	292	

UTAH

January 1 – December 31, 2020

Date	Interval start/finish (MT Time)		Network Total Calls*	Calls received but not delivered**	# of Calls Abandoned from Agent Queue	Max Delay Time Seconds***	ASA Seconds
	15:30	15:44	835	12	102	1207	288
	15:45	15:59	744	0	70	857	236
	16:00	16:14	686	0	60	644	222
	16:15	16:29	648	0	36	513	147
	16:30	16:44	702	0	55	688	187
	16:45	16:59	629	0	65	580	224
9/10/2020	8:00	8:15	292	0	2	32	7
	8:15	8:29	361	0	3	48	15
	8:30	8:44	376	0	1	59	18
	8:45	8:59	382	0	1	111	30
	9:00	9:15	504	0	3	67	15
	9:15	9:29	503	0	3	65	19
	9:30	9:44	574	0	10	245	79
	9:45	9:59	503	0	12	250	132
	10:00	10:14	517	0	1	103	38
	10:15	10:29	543	0	1	68	23
	10:30	10:44	563	0	1	83	24
	10:45	10:59	526	0	1	92	32
	11:00	11:14	576	0	4	140	61
	11:15	11:29	623	0	1	62	16
	11:30	11:44	559	0	3	103	30
	11:45	11:59	521	0	1	50	14
	12:00	12:14	516	0	2	39	12
	12:15	12:29	547	0	0	107	28
	12:30	12:44	596	0	5	155	59
	12:45	12:59	499	0	5	110	48
	13:00	13:14	521	0	1	41	14
	13:15	13:29	473	0	1	70	18
	13:30	13:44	504	0	1	39	14
	13:45	13:59	493	0	2	83	19
14:00	14:14	482	0	5	79	21	
14:15	14:29	518	0	1	79	19	
14:30	14:44	443	0	2	85	28	
14:45	14:59	498	0	1	89	25	

UTAH

January 1 – December 31, 2020

Date	Interval start/finish (MT Time)		Network Total Calls*	Calls received but not delivered**	# of Calls Abandoned from Agent Queue	Max Delay Time Seconds***	ASA Seconds
	15:00	15:14	568	0	5	111	47
	15:15	15:29	500	0	3	73	25
	15:30	15:44	605	0	2	101	44
	15:45	15:59	554	0	3	190	55
	16:00	16:14	564	0	6	153	76
	16:15	16:29	577	0	5	164	40
	16:30	16:44	534	0	12	266	133
	16:45	16:59	512	0	28	333	192
9/11/2020	8:00	8:15	183	151	1	50	50
	8:15	8:29	183	145	1	52	52
	8:30	8:44	224	168	2	52	52
	8:45	8:59	270	164	5	84	84
	9:00	9:15	290	191	1	130	130
	9:15	9:29	323	178	2	112	112
	9:30	9:44	310	151	2	99	99
	9:45	9:59	316	160	1	89	89
	10:00	10:14	354	309	13	243	243
	10:15	10:29	380	235	2	114	114
	10:30	10:44	344	199	4	103	103
	10:45	10:59	353	221	7	207	207
	11:00	11:14	335	187	7	133	133
	11:15	11:29	360	244	2	66	66
	11:30	11:44	358	205	5	129	129
	11:45	11:59	323	174	1	78	78
	12:00	12:14	315	152	0	115	115
	12:15	12:29	337	179	5	83	83
	12:30	12:44	350	161	2	92	92
	12:45	12:59	348	167	18	279	279
	13:00	13:14	335	136	14	244	244
	13:15	13:29	286	120	0	98	98
	13:30	13:44	327	117	3	149	149
	13:45	13:59	296	101	2	101	101
14:00	14:14	306	103	2	114	114	
14:15	14:29	294	125	1	118	118	

UTAH

January 1 – December 31, 2020

Date	Interval start/finish (MT Time)		Network Total Calls*	Calls received but not delivered**	# of Calls Abandoned from Agent Queue	Max Delay Time Seconds***	ASA Seconds
	14:30	14:44	305	115	0	210	210
	14:45	14:59	331	135	2	181	181
	15:00	15:14	334	112	3	165	165
	15:15	15:29	298	116	1	129	129
	15:30	15:44	348	118	2	102	102
	15:45	15:59	307	9	2	95	95
	16:00	16:14	318	0	1	111	111
	16:15	16:29	328	0	3	123	123
	16:30	16:44	300	95	1	143	143
	16:45	16:59	287	119	0	100	100

* All customers attempting to reach PacifiCorp Network.

** When Twenty First Century is manually invoked, the AT&T Network returns a courtesy message to non-outage callers. This includes repeated attempts.

*** Longest time any customer waited.

4.3 Utah State Customer Guarantee Summary Status

 customer *guarantees*

January to December 2020

Utah

Description	2020				2019			
	Events	Failures	% Success	Paid	Events	Failures	% Success	Paid
CG1 Restoring Supply	889,460	0	100.00%	\$0	933,114	0	100.00%	\$0
CG2 Appointments	8,836	0	100.00%	\$0	9,333	4	99.96%	\$200
CG3 Switching on Power	2,331	0	100.00%	\$0	4,042	0	100.00%	\$0
CG4 Estimates	1,455	4	99.73%	\$200	1,415	3	99.79%	\$150
CG5 Respond to Billing Inquiries	1,989	1	99.95%	\$50	2,335	7	99.70%	\$350
CG6 Respond to Meter Problems	756	0	100.00%	\$0	686	1	99.85%	\$50
CG7 Notification of Planned Interruptions	161,097	15	99.99%	\$750	187,372	37	99.98%	\$1,850
	1,065,924	20	99.99%	\$1,000	1,138,297	52	100.00%	\$2,600

Overall Customer Guarantee performance remains above 99 percent, demonstrating Rocky Mountain Power's continued commitment to customer satisfaction.

Major Events are excluded from the Customer Guarantees program. The program also defines certain exemptions, which are primarily for safety, access to outage site, and emergencies.

5 Maintenance Compliance to Annual Plan

5.1 T&D Preventive and Corrective Maintenance Programs

Preventive Maintenance

The primary focus of the preventive maintenance plan is to inspect facilities, identify abnormal conditions⁵, and perform appropriate preventive actions upon those facilities. On-going assessment of policies, including their costs and benefits, will result in modifications to them. As the Company continues this assessment, further variations of the policies will result in refinement to the maintenance plan.

Transmission and Distribution Lines

- Visual assurance inspections are designed to identify damage or defects that may endanger public safety or adversely affect the integrity of the electric system.
- Detailed inspections are in depth visual inspections of each structure and the spans between each structure or pad-mounted distribution equipment.⁶
- Pole testing includes a sound and bore to identify decay pockets that would compromise the wood pole's structural integrity.

Substations and Major Equipment

- Rocky Mountain Power inspects and maintains substations and associated equipment to ascertain all components within the substation are operating as expected. Abnormal conditions that are identified are prioritized for repair (corrective maintenance).
- Rocky Mountain Power has a condition-based maintenance program for substation equipment including load tap changers, regulators, and transmission circuit breakers. Diagnostic testing is performed on a time-based interval and the results are analyzed to determine if the equipment is suitable for service or maintenance tasks to be performed. Protection system and communication system maintenance is performed based on a time interval basis.

Corrective Maintenance

The primary focus of the corrective maintenance plan is to correct the abnormal conditions found during the preventive maintenance process.

Transmission and Distribution Lines

⁵ The primary focus of the preventive maintenance plan is to inspect facilities, identify abnormal conditions, and perform appropriate preventive actions upon those facilities. Condition priorities are as follows:

Priority A: Conditions that pose a potential but not immediate hazard to the public or employees, or that risk loss of supply or damage to the electrical system.

Priority B: Conditions that are nonconforming, but that in the opinion of the inspector do not pose a hazard.

Priority C: Conditions that are nonconforming, but that in the opinion of the inspector do not need to be corrected until the next scheduled work is performed on that facility point.

Priority D: Conditions that conform to the NESC and are not reportable to the associated State Commission. Priority G: Conditions that conform to the regulations requirement that was in place when construction took place but do not conform to more recent code adoptions. These conditions are "grandfathered" and are considered conforming.

⁶ Effective 1/1/2007, Rocky Mountain Power modified its reliability & preventive planning methods to utilize repeated reliability events to prioritize localized preventive maintenance activities, using its Reliability Work Planning methodology. At this time, repeated outage events experienced by customers will result in localized inspection and correction activities, rather than being programmatically performed at either the entire circuit or map section level.

UTAH


January 1 – December 31, 2020

- Correctable conditions are identified through the preventive maintenance process.
- Outstanding conditions are recorded in a database and remain until corrected.


Substations and Major Equipment

- Correctable conditions are identified through the preventive maintenance process, often associated with actions performed on major equipment.
- Corrections consist of repairing equipment or responding to a failed condition.

5.2 Maintenance Spending




5.2.1 Maintenance Historical Spending



5.3 Distribution Priority “A” Conditions Correction History

Rocky Mountain Power is committed to correcting Priority “A” Conditions with an average age or 120 days or less. The Company believes that it is a useful indicator of its commitment to providing safe and reliable service to its Utah customers. As shown in the graph below, Rocky Mountain Power consistently delivers an average age of Priority “A” Conditions well below the 120 day target.





6 Capital Investment

6.1 Capital Spending - Distribution and General Plant

January – December 2020

Investment	Actuals (\$M)	Plan (\$M)	Significant Variances
1. Mandated	\$27.7	\$41.0	Mandated wildfire mitigation, and net metering under plan, (-\$14.5M).
2. New Connect	\$88.2	\$89.6	Industrial new revenue connections over plan, (+\$4.0M -- including Biofire Diagnostics +\$2.6M, Tyson Foods +\$1.7M, and Cal-Maine Foods -\$2.5M); commercial new revenue connections under plan, (-\$4.5M -- including NWQ -\$8.6M, and Salt Lake Airport +\$2.3M).
3. System Reinforcement	\$18.0	\$19.0	Substation reinforcements under plan, (-\$1.9M -- including Timp 30 MVA Xfmr -\$1.4M, and 90th South 30 MVA Xfmr -\$1.7M).
4. Replacement	\$76.7	\$65.0	Replacements for storm & casualty, vehicles, overhead distribution poles, UG cable, and abandoned facilities removal over plan, (+\$14.4M); replacements for overhead distribution lines, and substation equipment under plan, (-\$2.9M).
5. Upgrade & Modernize	\$17.3	\$30.0	Substation improvements over plan, (+\$1.1M); feeder improvements, and functional upgrade reliability under plan (-\$13.6M -- including Automated Metering Infrastructure -\$11.5M under plan due to project timing).
Total	\$227.9	\$244.6	





*Actual costs shown are expenditure values, not plant placed in service (PPIS) values. Actual expenditures are not directly tied to PPIS values.

6.2 Capital Spending – Transmission/Interconnections

January – December 2020

Investment	Actuals (\$M)	Plan (\$M)	Significant Variances
1. Mandated	\$11.7	\$31.1	Mandated environmental/avian protection over plan, (+\$1.0M); mandated wildfire mitigation, and right of way renewals under plan, (-\$20.0M).
2. New Connect	\$5.0	\$3.5	Commercial new revenue connections, and industrial new revenue connections over plan, (+\$1.5M).
3. Local Transmission System Reinforcements	\$8.5	\$15.6	Substation reinforcement over plan, (+\$2.5M -- including Draper 138kV Conversion +\$3.5M); subtransmission reinforcement under plan, (-\$9.6M -- including Jordanelle-Midway 138kV Ln w/Heber -\$8.9M under plan due to permitting issues).
4.** Main Grid Reinforcements / Interconnections	\$30.0	***\$58.0	Naples 138-12.5 kV New Substation over plan, (+\$4.0M); Q2469 PAC ESA Milford Solar TSR under plan (delay in steel pole deliveries moved project in-service into 2021), (-\$4.1M); Q0155 UAMPS Heber Light & Power under plan, (-\$2.5M); unidentified main grid/generation interconnections under plan, see note below*** (-\$23.9M).
5.** Energy Gateway Transmission	\$1.8	\$1.2	
6. Replacement	\$17.2	\$23.8	Replacements for substation transformers, and substation switchgear/breakers/reclosers under plan, (-\$7.0M -- including Mobile #6 Failed Xfmr Replacement -\$3.4M).
7. Upgrade & Modernize	\$2.4	\$3.7	Substation improvements under plan, (-\$1.8M -- including Pavant Xfmr Protection - \$1.2M).
Total	\$76.6	\$136.9	



* Actual costs shown are expenditure values, not plant placed in service (PPIS) values. Actual expenditures are not directly tied to PPIS values. ** Main Grid Reinforcement/Interconnections and Energy Gateway Transmission values include a small amount of General Plant \$ for communications work. *** Unidentified main grid/generation interconnection projects are managed at the program level. Plan funding is 100% allocated to Utah, by necessity, for Plan application purposes only. Actual funding is reallocated to specific projects across PacifiCorp as identified or as customer agreements are signed, not necessarily within the state of Utah.

6.3 New Connects

	2019	2020												
	YEAR	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	YEAR
Residential														
UT South	1,694	154	96	140	164	141	182	143	175	213	160	193	174	1,935
UT North/Metro	8,170	661	567	705	813	686	715	640	786	542	1,073	1,037	979	9,204
UT Central	16,504	1,454	1,426	1,426	1,307	1,300	1,218	1,582	1,275	1,381	1,914	1,611	1,669	17,563
Total Residential	26,368	2,269	2,089	2,271	2,284	2,127	2,115	2,365	2,236	2,136	3,147	2,841	2,822	28,702
Commercial														
UT South	265	22	25	23	31	18	43	19	21	28	24	23	30	307
UT North/Metro	839	96	55	77	97	114	112	74	80	88	129	118	147	1,187
UT Central	1,137	116	85	95	172	140	153	153	137	138	164	141	178	1,672
Total Commercial	2,241	234	165	195	300	272	308	246	238	254	317	282	355	3,166
Industrial														
UT South	0	0	0	0	1	0	0	0	0	0	0	0	0	1
UT North/Metro	0	0	0	0	0	0	0	0	0	0	0	0	0	0
UT Central	5	0	0	0	0	0	1	0	1	0	0	0	2	4
Total Industrial	5	0	0	0	1	0	1	0	1	0	0	0	2	5
Irrigation														
UT South	39	2	2	5	12	4	9	2	3	1	3	1	3	47
UT North/Metro	6	0	0	0	0	3	0	0	2	0	1	1	0	7
UT Central	9	2	0	2	2	0	1	0	0	0	0	1	1	9
Total Irrigation	54	4	2	7	14	7	10	2	5	1	4	3	4	63
TOTAL New Connects														
UT South	1,998	178	123	168	208	163	234	164	199	242	187	217	207	2,290
UT North/Metro	9,015	757	622	782	910	803	827	714	868	630	1,203	1,156	1,126	10,398
UT Central	17,655	1,572	1,511	1,523	1,481	1,440	1,373	1,735	1,413	1,519	2,078	1,753	1,850	19,248
TOTAL New Connects	28,668	2,507	2,256	2,473	2,599	2,406	2,434	2,613	2,480	2,391	3,468	3,126	3,183	31,936

Utah South region includes Moab, Price, Cedar City and Richfield

Utah North/Metro region includes SLC Metro, Ogden and Layton

Utah Central region included American Fork, Vernal, Toole, Jordan Valley and Park City

Region areas are subject to change for operational purposes and may differ from historical reporting.

Smithfield, Tremonton, and Laketown are excluded because the report was developed using a prior coding system that included them under ID/ WY WEST and not Utah. Beginning in 2021, Rocky Mountain Power implemented a new reporting system for customer service data. Volumes in January through June values are being restated utilizing the new reporting methodology that better identifies new connects in the months that service was established.

UTAH

January 1 – December 31, 2020

7 Vegetation Management

7.1 Production

UTAH
Tree Program Reporting
January 1, 2020 through December 31, 2020
Distribution

	Total 3 Year Program/Total Line Miles	Calendar Year Reporting				Cycle Reporting			
		1/1/2020- 12/31/2020 Miles Planned	1/1/2020- 12/31/2020 Actual Miles	1/1/2020- 12/31/2020 Ahead/Behind	1/1/2020- 12/31/2020 % Ahead/Behind	1/1/2020- 12/31/2022 Miles Planned	1/1/2020- 12/31/2022 Actual Miles	01/01/2020- 12/31/2022 Ahead/Behind	1/1/2020- 12/31/2022 % Ahead/Behind
		column a	column b	column c	column d	column e	column f	column g	column h
UTAH	10,840	3,872	3,872	0	100.0%	3,872	3,872	0	100.0%
AMERICAN FORK	942	175	175	0	100.0%	175	175	0	100.0%
CEDAR CITY	1,379	684	684	0	100.0%	684	684	0	100.0%
JORDAN VALLEY	802	516	516	0	100.0%	516	516	0	100.0%
LAYTON	296	28	28	0	100.0%	28	28	0	100.0%
MOAB	625	166	166	0	100.0%	166	166	0	100.0%
OGDEN	958	357	357	0	100.0%	357	357	0	100.0%
PARK CITY	546	217	217	0	100.0%	217	217	0	100.0%
PRICE	595	318	318	0	100.0%	318	318	0	100.0%
RICHFIELD	1,243	158	158	0	100.0%	158	158	0	100.0%
SL METRO	1,261	336	336	0	100.0%	336	336	0	100.0%
SMITHFIELD	766	276	276	0	100.0%	276	276	0	100.0%
TOOELE	494	94	94	0	100.0%	94	94	0	100.0%
TREMONTON	678	460	460	0	100.0%	460	460	0	100.0%
VERNAL	255	87	87	0	100.0%	87	87	0	100.0%

Distribution cycle \$/tree:	\$155
Distribution cycle \$/mile:	\$2,828
Distribution cycle removal %	6.67%

Transmission

Total Line Miles	Line Miles Scheduled	Line Miles Worked	Miles Ahead(behind) Schedule	% of miles on/behind Schedule
6,575	1,276	1,197	(79)	94%

Current distribution cycle began January 1, 2020 and extends until December 31, 2022.

Notes:

- Column a: Total overhead distribution pole miles by district
- Column b: Total overhead distribution pole miles planned for the period January 1, 2020 through December 31, 2020
- Column c: Actual overhead distribution pole miles worked during the period January 1, 2020 through December 31, 2020
- Column d: Miles ahead or behind for the period January 1, 2020 through December 31, 2020 (column c-column b)
- Column e: Percent of actual compared to planned for the period January 1, 2020 through December 31, 2020 ((column c÷b)×100)
- Column f: Total overhead distribution pole miles planned for the period January 1, 2020 through December 31, 2022
- Column g: Actual overhead distribution pole miles worked during the period January 1 2020 through December 31, 2022
- Column h: Miles ahead or behind for the period January 1, 2020 through December 31, 2022 (column g-column f)
- Column i: Percent of actual compared to planned for the period January 1, 2020 through December 31, 2022 ((column g÷f)×100). Max = 100%

UTAH

January 1 – December 31, 2020

7.2 Budget


UTAH
Tree Program Reporting

	CY2020	CY2021	CY2022
Distribution	\$13,250,259	\$13,250,259	\$13,250,259
Transmission	\$1,776,556	\$1,776,556	\$1,776,556
Total Tree Budget	\$15,026,815	\$15,026,815	\$15,026,815

Calendar Year 2020	Distribution			Transmission		
	Actuals	Budget	Variance	Actuals	Budget	Variance
Jan	\$957,259	\$1,143,156	-\$185,897	\$91,334	\$41,967	\$49,367
Feb	\$743,146	\$863,031	-\$119,884	\$90,292	\$40,959	\$49,333
Mar	\$1,090,070	\$1,086,180	\$3,890	\$86,038	\$103,351	-\$17,313
Apr	\$1,176,070	\$1,306,385	-\$130,315	\$89,998	\$111,575	-\$21,577
May	\$1,164,245	\$1,152,899	\$11,346	\$115,136	\$99,047	\$16,089
Jun	\$1,386,175	\$1,051,283	\$334,892	\$59,189	\$372,611	-\$313,422
Jul	\$1,083,743	\$636,799	\$446,944	\$176,228	\$242,579	-\$66,351
Aug	\$1,132,685	\$1,013,333	\$119,352	\$75,179	\$147,999	-\$72,820
Sep	\$1,092,421	\$1,023,971	\$68,450	\$145,550	\$131,198	\$14,352
Oct	\$1,985,533	\$1,422,887	\$562,646	\$176,519	\$122,178	\$54,341
Nov	\$2,241,499	\$1,309,080	\$932,419	\$109,123	\$94,676	\$14,447
Dec	\$2,161,580	\$1,241,256	\$920,325	\$83,800	\$268,416	-\$184,616
Total	\$16,214,426	\$13,250,259	\$2,964,167	\$1,298,388	\$1,776,556	\$(478,168)

Average # Tree Crews on Property (YTD) 82

7.2.1 Vegetation Historical Spending



8 Standard Guarantees/Program Summary

8.1 Service Standards Program Summary⁷

8.1.1 Rocky Mountain Power Customer Guarantees

<u>Customer Guarantee 1:</u> Restoring Supply After an Outage	The Company will restore supply after an outage within 24 hours of notification with certain exceptions as described in Rule 25.
<u>Customer Guarantee 2:</u> Appointments	The Company will keep mutually agreed upon appointments, which will be scheduled within a two-hour time window.
<u>Customer Guarantee 3:</u> Switching on Power	The Company will switch on power within 24 hours of the customer or applicant's request, provided no construction is required, all government inspections are met and communicated to the Company and required payments are made. Disconnection for nonpayment, subterfuge or theft/diversion of service is excluded.
<u>Customer Guarantee 4:</u> Estimates For New Supply	The Company will provide an estimate for new supply to the applicant or customer within 15 working days after the initial meeting and all necessary information is provided to the Company and any required payments are made.
<u>Customer Guarantee 5:</u> Respond To Billing Inquiries	The Company will respond to most billing inquiries at the time of the initial contact. For those that require further investigation, the Company will investigate and respond to the Customer within 10 working days.
<u>Customer Guarantee 6:</u> Resolving Meter Problems	The Company will investigate and respond to reported problems with a meter or conduct a meter test and report results to the customer within 10 working days.
<u>Customer Guarantee 7:</u> Notification of Planned Interruptions	The Company will provide the customer with at least two days' notice prior to turning off power for planned interruptions consistent will Rule 25 and relevant exemptions.

Note: See Rule 25 for a complete description of terms and conditions for the Customer Guarantee Program.

⁷ In 2012, rules were codified in Utah Administrative Code R746-313. The Company, Commission and other stakeholders worked to develop mechanisms that comply with these rules and supersedes the Company's Service Standards Program.

8.1.2 Rocky Mountain Power Performance Standards⁸

<u>*Network Performance Standard 1:</u> Improve System Average Interruption Duration Index (SAIDI)	In 2016 Utah Commission adopted a modified 365-day rolling (rather than calendar year) performance baseline control zone of between 137-187 minutes.
<u>*Network Performance Standard 2:</u> Improve System Average Interruption Frequency Index (SAIFI)	In 2016 Utah Commission adopted a modified 365-day rolling (rather than calendar year) performance baseline control zone of between 1.0-1.6 events.
<u>Network Performance Standard 3:</u> Improve Under Performing System Segments	The Company will identify underperforming circuit segments and outline improvement actions and their costs, and using the Open Reliability Reporting (ORR) process, evidence the outcome of the ORR process for the circuit segments chosen ⁹ .
<u>*Network Performance Standard 4:</u> Supply Restoration	The Company will restore power outages due to loss of supply or damage to the distribution system within three hours to 80% of customers on average.
<u>Customer Service Performance Standard 5:</u> Telephone Service Level	The Company will answer 80% of telephone calls within 30 seconds. The Company will monitor customer satisfaction with the Company's Customer Service Associates and quality of response received by customers through the Company's eQuality monitoring system.
<u>Customer Service Performance Standard 6:</u> Commission Complaint Response/Resolution	The Company will a) respond to at least 95% of non-disconnect Commission complaints within three working days; b) respond to at least 95% of disconnect Commission complaints within four working hours; and c) resolve 95% of informal Commission complaints within 30 days, except in Utah where the Company will resolve 100% of informal Commission complaints within 30 days.

*Note: Performance Standards 1, 2 & 4 are for underlying performance days and exclude Major Events.

⁸ On December 20, 2016, the Public Service Commission of Utah approved modified electric service reliability performance baseline notification levels of 187 SAIDI minutes and 1.6 SAIFI events, with proposed baseline control zones of 137-187 SAIDI and 1.0-1.6 SAIFI (Docket NOS. 13-035-01 and 15-035-72).


⁹ On June 1, 2107, in Dockets 15-035-72 and 08-035-55, the Commission approved modified reliability improvement methods with the Company's Open Reliability Reporting (ORR) process, in which the Commission concluded that the process reasonably satisfies the requirements of Utah Administrative Code R746-313-7(3)(e) relating to reporting on electric service reliability for areas whose reliability performance warrants additional improvement efforts. This change is reflected in Section 2.8.

UTAH

January 1 – December 31, 2020

8.1.3 Utah Distribution Service Area Map with Operating Areas/Districts

Below is a graphic showing the specific areas where the Company's distribution facilities are located.



8.2 Cause Code Analysis

The tables below outline categories used in outage data collection. Subsequent charts and table use these groupings to develop patterns for outage performance.

Direct Cause Category	Category Definition & Example/Direct Cause
Animals	Any problem nest that requires removal, relocation, trimming, etc.; any birds, squirrels or other animals, whether or not remains found.
	<ul style="list-style-type: none"> • Animal (Animals) • Bird Mortality (Non-protected species) • Bird Mortality (Protected species)(BMTS) • Bird Nest • Bird or Nest • Bird Suspected, No Mortality
Environment	Contamination or Airborne Deposit (i.e. salt, trona ash, other chemical dust, sawdust, etc.); corrosive environment; flooding due to rivers, broken water main, etc.; fire/smoke related to forest, brush or building fires (not including fires due to faults or lightning).
	<ul style="list-style-type: none"> • Condensation/Moisture • Contamination • Fire/Smoke (not due to faults) • Flooding • Major Storm or Disaster • Nearby Fault • Pole Fire
Equipment Failure	Structural deterioration due to age (incl. pole rot); electrical load above limits; failure for no apparent reason; conditions resulting in a pole/cross arm fire due to reduced insulation qualities; equipment affected by fault on nearby equipment (e.g., broken conductor hits another line).
	<ul style="list-style-type: none"> • B/O Equipment • Overload • Deterioration or Rotting • Substation, Relays
Interference	Willful damage, interference or theft; such as gun shots, rock throwing, etc.; customer, contractor or other utility dig-in; contact by outside utility, contractor or other third-party individual; vehicle accident, including car, truck, tractor, aircraft, manned balloon; other interfering object such as straw, shoes, string, balloon.
	<ul style="list-style-type: none"> • Dig-in (Non-PacifiCorp Personnel) • Other Interfering Object • Vandalism or Theft • Other Utility/Contractor • Vehicle Accident
Loss of Supply	Failure of supply from Generator or Transmission system; failure of distribution substation equipment.
	<ul style="list-style-type: none"> • Failure on other line or station • Loss of Feed from Supplier • Loss of Generator • Loss of Substation • Loss of Transmission Line • System Protection
Operational	Accidental Contact by PacifiCorp or PacifiCorp's Contractors (including live-line work); switching error; testing or commissioning error; relay setting error, including wrong fuse size, equipment by-passed; incorrect circuit records or identification; faulty installation or construction; operational or safety restriction.
	<ul style="list-style-type: none"> • Contact by PacifiCorp • Faulty Install • Improper Protective Coordination • Incorrect Records • Internal Contractor • Internal Tree Contractor • Switching Error • Testing/Startup Error • Unsafe Situation
Other	Cause Unknown; use comments field if there are some possible reasons.
	<ul style="list-style-type: none"> • Invalid Code • Other, Known Cause • Unknown
Planned	Transmission requested, affects distribution sub and distribution circuits; Company outage taken to make repairs after storm damage, car hit pole, etc.; construction work, regardless if notice is given; rolling blackouts.
	<ul style="list-style-type: none"> • Construction • Customer Notice Given • Energy Emergency Interruption • Intentional to Clear Trouble • Emergency Damage Repair • Customer Requested • Planned Notice Exempt • Transmission Requested
Tree	Growing or falling trees
	<ul style="list-style-type: none"> • Tree-Non-preventable • Tree-Trimable • Tree-Tree felled by Logger
Weather	Wind (excluding windborne material); snow, sleet or blizzard, ice, freezing fog, frost, lightning.
	<ul style="list-style-type: none"> • Extreme Cold/Heat • Freezing Fog & Frost • Wind • Lightning • Rain • Snow, Sleet, Ice and Blizzard

8.3 Reliability Definitions

Interruption Types

Below are the definitions for interruption events. For further details, refer to IEEE 1366-2003¹⁰ Standard for Reliability Indices.

Sustained Outage

A sustained outage is defined as an outage of greater than 5 minutes in duration.

Momentary Outage Event

A momentary outage is defined as an outage equal to or less than 5 minutes in duration. Rocky Mountain Power has historically captured this data using substation breaker fault counts, but where SCADA (Supervisory Control and Data Acquisition Systems) exist, uses this data to calculate consistent with IEEE 1366-2003.

Reliability Indices

SAIDI

SAIDI (system average interruption duration index) is an industry-defined term to define the average duration summed for all sustained outages a customer experiences in a given period. It is calculated by summing all customer minutes lost for sustained outages (those exceeding 5 minutes) and dividing by all customers served within the study area. When not explicitly stated otherwise, this value can be assumed to be for a one-year period.

Daily SAIDI

In order to evaluate trends during a year and to establish Major Event Thresholds, a daily SAIDI value is often used as a measure. This concept was introduced in IEEE Standard 1366-2003. This is the day's total customer minutes out of service divided by the static customer count for the year. It is the total average outage duration customers experienced for that given day. When these daily values are accumulated through the year, it yields the year's SAIDI results.

SAIFI

SAIFI (system average interruption frequency index) is an industry-defined term that attempts to identify the frequency of all sustained outages that the average customer experiences during a given time-frame. It is calculated by summing all customer interruptions for sustained outages (those exceeding 5 minutes in duration) and dividing by all customers served within the study area.

CAIDI

CAIDI (customer average interruption duration index) is an industry-defined term that is the result of dividing the duration of the average customer's sustained outages by the frequency of outages for that average customer. While the Company did not originally specify this metric under the umbrella of the Performance Standards Program within the context of the Service Standards Commitments, it has since been determined to be valuable for reporting purposes. It is derived by dividing PS1 (SAIDI) by PS2 (SAIFI).

¹⁰ IEEE 1366-2003 was adopted by the IEEE on December 23, 2003. It was subsequently modified in IEEE 1366-2012, but all definitions used in this document are consistent between these two versions. The definitions and methodology detailed therein are now industry standards. Later, in Docket No. 04-035-T13 the Utah Public Utilities Commission adopted the standard methodology for determining major event threshold.

UTAH

January 1 – December 31, 2020

MAIFI_E

MAIFI_E (momentary average interruption event frequency index) is an industry-defined term that attempts to identify the frequency of all momentary interruption events that the average customer experiences during a given time-frame. It is calculated by counting all momentary operations which occur within a 5 minute time period, as long as the sequence did not result in a device experiencing a sustained interruption. This series of actions typically occurs when the system is trying to re-establish energy flow after a faulted condition, and is associated with circuit breakers or other automatic reclosing devices.

Lockout

Lockout is the state of device when it attempts to re-establish energy flow after a faulted condition but is unable to do so; it systematically opens to de-energize the facilities downstream of the device then recloses until a lockout operation occurs. The device then requires manual intervention to re-energize downstream facilities. This is generally associated with substation circuit breakers and is one of the variables used in the Company's calculation of blended metrics.

CEMI

CEMI is an acronym for Customers Experiencing Multiple (Momentary Event and Sustained) Interruptions. This index depicts repetition of outages across the period being reported and can be an indicator of recent portions of the system that have experienced reliability challenges.

ORR

ORR is an acronym for Open Reliability Reporting, which shifts the company's reliability program from a circuit based metric (RPI) to a targeted approach reviewing performance in a local area, measured by customer minutes lost. Project funding is based on cost effectiveness as measured by the cost per avoided annual customer minute interrupted.

CPI99

CPI99 is an acronym for Circuit Performance Indicator, which uses key reliability metrics of the circuit to identify underperforming circuits. It excludes Major Event and Loss of Supply or Transmission outages. The variables and equation for calculating CPI are:

$$\text{CPI} = \text{Index} * ((\text{SAIDI} * \text{WF} * \text{NF}) + (\text{SAIFI} * \text{WF} * \text{NF}) + (\text{MAIFI}_E * \text{WF} * \text{NF}) + (\text{Lockouts} * \text{WF} * \text{NF}))$$

Index: 10.645

SAIDI: Weighting Factor 0.30, Normalizing Factor 0.029

SAIFI: Weighting Factor 0.30, Normalizing Factor 2.439

MAIFI_E: Weighting Factor 0.20, Normalizing Factor 0.70

Lockouts: Weighting Factor 0.20, Normalizing Factor 2.00

Therefore, $10.645 * ((3\text{-year SAIDI} * 0.30 * 0.029) + (3\text{-year SAIFI} * 0.30 * 2.439) + (3\text{-year MAIFI}_E * 0.20 * 0.70) + (3\text{-year breaker lockouts} * 0.20 * 2.00)) = \text{CPI Score}$

CPI05

CPI05 is an acronym for Circuit Performance Indicator, which uses key reliability metrics of the circuit to identify underperforming circuits. Unlike CPI99, it includes Major Event and Loss of Supply or Transmission outages. The calculation of CPI05 uses the same weighting and normalizing factors as CPI99.

Performance Types

Rocky Mountain Power recognizes several categories of performance; major events and underlying performance. Underlying performance days may be significant event days. Outages recorded during any day may be classified as "controllable" events.

UTAH

January 1 – December 31, 2020

Major Events

A Major Event (ME) is defined as a 24-hour period where SAIDI exceeds a statistically derived threshold value (Reliability Standard IEEE 1366-2012) based on the 2.5 beta methodology. The values used for the reporting period and the prospective period are shown below.

Effective Date	Customer Count	ME Threshold SAIDI	ME Customer Minutes Lost
1/1-12/31/2020	954,372	4.84	4,614,733

Significant Events

The Company has evaluated its year-to-year performance and as part of an industry weather normalization task force, sponsored by the IEEE Distribution Reliability Working Group, determined that when the Company recorded a day in excess of 1.75 beta (or 1.75 times the natural log standard deviation beyond the natural log daily average for the day's SAIDI) that generally these days' events are generally associated with weather events and serve as an indicator of a day which accrues substantial reliability metrics, adding to the cumulative reliability results for the period. As a result, the Company individually identifies these days so that year-on-year comparisons are informed by the quantity and their combined impact to the reporting period results.

Underlying Events

Within the industry, there has been a great need to develop methodologies to evaluate year-on-year performance. This has led to the development of methods for segregating outlier days, via the approaches described above. Those days which fall below the statistically derived threshold represent "underlying" performance, and are valid. If any changes have occurred in outage reporting processes, those impacts need to be considered when making comparisons. Underlying events include all sustained interruptions, whether of a controllable or non-controllable cause, exclusive of major events, prearranged (which can include short notice emergency prearranged outages), customer requested interruptions and forced outages mandated by public authority typically regarding safety in an emergency situation.

Controllable Distribution (CD) Events

In 2008, the Company identified the benefit of separating its tracking of outage causes into those that can be classified as "controllable" (and thereby reduced through preventive work) from those that are "non-controllable" (and thus cannot be mitigated through engineering programs); they will generally be referred to in subsequent text as controllable distribution (CD). For example, outages caused by deteriorated equipment or animal interference are classified as controllable distribution since the Company can take preventive measures with a high probability to avoid future recurrences; while vehicle interference or weather events are largely out of the Company's control and generally not avoidable through engineering programs. (It should be noted that Controllable Events is a subset of Underlying Events. The *Cause Code Analysis* section of this report contains two tables for Controllable Distribution and Non-controllable Distribution, which list the Company's performance by direct cause under each classification.) At the time that the Company established the determination of controllable and non-controllable distribution it undertook significant root cause analysis of each cause type and its proper categorization (either controllable or non-controllable). Thus, when outages are completed and evaluated, and if the outage cause designation is improperly identified as non-controllable, then it would result in correction to the outage's cause to preserve the association between controllable and non-controllable based on the outage cause code. The company distinguishes the performance delivered using this differentiation for comparing year to date performance against underlying and total performance metrics.

CERTIFICATE OF SERVICE

Docket No. 21-035-28

I hereby certify that on April 28, 2021, a true and correct copy of the foregoing was served by electronic mail to the following:

Utah Office of Consumer Services

Michele Beck mbeck@utah.gov
ocs@utah.gov

Division of Public Utilities

dpudatarequest@utah.gov

Assistant Attorney General

Patricia Schmid pschmid@agutah.gov
Justin Jetter jjetter@agutah.gov
Robert Moore rmoore@agutah.gov
Victor Copeland vcopeland@agutah.gov

Rocky Mountain Power

Data Request Response Center datarequest@pacificorp.com
Jana Saba jana.saba@pacificorp.com
utahdockets@pacificorp.com



Katie Savarin
Coordinator, Regulatory Operations