

October 7, 2021

VIA ELECTRONIC FILING

Public Service Commission of Utah Heber M. Wells Building, 4th Floor 160 East 300 South Salt Lake City, UT 84114

Attention: Gary Widerburg Commission Administrator

Re: Docket No. 21-035-54 Rocky Mountain Power's Application for a Certificate of Public Convenience and Necessity for the Gateway South Transmission Project

Rocky Mountain Power hereby submits for filing its Application for Certificate of Public Convenience and Necessity for the Gateway South Transmission Project. Enclosed are the confidential and non-confidential electronic copies of the testimony, exhibits, and workpapers in the file formats in which they were created.

Rocky Mountain Power respectfully requests that all formal correspondence and requests for additional information regarding this filing be addressed to the following:

By E-mail (preferred):

<u>datarequest@pacificorp.com</u> <u>jana.saba@pacificorp.com</u> john.hutchings@pacificorp.com

By regular mail:

Data Request Response Center PacifiCorp 825 NE Multnomah, Suite 2000 Portland, OR 97232

Informal inquiries may be directed to Jana Saba at (801) 220-2823.

Sincerely,

war Joelle Steward

Vice President, Regulation

cc: Service List

Richard Garlish John Hutchings 1407 West North Temple, Suite 320 Salt Lake City, Utah 84116 Telephone: (801) 220-2533 Facsimile: (801) 220-3299 Email: <u>richard.garlish@pacificorp.com</u> john.hutchings@pacificorp.com

Katherine McDowell (pro hac vice pending) Adam Lowney (pro hac vice pending) McDowell Rackner Gibson PC 419 SW 11th Avenue, Suite 400 Portland, Oregon 97205 Telephone: (503) 595-3924 Facsimile: (503) 595-3928 Email: <u>katherine@mrg-law.com</u> <u>adam@mrg-law.com</u>

Attorneys for Rocky Mountain Power

BEFORE THE PUBLIC SERVICE COMMISSION OF UTAH

IN THE MATTER OF THE APPLICATION OF)	
ROCKY MOUNTAIN POWER FOR A)	Docket No. 21-035-54
CERTIFICATE OF PUBLIC)	
CONVENIENCE AND NECESSITY FOR THE)	
GATEWAY SOUTH TRANSMISSION PROJECT)	
)	

PacifiCorp, d/b/a Rocky Mountain Power (the "Company"), in accordance with Utah Code Ann. § 54-4-25, respectfully submits this Application to the Public Service Commission of Utah ("Commission") requesting an order granting a certificate of public convenience and necessity ("CPCN") to construct the 416-mile Gateway South 500-kilovolt ("kV") transmission line. Approximately one-third of the line, or 183 miles, is in Utah, with the balance located in Colorado and Wyoming. Gateway South is Segment F of the Energy Gateway Transmission Expansion Project ("Energy Gateway"), which has long been recognized as a least-cost, least-risk transmission expansion plan for PacifiCorp, Utah, and the region. Since 2008, the Commission has granted CPCNs or approved resource decisions for the Populus-Terminal transmission line, the Mona-Oquirrh transmission line, the Sigurd-Red Butte transmission line, and the Aeolus-Bridger/Anticline transmission line—all of which are integral components of Energy Gateway.¹ The Company is moving forward with Gateway South as the next Energy Gateway development because current circumstances make it both necessary and economic.

First, PacifiCorp is obligated under its Open Access Transmission Tariff ("OATT") to reliably accommodate nearly 2,500 megawatts ("MW") of interconnection and transmission service requests governed by 13 executed contracts that require the construction of Gateway South. The Company must provide reliable transmission and interconnection service in accordance with the rates, terms, and conditions of PacifiCorp's OATT, which is subject to the exclusive jurisdiction of the Federal Energy Regulatory Commission ("FERC"). Where a request for OATT service cannot be reliably provided on the existing system, the Company's

¹ See In the Matter of the Application of Rocky Mountain Power for a Certificate of Public Convenience and Necessity Authorizing Construction of the Populus-to-Terminal 345 kV Transmission Line Project, Docket No. 08-035-42, Report and Order Granting Certificate of Public Need and Necessity (Sept. 4, 2008) (hereinafter "Populus-Terminal CPCN Order"); In the Matter of the Application of Rocky Mountain Power for a Certificate of Public Convenience and Necessity Authorizing Construction of the Mona-Oquirrh 500/345 kV Transmission Line, Docket No. 09-035-56, Report and Order (June 16, 2010) (hereinafter "Mona-Oquirrh CPCN Order"); In the Matter of a Certificate of Public Convenience and Necessity Authorizing Construction of the Sigurd – Red Butte No. 2 345 kV Transmission Line, Docket No. 12-035-97, Report and Order (March 15, 2013); Application of Rocky Mountain Power for Approval of a Significant Energy Resource Decision and Voluntary Request for Approval of Resource Decision, Docket No. 17-035-40, Order "EV 2020 Order").

OATT and long-standing FERC precedent explicitly require it to construct and expand its system to provide FERC-jurisdictional transmission and interconnection service.²

Second, Gateway South will improve grid reliability by providing better operational control of the backbone transmission system by interconnecting two areas of the PacifiCorp transmission system that are abundant in two different forms of renewable resources—wind-rich eastern Wyoming with the solar-rich area of southern Utah. Gateway South also provides critical voltage support to the Company's transmission network and enhances the Company's ability to comply with mandated reliability and performance standards.

Third, the Company's 2021 Integrated Resource Plan ("IRP") demonstrates the need for additional transmission and generation resources to serve load. Gateway South, together with the Gateway West Segment D.1 230-kV transmission line ("Gateway West Segment D.1") (collectively with Gateway South, the "Transmission Projects"), allow the interconnection of over 1,600 MW of new tax-credit-eligible wind resources in eastern Wyoming that were selected in the Company's 2020 All Source Request for Proposals ("2020AS RFP"). The time-limited federal tax incentives from these new renewable generation resources substantially offset the costs of the Transmission Projects.

The Transmission Projects, and the new generation resources they enable, serve the public interest by providing net benefits to customers in a wide range of price-policy scenarios.

² See PacifiCorp OATT, Sections 28.2 and 15.4 (reflecting verbatim FERC's pro forma tariff established in 1996 and requiring a transmission provider to construct facilities as necessary to reliably provide requested transmission service); *Standardization of Generator Interconnection Agreements and Procedures*, Order No. 2003, 104 FERC ¶ 61,103 at 767 (2003) (explaining that FERC's pro forma interconnection services "provide for the construction of Network Upgrades that would allow the Interconnection Customer to flow the output of its Generating Facility onto the Transmission Provider's Transmission System in a safe and reliable manner."); *Preventing Undue Discrimination and Preference in Transmission Service*, Order No. 890, 118 FERC ¶ 61,119 at 814 (2007) (explaining that despite certain policy reforms, transmission providers "will continue to be obligated to construct new facilities to satisfy a request for service if that request cannot be satisfied using existing capacity").

This includes present value revenue requirement differential ("PVRR(d)") customer benefits of \$128 million in the base case (assuming medium natural gas and medium carbon dioxide ("CO₂") prices). On a risk-adjusted basis, construction of the Transmission Projects is \$260 million lower cost when compared to a portfolio without the Transmission Projects.

The Company plans to construct and energize the Transmission Projects by the end of 2024, requiring construction to begin by June 2, 2022. The Company is on track to have all Utah siting permits by June 2022. Therefore, the Company requests that the Commission grant the requested CPCN for Gateway South no later than June 1, 2022.

I. NAME AND ADDRESS OF APPLICANT

1. PacifiCorp provides retail electric service under the name Rocky Mountain Power in the states of Utah, Wyoming, and Idaho, and under the name Pacific Power in the states of Oregon, Washington, and California. Rocky Mountain Power is a public utility in the state of Utah subject to the jurisdiction of the Commission as to its electric service to retail customers in Utah. Rocky Mountain Power's principal place of business in Utah is 1407 West North Temple, Salt Lake City, Utah 84116.

2. Formal correspondence and requests for additional information regarding this matter should be addressed to:

By email (preferred): datarequest@pacificorp.com

By regular mail:

Data Request Response Center PacifiCorp 825 NE Multnomah, Suite 2000 Portland, Oregon 97232 With copies to:

Jana Saba Utah Regulatory Affairs Manager Rocky Mountain Power Email: jana.saba@pacificorp.com

Richard Garlish John Hutchings Rocky Mountain Power 1407 West North Temple, Suite 320 Salt Lake City, Utah 84116 Email: john.hutchings@pacificorp.com richard.garlish@pacificorp.com

Katherine McDowell Adam Lowney McDowell Rackner Gibson PC 419 SW 11th Avenue, Suite 400 Portland, Oregon 97205 E-mail: <u>katherine@mrg-law.com</u> <u>adam@mrg-law.com</u>

Informal inquiries related to this Application should be directed to Jana Saba at (801) 220-2823.

II. SUPPORTING TESTIMONY

3. Rocky Mountain Power's Application for a CPCN for Gateway South is supported by pre-filed written direct testimony and exhibits of the following Company witnesses:

• Mr. Rick A. Vail, Vice President of Transmission, provides a detailed description of Gateway South, demonstrates that Gateway South is necessary to both meet the Company's obligations as a transmission provider and improve the reliability of its transmission system. Mr. Vail also describes how the Transmission Projects will increase both the interconnection capacity in eastern Wyoming and the transfer

capability out of eastern Wyoming and into central Utah. Mr. Vail explains that PacifiCorp followed the mandatory OATT study process to identify the construction of the Transmission Projects as a prerequisite to reliably providing service in response to nearly 2,500 MW of transmission and interconnection service requests, and then listed the Transmission Projects in multiple FERC-jurisdictional executed contracts accordingly. Mr. Vail also addresses the status of the permitting for Gateway South.

Mr. Rick T. Link, Senior Vice President of Resource Planning, Procurement and Optimization, provides the economic analysis demonstrating that Gateway South is beneficial to Utah customers and in the public interest. Mr. Link describes the customer benefits resulting from the timely construction of the Transmission Projects and explains the need for the Transmission Projects and associated generation resources as outlined in the Company's 2021 IRP. Mr. Link also explains the status of the Company's 2020AS RFP, soliciting cost-effective generation projects enabled by the Transmission Projects, and addresses questions the Commission raised in the 2019 IRP regarding Gateway South.

III. OVERVIEW OF THE TRANSMISSION PROJECTS

A. Description of Transmission Projects.

1. Gateway South

4. Gateway South is a 416-mile, high-voltage 500-kV transmission line that will connect southeastern Wyoming to northern Utah. Gateway South will begin at the Aeolus substation, which is located near Medicine Bow, Wyoming and was recently constructed as part of the Aeolus-to-Bridger/Anticline transmission project. From the Aeolus substation, the line extends west to Wamsutter, Wyoming, and then generally south to the Colorado border.

From there, the line crosses through the northwest corner of Colorado, enters Utah, eventually terminating at the Clover substation near Mona, Utah.

5. Gateway South also requires the Company to modify the existing 345-kV transmission infrastructure in the Mona/Clover area.

6. Because of the length of Gateway South, the Company will construct two series compensation substations along the line to reduce net transmission line impedance and improve the power transfer capability of the line. The addition of series compensation substations also improves power flow control, voltage regulation and increases the transient stability margin of the line.

Construction of Gateway South will also require modifications to the Aeolus,
 Anticline, Clover, and Mona substations to accommodate the new line.

8. The estimated cost of Gateway South is \$2.074 billion.

2. Gateway West Segment D.1

9. The Company is not requesting a CPCN for Gateway West Segment D.1, which is located entirely in Wyoming. However, the Company includes the following description of Gateway West Segment D.1 because, together with Gateway South, it is necessary to the interconnection of the majority of the over 1,600 MW of new wind resources in eastern Wyoming selected in the 2020AS RFP. Therefore, the Company's economic analysis described in Mr. Link's testimony, which was derived from the 2021 IRP, appropriately includes the costs and benefits of Gateway West Segment D.1.

10. Gateway West Segment D.1 includes construction of a new 59-mile, highvoltage 230-kV transmission line from the Shirley Basin substation in southeastern Wyoming to the Windstar substation near Glenrock, Wyoming. In addition, the Company will rebuild the

7

existing Dave Johnston – Amasa – Difficulty – Shirley Basin 230-kV transmission line, which runs approximately 57 miles from the Shirley Basin substation to the Dave Johnston substation near Glenrock, Wyoming.

11. Gateway West Segment D.1 requires construction of a new 230-kV Heward substation that will be sited adjacent to the Difficulty substation, which is owned by Tri-State Generation & Transmission. Gateway West Segment D.1 also requires additions to the Shirley Basin, Dave Johnston, Windstar, and Anticline substations.

12. The estimated cost of the Transmission Projects is \$2.4 billion.

IV. LEGAL STANDARD

13. Before constructing a transmission line located in Utah, Utah Code Ann. § 54-4-25 requires that a public utility obtain a CPCN. The statute identifies the "minimum amount and type of evidence" that must be provided,³ including evidence that: (1) the "present or future public convenience and necessity does or will require the construction" of the line;⁴ (2) the "applicant has received or is in the process of obtaining the required consent, franchise, or permit of the proper county, city, municipal, or other public authority";⁵ (3) and the line "will not conflict with or adversely affect the operations of any existing certificated fixed public utility which supplies the same product or service to the public and that it will not constitute an extension into the territory certificated to the existing fixed public utility."⁶ The Commission has repeatedly affirmed that the CPCN process "is not about the location or siting" of the transmission line.⁷

³ Populus-Terminal CPCN Order at 4.

⁴ Utah Code Ann. § 54-4-25(1).

⁵ Utah Code Ann. § 54-4-25(4)(a)(i).

⁶ Utah Code Ann. § 54-4-25(4)(b).

⁷ See, e.g., Populus-Terminal CPCN Order at 2.

14. After a decade of planning, the Company now proposes to move forward with construction of Gateway South and place it into service by the end of 2024. Gateway South is an important component of Energy Gateway, and Gateway South has long been recognized as a key transmission segment in the region's long-term transmission planning. By acting now on this time-limited opportunity to develop the Transmission Projects, the Company can provide substantial customer benefits.

15. PacifiCorp followed the OATT process to identify the construction of the Transmission Projects as a prerequisite to reliably providing service in response to nearly 2,500 MW of transmission and interconnection service requests, and the Transmission Projects were listed in multiple FERC-jurisdictional executed contracts accordingly. More specifically, PacifiCorp executed 13 contracts with third-party customers that require construction of one or both of the Transmission Projects, including a transmission service agreement that requires construction of Gateway South to reliably provide 500 MW of firm point-to-point ("PTP") transmission. The Transmission Projects are therefore lynchpins in PacifiCorp's ability to meet its obligation to grant generator interconnection service and transmission service under the OATT.

16. The Transmission Projects, and Gateway South in particular, will also enhance the Company's ability to comply with mandated North American Electric Reliability Corporation ("NERC") and Western Electricity Coordinating Council ("WECC") reliability and performance standards. Congestion on the current transmission system in eastern Wyoming limits the ability to deliver energy from eastern Wyoming to PacifiCorp load centers in Utah, Wyoming, Idaho, and the Pacific Northwest. The Transmission Projects will increase transfer capability by approximately 875 MW from the Windstar/Dave Johnston area south to Shirley Basin/Aeolus, which, in turn, will support approximately 1,700 MW of incremental transfer capability from eastern Wyoming to the central Utah energy hub.

17. Construction of the Transmission Projects will enable the Company to more efficiently utilize existing generation resources in Wyoming to serve loads in Utah, Wyoming, Idaho, and the Pacific Northwest. The Transmission Projects also better position the Company to interconnect and integrate future resources in southeastern Wyoming and more efficiently serve expected customer load. In addition to increasing the transmission capacity out of eastern Wyoming, the Transmission Projects will also provide critical voltage support to the Wyoming transmission network and enhance the overall reliability of the transmission system by adding incremental new transmission capacity between the Company's existing thermal and renewable facilities and future facilities and other sources of energy in northern Utah. Additional transmission paths will mitigate the impact of outages on the existing system.

18. The Company needs additional resources to serve load and the Transmission Projects enable new, cost-effective wind resources to fill this need. Specifically, the Transmission Projects allow the Company to interconnect up to approximately 2,030 MW of new resources, including over 1,600 MW of new tax-credit-eligible wind resources selected in the 2020AS RFP. As with the Aeolus-to-Bridger/Anticline line, for which the Commission granted resource approval in 2018,⁸ the tax credits from new renewable generation enabled by the Transmission Projects produce significant benefits that offset costs of the Transmission Projects.

19. The Company has requested CPCNs from the Wyoming Public Service Commission for the Transmission Projects in Docket No. 20000-588-EN-20 (Record No.

⁸ EV 2020 Order.

15604). A hearing in that filing is scheduled for February 22, 2022-March 2, 2022. A CPCN is not required from the Colorado Public Service Commission.

A. Gateway South is Necessary.

1. The Transmission Projects Fulfill the Company's Obligations under its OATT and Avoid Construction of Less Cost-Effective, Stop-Gap Options.

20. The Company is required to provide reliable transmission and interconnection service in accordance with the rates, terms, and conditions of PacifiCorp's FERC-jurisdictional OATT. Where a request for OATT service cannot be reliably provided on the existing system, the Company's OATT and long-standing FERC policy explicitly require it to construct and expand its system to provide FERC-jurisdictional transmission and interconnection service.⁹

21. The OATT's PTP transmission service provisions require a transmission provider to "use due diligence to *expand or modify its Transmission System* to provide the requested Firm Transmission Service" if the transmission provider cannot accommodate the request because of insufficient capability on its system.¹⁰ PacifiCorp's OATT explains that if the transmission system cannot provide firm PTP transmission service without degrading reliability to existing customers or interfering with PacifiCorp's ability to meet its prior

⁹ See PacifiCorp OATT, Sections 28.2 and 15.4 (reflecting verbatim FERC's pro forma tariff established in 1996 and requiring a transmission provider to construct facilities as necessary to reliably provide requested transmission service); *Standardization of Generator Interconnection Agreements and Procedures*, Order No. 2003, 104 FERC ¶ 61,103 at 767 (2003) (explaining that FERC's pro forma interconnection services "provide for the construction of Network Upgrades that would allow the Interconnection Customer to flow the output of its Generating Facility onto the Transmission Provider's Transmission System in a safe and reliable manner."); *Preventing Undue Discrimination and Preference in Transmission Service*, Order No. 890, 118 FERC ¶ 61,119 at 814 (2007) (explaining that despite certain policy reforms, transmission providers "will continue to be obligated to construct new facilities to satisfy a request for service if that request cannot be satisfied using existing capacity").

¹⁰ PacifiCorp OATT, Section 15.4 (emphasis added).

contractual obligations, then PacifiCorp is "obligated to expand or upgrade its Transmission System[.]"¹¹

22. For interconnection service, FERC requires PacifiCorp to "*construct[] Network Upgrades*" if necessary to allow the interconnecting generator to flow its output onto the transmission system in a safe and reliable manner.¹²

23. The obligation to construct transmission facilities in response to transmission or interconnection service requests applies to both newly identified facilities and planned system expansions or upgrades, like the Transmission Projects, when service requests depend on their construction.¹³ PacifiCorp's FERC-approved Attachment K to the OATT makes clear that once a planned transmission project is required to be in service for PacifiCorp to grant an OATT request for PTP transmission service or generator interconnection service, PacifiCorp is obligated to construct the project.¹⁴ Under those circumstances, the OATT requires PacifiCorp to identify the requisite upgrades as "Contingent Facilities" in the OATT studies posted to its Open Access Same-Time Information System ("OASIS") website and ultimately in the FERC-jurisdictional agreement on file with FERC. The Company has executed 13 transmission service and generator interconnection service contracts that list either one or both Transmission Projects as Contingent Facilities. This means that PacifiCorp *cannot provide* the

¹¹ PacifiCorp OATT, Section 13.5 (emphasis added).

¹² Order No. 2003 at P 767 (emphasis added).

¹³ California Indep. System Operator, 133 FERC ¶ 61,224 (2010) (clarifying that the OATT's obligation to construct attaches to planned facilities identified as necessary to grant interconnection requests, stating that "[t]he fact that CAISO has voluntarily chosen to evaluate a network upgrade in its transmission planning process should not affect the obligation to build these facilities.").

¹⁴ PacifiCorp OATT, Attachment K ("Transmission Provider shall use Point-to-Point Transmission Service usage forecasts and Demand Resources forecasts to determine system usage trends, and such forecasts do not obligate the Transmission Provider to construct facilities **<u>until</u>** formal requests for either Point-to-Point Transmission Service or Generator Interconnection Service requests are received pursuant to Parts II and IV of the Tariff.") (emphasis added).

contracted services to 13 contractual counterparties without constructing the Transmission Projects.

24. Among these contracts is an executed 500 MW PTP transmission service agreement that requires Gateway South to be in service. If the Company were not planning to construct Gateway South, the Company's analysis shows that in order to grant only this single PTP transmission service request—and ignoring the other thousands of megawatts of queued service requests—PacifiCorp would be obligated to construct, at a minimum, a 230-kV transmission line at a cost in excess of \$1 billion.

25. The Company has also executed 12 interconnection agreements that identify one or both Transmission Projects as Contingent Facilities. Interconnecting these generators without the Transmission Projects would require the Company to construct substantially similar transmission facilities at comparable costs but with fewer financial, interconnection, transmission, and operational efficiencies.

26. The Transmission Projects are cost-effective transmission system upgrades required to allow the Company to meet its OATT obligation to provide transmission and interconnection service. It is unrealistic to assume that, absent the Transmission Projects, the Company would not be obligated to construct *any* transmission system upgrades out of eastern Wyoming to accommodate FERC-jurisdictional requests for OATT interconnection service and transmission service.

2. The Transmission Projects enable the Company to efficiently satisfy its obligation to comply with mandatory reliability standards.

27. The Commission granted a CPCN for Energy Gateway's Populus-Terminal transmission line, in part, because "future utility service will be more reliable and efficient"

13

with the transmission line.¹⁵ Similarly, when granting a CPCN for Energy Gateway's Mona-Oquirrh transmission line, the Commission relied on evidence that the line would "strengthen [PacifiCorp's] transmission grid in order to comply with important regional and national reliability standard and directives."¹⁶ Like Populus-Terminal, Mona-Oquirrh and Sigurd-Red Butte, the Transmission Projects are a critical component of the Company's short- and longterm plan to meet its federal reliability mandates.

28. NERC's TPL-001-4 standard requires the Company to have a forward-looking transmission plan to reliably serve current and anticipated customer demands under all expected operating conditions, including normal system operations (all system elements in service) and during system contingencies (where multiple elements of the transmission system are out of service), both planned or otherwise. To meet this standard, the Company performs annual reliability assessments to determine whether its transmission system complies with minimum mandatory system performance standards. The Transmission Projects, as part of Energy Gateway, have been included in the Company's annual TPL-001-4 assessment as part of its short- and long-term plans to dependably meet NERC and WECC reliability requirements for eight years. The Transmission Projects' new transmission segments are particularly effective in increasing system reliability under the various multiple contingency categories of the TPL-001-4 standard.

29. The Company could maintain long-term compliance with the TPL-001-4 standard without any new transmission facilities in eastern Wyoming only if the transmission system experienced *no* changes in loads or resources—which is an entirely unrealistic assumption.

¹⁵ Populus-Terminal CPCN Order at 3.

¹⁶ Mona-Oquirrh CPCN Order at 15.

3. The Transmission Projects Provide Substantial Customer Benefits.

30. When granting a CPCN for Energy Gateway's Mona-Oquirrh transmission line, the Commission pointed to the Company's 2008 IRP, which identified Energy Gateway generally "as the blueprint to most efficiently integrate transmission lines and collection points with resources and load centers."¹⁷ The Commission also focused on the fact the line and "more broadly Energy Gateway, will increase the Company's system-wide access to new and existing resources."¹⁸ Here, like Mona-Oquirrh, the Transmission Projects are a critical component of Energy Gateway and the Company's economic analysis from the 2021 IRP, presented here in Mr. Link's testimony, demonstrates that construction of the Transmission Projects will provide substantial customer benefits.

31. The Company's 2021 IRP shows that PacifiCorp has a capacity deficit in all years of the 20-year planning horizon. In 2021, the capacity need is over 1,000 MW and increases over time to over 6,600 MW by 2040. In 2025, the first full year that the Transmission Projects will be online, the capacity need is 1,672 MW.

32. To identify the most cost-effective approach to meet the identified capacity need, PacifiCorp utilized its new, more advanced Plexos resource modeling and optimization tool to construct and select the preferred portfolio in the 2021 IRP. When optimizing resource portfolios, the Plexos model is able to view the costs and benefits of certain transmission upgrades and can select specific transmission upgrades that enable new resource additions. The model accounts for costs of potential transmission resources and the value generated by the transmission resources by enabling low-cost generation options and better optimizing how resources are used to serve load to lower system costs.

¹⁷ Mona-Oquirrh CPCN Order at 14.

¹⁸ Mona-Oquirrh CPCN Order at 15.

33. The Plexos model selected the Transmission Projects, and the low-cost generation resources enabled by the Transmission Projects, as critical components of the least-cost, least-risk portfolio of resources to serve customers through the 20-year IRP planning horizon.

34. To individually analyze the Transmission Projects, the Company used Plexos to model its system with and without the Transmission Projects and associated wind resources across multiple natural gas and greenhouse gas price scenarios. This with and without modeling was directly responsive to the Commission's concerns in the 2019 IRP¹⁹ and 2020AS RFP proceeding²⁰ and consistent with the modeling the Commission found "thorough and extensive" when approving the Energy Vision 2020 resources.²¹ When individually analyzed, the Company's modeling demonstrates that through 2040, the resource portfolio that includes the Transmission Projects is \$128 million lower cost than the comparable portfolio without the Transmission Projects, when examined using a medium natural gas, medium carbon dioxide price-policy scenario. On a risk-adjusted basis, construction of the Transmission Projects. The risk-adjusted results indicate that the Transmission Projects add significant risk mitigation benefits associated with volatility in market prices, loads, hydro generation, and unplanned outages.

¹⁹ *PacifiCorp's 2019 Integrated Resource Plan*, Docket No. 19-035-02, Order at 22 (May 13, 2020) (hereinafter "2019 IRP Order") (Commission concerned that PacifiCorp "did not model the Preferred Portfolio without the yet-to-be-built Gateway South as a presumed component," which was "inadequate" because the 2019 IRP Action Plan called for "nearly immediate construction of the line without identifying and justifying selection of the specific resources that will rely on it and, in particular, their geographic location.").

²⁰ Application of Rocky Mountain Power for Approval of Solicitation Process for 2020 All Source Request for Proposals, Docket No. 20-035-05, Order Approving 2020 All Source RFP at 14-15 (July 17, 2020) (Company committed to "perform, at minimum, a sensitivity that removes Gateway South and all bids that require Gateway South" as part of RFP evaluation process, which the Commission found was reasonable and adequately addressed concerns over the impact of the Transmission Projects on RFP bids).
²¹ EV 2020 Order at 22.

35. Further, the risk-adjusted results demonstrate that there is a tremendous opportunity cost of not building the Transmission Projects in the likely event that regulatory policies at some point in the future will impose costs on greenhouse gas emissions. Among all scenarios that assume some costs for greenhouse gas emissions, the portfolios with the Transmission Projects are significantly lower cost than portfolios without the Transmission Projects—with customer savings ranging from \$128 million to over \$2.8 billion.

36. Moreover, without the Transmission Projects, PacifiCorp customers will be exposed to increasing market risk, in the form of both price and volume volatility. Indeed, without the Transmission Projects, and the associated generation enabled by the projects, market purchases increase by nearly 20 percent on an annual basis. This creates higher risk as the Company is forced to rely on market purchases at a time when there are increasing resource adequacy concerns throughout the Western Interconnection. This increased market and reliability risk is not reflected in the PVRR(d) results and provides additional evidence that the potential customer savings are conservative.

37. To further confirm the robust customer benefits resulting from the construction of the Transmission Projects, the Company also modeled potential alternative transmission investments responsive to the Commission's concerns raised in the 2019 IRP and 2020AS RFP proceedings. In particular, the Commission was concerned that PacifiCorp did not model a potential alternative transmission expansion case evaluated by the Northern Tier Transmission Group ("NTTG") in its 2018-2019 Regional Transmission Plan.²² As explained by Mr. Link, the Company explicitly modeled the NTTG case study for this filing and the results favor construction of the Transmission Projects by a significant margin.

²² 2019 IRP Order at 22; see also Order Approving 2020 All Source RFP at 14-15.

B. The Company Has or Will Obtain the Required Permits.

38. The Company has obtained many of the required permits and will obtain all permits ahead of construction. There are a number of construction related permits that will be the responsibility of the construction contractor to obtain prior to construction. A list of the required permits and status can be found in Exhibit 1 attached to this Application.

C. Construction of Gateway South Will Not Conflict with Any Other Utility's Service.

39. The construction of Gateway South will not conflict with or otherwise adversely impact the provision of electric service by any other utility that is certified to provide electric utility service in Utah. The construction of Gateway South will also not constitute an extension of service into a territory for which another utility has a CPCN to provide electric utility service.

D. The Company has the Financial Ability to Construct Gateway South.

40. The Company intends to finance Gateway South through its normal internal and external sources of capital, including net cash flow from operating activities, public and private debt offerings, the issuance of commercial paper, the use of unsecured revolving credit facilities, capital contributions, and other sources. The financial impact will not impair the Company's ability to continue to provide safe and reliable electricity service at reasonable rates.

V. CONCLUSION

Rocky Mountain Power respectfully requests that the Commission issue an order on or before June 1, 2022, granting a CPCN to construct Gateway South. Gateway South is prudent and in the public interest and is an integral component of the Company's long-term plans to provide stable, reliable electric service at just and reasonable rates.

Respectfully submitted this 7th day of October, 2021.

ar

Richard Garlish John Hutchings 1407 West North Temple, Suite 320 Salt Lake City, Utah 84116 Telephone: (801) 220-2533 Facsimile: (801) 220-3299 Email: <u>richard.garlish@pacificorp.com</u> Email: john.hutchings@pacificorp.com

Attorneys for Rocky Mountain Power

Exhibit 1

Gateway South - Utah Federal, State, and Local Permits and Approvals

Table 1 is a list of the major federal, state, and local permits and approvals that could be required for construction, operation, and maintenance of the Gateway South Project (the Utah portion only).

TABLE 1 - S ENVIRONMEN	LUMMARY OF POTENTIA NTAL REVIEW REQUIREN	L MAJOK FEDERAL, ST MENTS FOR THE GATEV	NIE, AND LOCAL PERMIT VAY SOUTH PROJECT'S C	S OK LICENSES KEQUIKED ONSTRUCTION AND OPER) AND OTHER ATION IN UTAH
Action Requiring Permit, Approval, or Review	Agency	Permit, License, Compliance, or Review	Relevant Laws and Regulations	Responsibility	Status
		FE	DERAL		
		Locating Facilities on La	nd under Federal Manageme	nt	
Preconstruction surveys; construction, operation, maintenance	Bureau of Land Management (BLM)	Right-of-way grant and temporary-use permit (an approved Plan of Development [POD] would be a condition of approval to granting the right-of-way	Federal Land Policy and Management Act (FLPMA) of 1976 (Public Law [P.L.] 94-579+); 43 United States Code (U.S.C.) 1761 et seq.; 43 CFR 2800	PacifiCorp	Received on 1/23/17
Preconstruction surveys; construction, operation, maintenance	U.S. Forest Service (USFS)	Special-use authorization	FLPMA, as amended	PacifiCorp	Received on 1/7/2020
		Biologi	cal Resources		
Protection of Federally Endangered, Threatened and Listed species via Biological Opinion	U.S. Fish and Wildlife Service (FWS)	Endangered Species Act compliance by consultation with FWS (may require permit for incidental take of listed species)	Endangered Species Act, as amended (16 U.S.C. 1531 et seq.)	PacifiCorp/Construction Contractor	Consultation completed as part of EIS. Construction Contractor to ensure compliance during construction
Protection of migratory birds	FWS	Compliance	Migratory Bird Treaty Act (16 U.S.C. 703 et seq.); 50 CFR 1; individual agency guidance; Memoranda of Understanding between federal land-management agencies and FWS	Construction Contractor	Maintain compliance during construction

TABLE 1 - SI ENVIRONMEN	JMMARY OF POTENTIAI TAL REVIEW REQUIREN	L MAJOR FEDERAL, ST AENTS FOR THE GATEV	ATE, AND LOCAL PERMITS WAY SOUTH PROJECT'S CO	S OR LICENSES REQUIRED ONSTRUCTION AND OPER) AND OTHER ATION IN UTAH
Action Requiring Permit, Approval, or Review	Agency	Permit, License, Compliance, or Review	Relevant Laws and Regulations	Responsibility	Status
Protection of bald and golden eagles	FWS	Compliance (may require permit for take of eagles)	Bald and Golden Eagle Protection Act of 1972 (16 U.S.C. 668), including the Final Eagle Permit Rule, or implementing regulations of September 11, 2009 (50 CFR 13; 50 CFR 22)	PacifiCorp	Will obtain permit if necessary
Protection of special status species	BLM and USFS	Compliance	BLM Policy Manual 6840; agency guidance	Construction Contractor	Maintain compliance during construction
Protection of fish, wildlife, and aquatic resources	BLM and USFS	Compliance	BLM Policy Manuals 6500 and 6720	Construction Contractor	Maintain compliance during construction
		Ground Disturbance ar	nd Water Quality Degradation		
Construction sites with greater than 1 acre of land disturbed	U.S. Environmental Protection Agency (EPA) (Utah Department of Environmental Quality [UDEQ])	Section 402 National Pollutant Discharge Elimination System General Permit for Storm Water Discharges from Construction Activities	Clean Water Act of 1972 (CWA) (33 U.S.C. 1342)	Construction Contractor	Prior to construction

Rocky Mountain Power Exhibit 1 Page 2 of 8 Docket No. 21-035-54

In progress

PacifiCorp

Rivers and Harbors Act of 1899 (33 U.S.C. 403)

In progress

PacifiCorp

40 U.S.C. 961

Floodplain use permits

USACE

floodplain, streams, and

rivers

Crossing 100-year

In progress

PacifiCorp

CWA (33 U.S.C. 1344)

(individual or coverage under nationwide permit)

Section 10 permit

USACE

and construction work in

navigable waters of the United States

Placement of structures

USACE 404 Permit

USACE

Discharge of dredge or fill material into waters of the

United States, including

wetlands

Action Requiring Permit, Approval, or Review	Agency	Permit, License, Compliance, or Review	Relevant Laws and Regulations	Responsibility	Status
Potential pollutant discharge during construction, operation, and maintenance	EPA	Spill Prevention Control and Countermeasure Plan for substations	Oil Pollution Act of 1990 (40 CFR 112)	Construction Contractor	Prior to construction
		Cultur	al Resources		
Disturbance of historic properties	Federal lead agency, State Historic Preservation Office (SHPO), Advisory Council on Historic Preservation	Section 106 consultation	National Historic Preservation Act of 1966 (54 U.S.C. 306108; 36 CFR 800)	PacifiCorp/Construction Contractor	Consultation completed as part of EIS. Construction Contractor to ensure compliance during construction
Excavation of archaeological resources	Federal land-management agency	Permits to excavate	Archaeological Resources Protection Act (ARPA) of 1979 (16 U.S.C. 470aa to 470ee)	PacifiCorp	Would acquire, if needed
Potential conflicts with freedom to practice traditional American Indian religions	Federal lead agency, federal land-management agency	Consultation with affected American Indians	American Indian Religious Freedom Act of 1978 (42 U.S.C. 1996)	PacifiCorp	Complete
Disturbance of graves, associated funerary objects, sacred objects, and items of cultural patrimony	Federal land-management agency	Consultation with affected Native American groups regarding treatment of remains and objects	Native American Graves Protection and Repatriation Act of 1990 (25 U.S.C. 3001-3002)	PacifiCorp	Would acquire, if needed
Investigation of cultural resources	Affected land- management agency	Permit for study of historical and archaeological resources	FLPMA of 1976	PacifiCorp	Complete
		Paleontolo	ogical Resources		
Ground disturbance on federal land or federal aid project	BLM and USFS	Compliance with BLM and USFS mitigation and planning standards for paleontological resources of public lands	FLPMA (43 U.S.C. 1701 et seq.); 36 CFR 291; BLM Handbook H-8270; BLM Handbook 8270	PacifiCorp	Complete

Rocky Mountain Power Exhibit 1 Page 3 of 8 Docket No. 21-035-54

TABLE 1 - S ENVIRONMEN	UMMARY OF POTENTIAI VTAL REVIEW REQUIREN	L MAJOR FEDERAL, STA AENTS FOR THE GATEV	VTE, AND LOCAL PERMIT VAY SOUTH PROJECT'S C	S OR LICENSES REQUIRED ONSTRUCTION AND OPER) AND OTHER ATION IN UTAH
Action Requiring Permit, Approval, or Review	Agency	Permit, License, Compliance, or Review	Relevant Laws and Regulations	Responsibility	Status
Collection of paleontological resources from federal land	BLM and USFS	Permit to collect paleontological resources from federal land	Omnibus Public Lands Management Act of 2009 – Paleontological Resources Preservation; (P.L. 111-11, Title VI, Subtitle D, Sections 6301 et seq., 123 Stat. 1172); 16 U.S.C. 470aaa	PacifiCorp	Complete
		Use o	of Pesticides		
Use of pesticides or herbicides on federal lands	Federal land-management agencies	Incorporate into right-of- way grant and temporary-use permit (BLM) and special-use authorization (USFS)	Carlson-Foley Act (43 U.S.C. 1241); Federal Noxious Weed Act of 1974 (P.L. 93-629) (76 U.S.C. 2801 et seq.), BLM Manual 9015	PacifiCorp	Complete
		Ai	r Traffic		
Location of towers and spans in relation to airport facilities and airspace	Federal Aviation Administration (FAA)	File notice of proposed construction or alteration; FAA to determine if structure is no hazard	FAA Act of 1958 (P.L. 85- 726); 14 CFR 77	Construction Contractor	Prior to construction
		Tran	isportation		
Use of National Forest System Roads	USFS	Road use permit	Sections 4 and 6, National Forest Roads and Trail Act of 1964; 16 U.S.C. 535 and 537	PacifiCorp	In progress
		T	RIBAL		
		Locating Facilities on I	and of Indian Reservations		

Rocky Mountain Power Exhibit 1 Page 4 of 8 Docket No. 21-035-54

ENVIRONMEN	TAL REVIEW REQUIREN	AENTS FOR THE GATEV	VAY SOUTH PROJECT'S CO	ONSTRUCTION AND OPER	ATION IN UTAH
Action Requiring Permit, Approval, or Review	Agency	Permit, License, Compliance, or Review	Relevant Laws and Regulations	Responsibility	Status
Crossing roads or irrigation facilities on Indian reservation land	BIA	Encroachment permit	25 CFR 169	PacifiCorp	In progress
Grant of easement across Indian reservation	BIA in coordination with Ute Indian Tribe of the Uintah and Ouray Indian Reservation	Grant of Easement	25 CFR 169	PacifiCorp	In progress
		Condu	ict Business		
Conducting business on the Uintah and Ouray Indian Reservation	Ute Indian Tribe of the Uintah and Ouray Indian Reservation	Business license	Requirement of the Ute Tribal Employment Rights Office and Ute Business Council	Construction Contractor	Prior to construction
		STATI	E OF UTAH		
		Pro	oject Need		
Project construction	PSC	Certificate of Public Convenience and Necessity; approve construction contracts	Utah Code Title 54-4-25 and UAC Title R746-401	PacifiCorp	In progress
		St	ate Lands		
Encroachment on, through, or over state land	Utah Division of Forestry, Fire and State Lands (FFSL), Utah School and Institutional Trust Lands Administration (SITLA), and Utah Division of Wildlife Resources (UDWR)	Application approval; easement on state land (bond may be required)	Utah Code Title 65A-7-8 and UAC Title R652 for FFSL; Utah Code Title 53C and UAC Title R850 for SITLA; and Utah Code Title 23 and UAC Title R657 for UDWR	PacifiCorp	In progress
			Water		
Construction sites with greater than 1 acre of land disturbed	Utah Division of Water Quality	Stormwater permit	UAC Title R317	Construction Contractor	Prior to construction

Rocky Mountain Power Exhibit 1 Page 5 of 8 Docket No. 21-035-54

TABLE 1 - SI ENVIRONMEN	JMMARY OF POTENTIAI TAL REVIEW REQUIREM	, MAJOR FEDERAL, STA IENTS FOR THE GATEW	NTE, AND LOCAL PERMITS VAY SOUTH PROJECT'S CO	S OR LICENSES REQUIREI DNSTRUCTION AND OPER	AND OTHER ATION IN UTAH
Action Requiring Permit, Approval, or Review	Agency	Permit, License, Compliance, or Review	Relevant Laws and Regulations	Responsibility	Status
Potential discharge into waters of the state (including wetlands and washes)	UDEQ	Section 401 permit	UAC Title R-317	Construction Contractor	Prior to construction
			Air		
Construction and operation	Air Quality Board	Notice of Construction	Utah Code Title 19-2-108 and UAC Title R317	Construction Contractor	Prior to construction
		Cultur	al Resources		
Survey or excavation of archaeological resources	Utah Governor's Public Lands Policy	Permit to survey	Utah Code Title 9-8-305; UAC Title R694-1	PacifiCorp	Complete
on lands owned or controlled by the state	Coordination Office	or excavate		Construction Contractor	Will obtain, if required
Disturbance of historic	SHPO, Utah	SHPO will comment on	Utah Code Title 9-8-404 and	Construction Contractor	Will obtain, if required
properties	Division of State History	state-funded undertakings	UAC Title R455		
Discovery of graves, associated funerary	Antiquities Section, Utah Division of	Consultation with state agency regarding	Utah Code Title 76-9- 704 and 9-9-403 to 9-9-	Construction Contractor	Will obtain, if required
objects, sacred objects, and items of cultural	State History	treatment or numan remains and funerary	405; UAC Title R203-1 and R455-4		
patrimony on nonfederal-, nonstate-administered land		objects			
Impact on historical sites	Division of State	Notification of planning	Utah Code Title 9-8-404	Construction Contractor	Will obtain, if required
	History	stage and before construction			
		Paleontol	ogical Resources		
Excavation and	Utah Geological Survey, Utah Museum of	Permit to excavate and collect	Utah Code Title 79-3-501 and 79-3-502. Hab Code	Construction Contractor	Will obtain, if required
collection of valeontological resources	Natural History, SITLA	paleontological	Title 63-73-11 through 63-		
from state lands		resources from state land	73-19		
			Vildlife		
Modification of habitat	UDWR	Easement for use of state wildlife resource lands	Utah Code Title 23 and UAC Title R657	PacifiCorp	In progress

Rocky Mountain Power Exhibit 1 Page 6 of 8 Docket No. 21-035-54

TABLE 1 - SI ENVIRONMEN	UMMARY OF POTENTIAI TAL REVIEW REQUIREN	L MAJOR FEDERAL, STA AENTS FOR THE GATEV	NTE, AND LOCAL PERMITS VAY SOUTH PROJECT'S CO	S OR LICENSES REQUIRED ONSTRUCTION AND OPER	AND OTHER ATION IN UTAH
Action Requiring Permit, Approval, or Review	Agency	Permit, License, Compliance, or Review	Relevant Laws and Regulations	Responsibility	Status
		Noxi	ious Weeds		
Construction and operation activities	Utah Department of Agriculture and Food	Compliance	Utah Administrative Code (UAC) Title R68-9	Construction Contractor	Maintain compliance during construction
			Local		
	Carbon County	Conditional-use permit	The Development Code of Carbon County, Utah – Sections 4.2.10C, 4.2.11C, 4.2.15C, 4.2.13C, 4.2.1C, 4.2.15C, 4.2.17C, 4.2.1C,	PacifiCorp	Permit issued 10/23/2020
of transmission lines	Juab County	Conditional-use permit	Juab County Land Use Code 2018	PacifiCorp	Permit issued 10/7/2020
	Sanpete County	Conditional Use Permit	Sanpete County Land Use Ordinance 2020	PacifiCorp	Permit issued 10/14/2020
	Uintah County	Conditional Use Permit	Uintah County Code of Ordinances 2011 – Chapter 17.28.030, 17.0	PacifiCorp	Permit issued 10/14/2020
	Utah County	Conditional Use Permit	Utah County Land Use Ordinance 2010 – Sections 5-5, 5-6, 5-9	PacifiCorp	Permit issued 11/6/2020
	Duchesne County	Permitted Use	Duchesne County Zoning Ordinance Title 8	PacifiCorp	Not required
	Wasatch County	Conditional Use Permit	Wasatch County Land Use and Development Code 2012 – Section 16.05.03, 16.11.02	PacifiCorp	In progress
Road Use, Building Permits, Driveway Permits, etc.	Carbon County	Other permits as required	The Development Code of Carbon County, Utah	Construction Contractor	Will obtain, as required prior to construction

Rocky Mountain Power Exhibit 1 Page 7 of 8 Docket No. 21-035-54

ER	TAH	
D OTH	I NI NC	
ED ANI	RATIC	
<u>equiri</u>	ND OPE	
SES RI	ION AN	
LICEN	RUCT	
TS OR	CONST	
PERMI	ECT'S	
OCAL]	I PROJ	
AND L	SOUTH	
TATE,	EWAY	
RAL, S	E GATI	
FEDE	OR TH	
MAJOR	NTS F	
TIAL I	IREME	
POTEN	REQU	
I JO X	VIEW	
MMAF	FAL RE	
E 1 - SU	NMEN	
TABLI	VIRO	
	E	

Action Requiring Permit,		Permit, License,	Relevant Laws and	Responsibility	Status
Approval, or Keview	Agency Juab County	Compliance, or Keview Other permits as required	Kegulations Juab County Land Use	Construction Contractor	Will obtain, as required
	,	-	Code 2018		prior to construction
	Sanpete County	Other permits as required	Sanpete County Land Use Ordinance 2020	Construction Contractor	Will obtain, as required prior to construction
	Uintah County	Other permits as required	Uintah County Code of Ordinances 2011	Construction Contractor	Will obtain, as required prior to construction
	Utah County	Other permits as required	Utah County Land Use Ordinance 2010	Construction Contractor	Will obtain, as required prior to construction
	Duchesne County	Other permits as required	Duchesne County Zoning	Construction Contractor	Will obtain, as required prior to construction
	Wasatch County	Other permits as required	Wasatch County Land Use and Development Code	Construction Contractor	Will obtain, as required prior to construction

Rocky Mountain Power Exhibit 1 Page 8 of 8 Docket No. 21-035-54

REDACTED

Rocky Mountain Power Docket No. 21-035-54 Witness: Richard A. Vail

BEFORE THE PUBLIC SERVICE COMMISSION OF THE STATE OF UTAH

ROCKY MOUNTAIN POWER

REDACTED Direct Testimony of Richard A. Vail

October 2021

1 Q. Please state your name, business address, and present position with PacifiCorp.

A. My name is Rick A. Vail. My business address is 825 NE Multnomah, Suite 1600,
Portland, Oregon 97232. My present position is Vice President of Transmission. I am
responsible for transmission system planning, customer generator interconnection
requests and transmission service requests, regional transmission initiatives, asset
management, capital budgeting for transmission, and administration of the Company's
Open Access Transmission Tariff ("OATT"). I am testifying on behalf of PacifiCorp
d/b/a Rocky Mountain Power (the "Company").

9 Q. Please describe your education and professional experience.

- A. I have a Bachelor of Science Degree with Honors in Electrical Engineering with a focus
 in electric power systems from Portland State University. I have been employed at the
 Company since 2001, and have had a range of management responsibility within the
 asset management group, including capital planning, maintenance policy, maintenance
 planning, and investment planning. I served as director of asset management from 2007
 to 2012. I became Vice President of Transmission in December 2012.
- 16

PURPOSE AND SUMMARY OF TESTIMONY

- 17 **Q.** What is the purpose of your testimony?
- 18 A. My testimony supports the Company's application for a certificate of public
 19 convenience and necessity ("CPCN") for the construction of Energy Gateway South
 20 (Segment F) ("Gateway South"), which consists of the following facilities:
- A new 416-mile, high-voltage 500-kilovolt ("kV") transmission line from the
 Aeolus substation, near Medicine Bow, Wyoming, to the Clover substation near
 Mona, Utah. Approximately 183 miles of Gateway South is located in Utah.

24 Rebuilding certain 345-kV transmission facilities in and around the Mona and ٠ 25 Clover substations. 26 Construction of a four-mile, high voltage 230-kV transmission line from the 27 Aeolus substation to the Freezeout Substation near Medicine Bow, Wyoming. 28 Two new series compensation stations. Expansion of the Aeolus, Anticline, and Clover substations along with 29 modifications to the Mona substation. 30 Additional shunt capacitors at Bonanza (Utah), Riverton and Mustang 31 32 (Wyoming) substations. Additions and modifications to various remedial action schemes, voltage 33 34 controllers and control schemes necessary to ensure protection and control of 35 the grid after integration of Gateway South. 36 My testimony also explains the relationship between Gateway South and 37 Gateway West – Windstar-Aeolus (Segment D.1), a 59-mile, 230-kV transmission line 38 from the Shirley Basin substation in southeastern Wyoming to the Windstar substation 39 near Glenrock, Wyoming and re-construction of an existing, 57-mile, 230-kV 40 transmission line from the Shirley Basin substation to the Dave Johnston substation 41 near Glenrock, Wyoming ("Gateway West Segment D.1"), (collectively, the 42 "Transmission Projects"). Both Transmission Projects are necessary to interconnect 43 the majority of the new low-cost wind resources in eastern Wyoming selected in the 2020 All Source Request for Proposals ("2020AS RFP"). Therefore, the customer 44 45 benefits of Gateway South arising from the ability to interconnect additional wind 46 resources must also account for the costs and benefits of Gateway West Segment D.1,

Page 3 – Direct Testimony of Rick A. Vail

as reflected in the economic analysis in the direct testimony of Company witness
Mr. Rick T. Link. To the extent my testimony is addressing the interconnection of
additional resources, it will generally refer to the Transmission Projects together.

I also provide an overview of the status of the permits that are required for
construction of Gateway South.

52 **Q.** Please summarize your testimony.

Gateway South is an important component of the Company's Energy Gateway 53 A. 54 Transmission Expansion Project ("Energy Gateway") and has long been recognized as 55 a key transmission segment in the region's long-term transmission planning. By 56 constructing Gateway South before the end of 2024, the Company can provide 57 substantial customer benefits. Gateway South supports the Company's short- and long-58 term energy demands and will strengthen the overall reliability of the existing 59 transmission system. The Transmission Projects (i.e., Gateway South together with Gateway West Segment D.1) will enable interconnection of new generating facilities 60 61 to meet projected resource needs. These resources can qualify for federal renewable tax 62 credits, making them lower cost than other resource alternatives.

PacifiCorp used the OATT study process to identify the construction of the Gateway South as a prerequisite to reliably providing service in response to nearly 2,500 megawatts ("MW") of transmission and interconnection service requests, and Gateway South was listed in multiple FERC-jurisdictional executed contracts accordingly. Thus, to satisfy its obligations under its Federal Energy Regulatory Commission ("FERC") Open Access Transmission Tariff ("OATT"), the Company

Page 4 – Direct Testimony of Rick A. Vail

must develop the Transmission Projects and bring them into service byDecember 31, 2024.

71 Congestion on the current transmission system in eastern Wyoming limits the 72 ability to deliver energy from eastern Wyoming to PacifiCorp load centers in 73 Wyoming, Idaho, Utah, and the Pacific Northwest. Gateway South will help relieve 74 this congestion and increase the transmission capacity from southeast Wyoming to 75 central Utah by 1,700 MW. Gateway South, together with the Gateway West Segment 76 D.1 project transmission system reinforcements, will allow the Company to 77 interconnect up to approximately 2,030 MW of renewable resources and create 78 substantial benefits for Utah customers and customers throughout the Company's 79 service area. Gateway South will also enhance the Company's ability to comply with 80 mandated North American Electric Reliability Corporation ("NERC") and Western 81 Electricity Coordinating Council ("WECC") reliability and performance standards.

Construction of Gateway South will enable the Company to more efficiently use existing generation resources in Wyoming to serve its customers in Utah, Wyoming, Idaho, and the Pacific Northwest. Gateway South will also better position the Company to interconnect and integrate future resources in southeastern Wyoming and more efficiently serve expected customer load.

In addition to increasing the transmission capacity out of southeastern Wyoming and into central Utah, Gateway South will also provide critical voltage support to the Company's transmission network and enhance the overall reliability of the transmission system by adding incremental new transmission capacity between the Company's existing thermal and renewable facilities and future facilities and other

Page 5 – Direct Testimony of Rick A. Vail

92 sources of energy in Utah. Additional transmission paths will mitigate the impact of93 outages on the existing system.

94 Q. Please describe the location of the Transmission Projects within the Energy

95 Gateway Project.

98

- 96 A. Figure 1 shows the general location of Gateway South and Gateway West Segment D.1
- 97 within the Energy Gateway Project:

Figure 1



Energy Gateway

99

DESCRIPTION OF GATEWAY SOUTH

100 Q. Please briefly describe PacifiCorp's transmission system.

101 PacifiCorp owns and operates approximately 16,900 miles of transmission lines A. 102 ranging from 46 kV to 500 kV across multiple western states. PacifiCorp has nearly 103 1.9 million customers with approximately 960,000 customers located in Utah. Utah is 104 located (along with Idaho and Wyoming) in PacifiCorp's eastern balancing authority 105 area ("BAA"), PacifiCorp East ("PACE"), which has over 12,000 circuit-miles of 106 transmission lines and a record peak demand of 9,142 MW. A new record peak was 107 reached in PacifiCorp's overall system on August 17, 2020, at 12,709 MW. The PACE peak at that time was 9,131 MW even with COVID-19 still impacting customer 108 109 demand.

110 Q. Is PacifiCorp's transmission system interconnected with any third-party systems?

111 A. Yes. PACE alone is interconnected with 17 other systems, including Arizona Public 112 Service, Bonneville Power Administration ("BPA"), NV Energy, Los Angeles 113 Department of Water & Power, NorthWestern Energy, WALC-Phoenix, Idaho Power, 114 WACM-Loveland, Western Area Power Administration, Black Hills Power, Utah 115 Associated Municipal Power Systems, Utah Municipal Power Agency, Deseret Power 116 Electric Cooperative, Basin Electric Power Cooperative, Intermountain Power Agency, Tri-State Generation & Transmission Association, and Public Service Company of 117 118 New Mexico.

119 Q. Please describe the Gateway South transmission project.

A. Gateway South is an extra-high voltage, single-circuit 500-kV alternating current
transmission line that extends approximately 416 miles from southeastern Wyoming to
122

northern Utah. Gateway South is also referred to as Segment F of Energy Gateway.

- 123 Q. Where does Gateway South begin and end?
- A. Gateway South will begin at the Aeolus substation, which is located near Medicine Bow, Wyoming, and was recently constructed as part of the Aeolus-to-Bridger/Anticline segment D.2 of the Gateway West Transmission Line Project. From the Aeolus substation, the line extends west to Wamsutter, Wyoming, and then generally south to the Colorado border. From there, the line crosses through the northwest corner of Colorado, and enters Utah, eventually terminating at the Clover substation near Mona, Utah.
- 131 Q. Please describe Gateway South's proposed route.
- A. After leaving the Aeolus substation, for approximately 91 miles the line runs roughly
 parallel to the nearly completed Aeolus-Bridger/Anticline 500-kV transmission line,
 which runs southwest and then west. Approximately 12 miles west of the existing
 Latham substation, the line turns south towards the Colorado state line for the next
 52 miles.
- 137After crossing into Colorado, the line runs for five miles before entering the138proposed Little Snake series compensation substation. After exiting the Little Snake139substation, the transmission line runs south and then west for the next 85 miles before140entering Utah, which occurs roughly five miles southwest of Dinosaur, Colorado.
- 141The transmission line then extends another 21 miles southwest to the proposed142Coyote series compensation substation. After the Coyote substation, the line runs west143for 168 miles across Uintah and Duchesne Counties in Utah before entering Spanish144Fork Canyon.

Once in Spanish Fork Canyon, the line generally follows U.S. Highway 6 from Solider Summit to near the intersection with U.S. Highway 89. At that point, the line turns south and generally follows U.S. Highway 89 and existing transmission line facilities before entering Sanpete County. The line then runs parallel to existing transmission facilities for three miles before turning west to enter Salt Creek Canyon and then routing east and north of Nephi, Utah into the Clover substation. Figure 2 is a high-level map of the proposed route:









A. Yes. The Transmission Projects (Gateway South and Gateway West Segment D.1) will
allow the Company to interconnect an additional 2,030 MW of generation resources in
eastern Wyoming and increase the system transfer capability by approximately
875 MW from the Windstar/Dave Johnston area south to Shirley Basin/Aeolus. This

159

160

will create approximately 1,700 MW of incremental transfer capability from eastern Wyoming (Aeolus) to the central Utah energy hub (Mona/Clover).

161 Q. Has the Company conducted any studies to verify these figures?

162 Yes. WECC path rating studies previously performed for the Aeolus South A. 163 transmission path established the 1,700 MW path rating for the full Energy Gateway 164 Project configuration, which can be achieved once Gateway South, Gateway West 165 Segment D.1, and Gateway West Segment D.2 are in service. Additionally, the 166 Company performed preliminary transfer capability assessment/System Operating 167 Limit ("SOL") studies, which modeled the Gateway South and Gateway West Segment 168 D.1, together with Gateway West Segment D.2. These studies confirmed the 1,700 MW 169 path rating on Gateway South and the ability to interconnect up to 2,030 MW of wind 170 generation in southeast Wyoming.

171 Q. Did the studies require the retirement of the Dave Johnston plant to achieve these 172 increases?

A. No. The Company's studies have shown that the 1,700 MW transfer capability on the
Gateway South transmission path can be achieved with or without Dave Johnston
generation being on-line because of the location of the Dave Johnston plant. Dynamic
voltage control was modeled at the Dave Johnston plant when generation was reduced
to zero.

178 Q. Does construction of Gateway South include any related modifications to the 179 Company's transmission system?

180 A. Yes. The Company must also modify the existing 345-kV transmission infrastructure
181 in the Mona/Clover area. Specifically, the Company proposes to reconstruct and

reconductor approximately five miles of the existing single-circuit Mona-to-Clover
345-kV #1 and #2 transmission lines. In addition, the existing 345-kV Huntington-toMona transmission line will be rerouted through the Clover substation via two miles of
new 345-kV transmission line. The 345-kV series reactors at Mona will be relocated to
Clover and serially connected to the Huntington – Clover 345-kV line.

187The Company also proposes installing additional shunt capacitors at the188Bonanza 138-kV substation in Utah and the Mustang 230-kV and Riverton 230-kV189substations in Wyoming.

190

The Company must also modify the Aeolus remedial action scheme.

191 Q. What types of towers and conductors will be used to construct Gateway South?

A. Gateway South will be constructed using approximately 1,570 structures utilizing a mixture of self-supported lattice steel towers and guyed-v towers with heights ranging from about 140 to 200 feet. In select areas a tubular steel H-frame will be deployed with a height range of about 110 to 165 feet. The selection of tower for each location is based on a combination of access, terrain, environmental constraints, efficiency and engineering preference.

198The self-supported steel lattice towers will have a "flat" configuration with each199phase being parallel to each other in a horizontal arrangement. The guyed-v towers200have a similar phase configuration, though are supported by one foundation and four201guy anchor points.

202The conductor for Gateway South will be triple bundled 1272 kcmil 45/7203Aluminum Conductor Steel Reinforced ("ACSR") "Bittern" per phase. Each conductor

in the phase bundle will have a diameter of 1.345 inches, with three phases, comprisedof three conductors each, for a total of nine conductors in the circuit.

In addition, each of the transmission line segments will also carry two overhead ground wires. One of the wires will be galvanized steel while the other will be optical ground wire ("OPGW") to facilitate communications. The wires will have a diameter of approximately 0.5 inches and 0.64 inches respectively. Optical signal regeneration sites are proposed in the segment between the Aeolus and Little Snake substations and also between the Coyote and Clover substations.

Q. What types of towers and conductors will be used to construct the 345-kV
transmission lines in the Clover/Mona area?

214 The 345-kV work will use a combination of tower types based on circuit design and A. 215 engineering characteristics. The 5-mile rebuild of the existing single circuit Mona-to-216 Clover 345-kV transmission line with H-frame construction with one circuit per 217 structure with H-frame tubular steel or self-supported lattice for the dead-end and large 218 angle structures. The conductor configuration will be triple bundle 1272 ACSR 219 "Bittern." The 'loop in' work associated with the Huntington-to-Mona line into the 220 Clover substation will use single circuit versions of the towers described above utilizing 221 a double bundle configuration of 954 ACSR "Rail" conductor.

In addition, each of the transmission line segments will also carry two overhead ground wires. One of the wires will be galvanized steel while the other will be OPGW to facilitate communications. The wires will have a diameter of approximately 0.5 inches and 0.64 inches respectively.

Page 12 – Direct Testimony of Rick A. Vail

226 Q. Will Gateway South require modifications to any substations?

A. Yes. Gateway South requires expansion of both the Aeolus substation, located near
Medicine Bow, Wyoming, and the Anticline substation, located near Point of Rocks,
Wyoming. Both the Aeolus and Anticline substations are new substations that are being
constructed in accordance with the resource approval granted by the Commission in
2018 for the construction of the Aeolus-to-Bridger/Anticline transmission line. In
addition, Gateway South requires expansion of the Clover substation.

233 Q. Please describe the proposed work at the Aeolus substation.

A. The existing Aeolus 500/230-kV substation constructed as part of Energy Vision 2020 will be expanded by approximately 14 acres to accommodate the Gateway South project. The substation will be constructed using conventional air insulated bus and equipment.

238 Construction of the Aeolus substation will require the following:

- Expansion of the existing 500-kV yard including all work to support the termination of one 500-kV transmission line to the Coyote series compensation substation, including completing two 500-kV breaker bays to support termination of the 500-kV line and connection to the high side of the 500/230-kV transformers;
- Installation of six single phase 500/230-kV transformer units with one
 additional spare unit;
- Installation of one 500-kV shunt capacitor, three single phase line reactors
 and one 138-kV neutral reactor;

248		• Completion of all site development, civil work, bus work, protection and
249		controls, security, and communications;
250		• Within the existing 230-kV yard, additional circuit breakers will be added
251		to support the 500/230-kV transformers and the new Aeolus – Freezeout #2
252		circuit. This will require two new additional bays to be constructed in the
253		area previously prepared for expansion. Installation of two 230-kV shunt
254		capacitors and one shunt reactor; and
255		• Implementation of modifications to the Aeolus remedial action scheme will
256		be required to take into account tripping of Gateway South and the Clover
257		500/345-kV transformer.
258		A preliminary one-line diagram and general layout is included in Exhibit RMP
259		(RAV-1) to my testimony.
260	Q.	Please describe the proposed work at the Anticline substation.
261	A.	The existing Anticline 500/345-kV substation constructed as part of Energy Vision
262		2020 will be expanded by approximately three acres to accommodate the Gateway
263		South project. The substation will be constructed using conventional air insulated bus
264		and equipment.
265		Construction of the Anticline substation will require the following:
265 266		 Construction of the Anticline substation will require the following: Expansion of the existing 345-kV yard including all work to support the
265 266 267		 Construction of the Anticline substation will require the following: Expansion of the existing 345-kV yard including all work to support the installation of phase shifting transformers;
265 266 267 268		 Construction of the Anticline substation will require the following: Expansion of the existing 345-kV yard including all work to support the installation of phase shifting transformers; Installation of three - three phase 345-kV 533.3-megavolt amperes
265 266 267 268 269		 Construction of the Anticline substation will require the following: Expansion of the existing 345-kV yard including all work to support the installation of phase shifting transformers; Installation of three - three phase 345-kV 533.3-megavolt amperes ("MVA") phase shifting transformer units;

271		• Completion of all site development, civil work, bus work, protection and
272		controls, security, and communications.
273		A preliminary one-line diagram and general layout is included in Exhibit RMP
274		(RAV-1).
275	Q.	Please describe the proposed expansion of the Clover substation.
276	A.	The existing Clover substation near Mona, Utah must be expanded by approximately
277		60 acres. The expansion is sited on parcels of land owned by the Bureau of Land
278		Management and PacifiCorp. The expanded substation will include additional security
279		fencing and an improved access road, and will be constructed using conventional air
280		insulated bus and equipment.
281		Construction of the Clover substation will require the following:
282		• Modification and expansion to the existing 345-kV substation with
283		extension of the main bus, addition of two 345-kV shunt reactors;
284		• Relocation of the existing Limber/Oquirrh - Clover transmission line
285		termination from the east side of the substation to a new line termination on
286		the west side of the substation. This will be accomplished through the
287		addition of a 345-kV breaker and half line termination bay. This will then
288		allow connection of the new 345-kV shunt reactors;
289		• Construction of two further 345-kV breaker and half bays to allow
290		connection to the low side of the second 500/345-kV transformer;
291		• Addition of a new line termination bay including three, 345-kV breakers to
292		accommodate a breaker and a half bay configuration for the re-routing of
293		the Huntington – Mona 345-kV transmission line via Clover;

Page 15 – Direct Testimony of Rick A. Vail

294		• Installation of a 345-kV series reactor relocated from the Mona substation;
295		• Construction of the new 500-kV substation yard including all work to
296		support the termination of one 500-kV transmission line from the Aeolus
297		substation;
298		• Construction of two 500-kV breaker bays to support termination of the 500-
299		kV line and connection to the high side of two banks of 500/345-kV
300		transformers;
301		• Installation of six single phase 500/345-kV transformer units with one
302		additional spare unit;
303		• Installation of two 500-kV shunt capacitors, three single phase 500-kV line
304		reactors and one 138-kV neutral reactor; and
305		• Completion of all site development, civil work, bus work, protection and
306		controls, security and communications, and construction of a 500-kV
307		control building including site emergency power.
308		A preliminary one-line diagram and general layout is included in Exhibit
309		RMP_(RAV-1).
310	Q.	Please describe the series compensation stations.
311	A.	Due to the length of Gateway South (416 miles), two series compensation stations will
312		be inserted in the line to reduce net transmission line impedance and improve the power
313		transfer capability of the line. The addition of series compensation also improves power
314		flow control, voltage regulation and increases transient stability margin of line.
315		The first proposed series compensation substation (Little Snake Colorado) will
316		be located in northern Colorado approximately 148 miles from the Aeolus substation

Page 16 – Direct Testimony of Rick A. Vail

and 30 miles north of Maybell, Colorado. The second proposed series compensation
site (Coyote) will be located 106 miles from Little Snake and around five miles
southwest of the DG&T Bonanza generating station in Utah.

320 Q. Please describe the proposed new Little Snake series compensation substation.

- 321 The proposed Little Snake series compensation substation will be located in northern A. 322 Colorado, approximately 148 miles from the Aeolus substation and 30 miles north of 323 Maybell, Colorado on a Bureau of Land Management-owned parcel. The new series 324 compensation substation will occupy an area of approximately 20 acres and include 325 security fencing and a small access road and will be constructed using conventional air 326 insulated bus and equipment. The Little Snake series compensation substation will 327 provide a method to connect the 500-kV transmission line to the series compensation 328 equipment. The site will be designed to allow for future expansion.
- 329 Construction of the Little Snake series compensation substation will require the330 following:
- Construction of the new 500-kV series compensation substation yard
 including all work to support the termination of one 500-kV transmission
 line from the Aeolus substation and another to the Coyote series
 compensation substation;
- Construction of 500-kV substation dead-end structures and overhead strain
 bus to accommodate connection to the series compensation equipment,
 disconnects, reactors and transition of the transmission line through the site;
- Installation of one, 2-segment 500-kV 2300/3105 Ampere series capacitor
 with bypass circuit breakers;

Page 17 – Direct Testimony of Rick A. Vail

- Installation of six single phase 500-kV line reactors and two 138-kV neutral
 reactors;
- Completion of all site development, civil work, bus work, protection and
 controls, security, primary metering, communications, and construction of
 a control building including site emergency power.

A preliminary one-line diagram and general layout is included in Exhibit RMP_(RAV-1). The preliminary drawings included in my exhibit show the name of this series compensation substation as "Godiva", which has since been changed to Little Snake".

Q. Please describe the proposed new Coyote series compensation substation.

350 The proposed Coyote series compensation substation will be located 106 miles from A. 351 Little Snake and around five miles southwest of the DG&T Bonanza generating station, in Uintah County, Utah, on a Bureau of Land Management-owned parcel. The new 352 353 series compensation substation will occupy an area of approximately 20 acres, will 354 include security fencing and an upgraded access road, and will be constructed using 355 conventional air insulated bus and equipment. The Coyote series compensation 356 substation will provide a method to connect the 500-kV transmission line to the series 357 compensation equipment. The site will be designed to allow for future expansion.

358 Construction of the Coyote series compensation substation will require the 359 following:

360

361

• Construction of the new 500-kV series compensation substation yard including all work to support the termination of one 500-kV transmission

- 362 line from the Little Snake series compensation substation and another to the363 Clover substation;
- Construction of 500-kV substation dead-end structures and strain bus to
 accommodate connection to the series compensation equipment,
 disconnects, reactors and transition of the transmission line through the site;
- Installation of one, 2-segment 500-kV 2300/3105 Ampere series capacitor
 with bypass circuit breakers;
- Installation of six single phase 500-kV line reactors and two 138-kV neutral
 reactors; and
- Completion of all site development, civil work, bus work, protection and
 controls, security and communications, and construction of a control
 building including site emergency power.
- 374 A preliminary one-line diagram and general layout is included in Exhibit375 RMP (RAV-1).

Q. Please describe any other related substation scopes or miscellaneous works required to support Gateway South.

A. The project will include modifications at the Mona substation (approximately five miles north of Clover substation) to relocate an existing 345-kV series reactor to Clover, modify one existing 345-kV bay and the bus to create the Clover – Camp Williams 345-kV line, by combining the existing Camp Williams to Mona #3 line and Mona to Clover 345-kV #3 line into one line which bypasses overhead Mona substation. Additionally, upgrade of two 345-kV breaker and half bays to 3000 Ampere capacity will be required by the replacement of six breakers and associated switches.

Page 19 – Direct Testimony of Rick A. Vail

REDACTED

385		Modifications to relays, protection systems, controls and communications as necessary
386		to support safe operation of the facilities will also be required.
387		The project will also include, subject to additional verification upon
388		identification of generation interconnects, additional shunt capacitors at:
389		• Bonanza: two 138-kV shunt capacitors and associated breakers;
390		• Mustang: two 230-kV shunt capacitors and associated breakers; and
391		• Riverton: one 230-kV shunt capacitor and associated breaker.
392		A number of other substations are expected to require relay modification work
393		and other ancillary facilities may be necessary as preliminary engineering designs
394		become final.
395		ESTIMATED COST AND TIMING OF THE TRANSMISSION PROJECTS
396	Q.	Please describe the estimated total cost of Gateway South.
397	А.	The following table provides a breakdown of the estimated total costs for each main
398		component of Gateway South.

Confidential Table I - Galeway South					
Item	Cost Estimate (\$m)				
Transmission					
Substation					
Engineering					
ROW Acquisition					
PM/Environmental/Support					
Indirects					
Total	\$2,074.00				

Confidential Table 1 - Gateway South

- 399 Q. What is the estimated cost including Gateway West Segment D.1?
- 400 A. The estimated costs of the Transmission Projects including Gateway West Segment
- 401 D.1 is \$2.4 billion.

402 Q. Does the Company have the financial ability to construct Gateway South?

A. Yes. Similar to previously built components of the Energy Gateway Project, the
Company intends to finance Gateway South through its normal internal and external
sources of capital, including net cash flow from operating activities, public and private
debt offerings, the issuance of commercial paper, the use of unsecured revolving credit
facilities, capital contributions, and other sources. The financial impact will not impair
the Company's ability to continue to provide safe and reliable electricity service at
reasonable rates.

410 Q. Will the cost of Gateway South be included in PacifiCorp's transmission rates?

A. Yes. Gateway South is considered an integrated network transmission asset under
PacifiCorp's OATT. As described in more detail later in my testimony, Gateway South
not only provides a number of benefits to the transmission grid, but its construction,
together with Gateway West Segment D.1, allows PacifiCorp to provide nearly
2,500 MW of OATT service requests. As a result, FERC precedent for ratemaking
requires PacifiCorp to roll the costs of these assets into PacifiCorp's federal
transmission rate base.

418 Q. How will the costs of Gateway South flow into PacifiCorp's transmission rates and 419 who will pay these rates?

A. All transmission rates charged to wholesale transmission customers must be approved
by FERC. PacifiCorp's transmission rate structure is a FERC-approved formula that
has been in place since 2012. A formula rate is a method of calculating a rate but is not
the rate itself; the actual transmission rate that is charged to wholesale transmission
customers is produced annually by updating FERC-approved inputs to the formula rate.

Page 21 – Direct Testimony of Rick A. Vail

Formula rates rely on annual updates using inputs from the detailed, publicly available,
and audited FERC Form No. 1, along with other Company data. The annual update
process includes transmission capital additions such as Gateway South.

428 Consistent with all other transmission assets, Utah retail rates would reflect the 429 state's system allocation of the cost of Gateway South and a revenue credit for the third-430 party transmission customers that pay PacifiCorp's OATT rate, which offset, in part, 431 the cost of PacifiCorp's transmission revenue requirement in retail rates.

432 Q. When does the Company expect to complete the construction of Gateway South?

A. The Company plans to have Gateway South in service by the end of 2024. As Mr. Link
testifies, this plan is designed to cost-effectively address PacifiCorp's need for
additional generation resources. As I will describe in more detail later in my testimony,
one of the benefits of Gateway South is that it will support the addition of new
generation resources. In order to take advantage of the full value of investment tax
credits associated with new solar generation resources—which directly benefit Utah
customers— Gateway South must be in service no later than December 31, 2024.

440 Q. Why did the Company move the completion of Gateway South to 2024, when the
441 2019 IRP indicated that it was expected to be placed in service in 2023?

A. The in-service date for Gateway South was intended to align with the expected inservice date for the new generation resources that would require Gateway South to
interconnect to PacifiCorp's system. As Mr. Link testified, this alignment was designed
to cost-effectively address PacifiCorp's need for additional generation resources.
When the bids were received and evaluated in the 2020AS RFP, it became apparent
that most bidders proposed a 2024 in-service date. Because the bids reliant on Gateway

Page 22 – Direct Testimony of Rick A. Vail

- South to interconnect were not proposing to interconnect in 2023, the Company was
 able to defer construction of Gateway South (and Gateway West Segment D.1) to 2024
 without compromising the benefits supplied by new generation resources.
- 451 Q. Does the 2024 in-service date compromise the value of tax credits attributable to
 452 the generation resources selected in the 2020AS RFP?
- A. No. As Mr. Link testifies, the deadline for production tax credits for new wind
 resources has been extended to 2024, which means that customers will still receive the
 full benefits of the credits when the Transmission Projects and the new generation
 resources achieve commercial operation in 2024.

457 Q. Does the 2024 in-service date affect the Company's ability to meet its obligations 458 under its OATT to provide interconnection and transmission service?

- A. No. The current schedule still allows the Company to meet its obligations under its
 OATT to reliably accommodate approximately 2,500 MW of interconnection and
 transmission service requests governed by 13 executed contracts that require the
 construction of one or both of the Transmission Projects, which is discussed in more
 detail below. To provide the contractually required transmission service and
 interconnection service by 2024, the Company expects the Transmission Projects to go
 into service before the end of 2024.
- 466 Q. Given the new 2024 in-service date, when must the Company start construction of
 467 Gateway South?
- 468 A. To achieve an in-service date before the end of 2024, the Company must start 469 construction no later than June 2, 2022, which will allow three full construction

Page 23 – Direct Testimony of Rick A. Vail

470 seasons. To meet this timeline, the Company must receive a CPCN from the471 Commission by June 1, 2022.

472 Q. Will any project related activities commence prior to June 2, 2022?

473 Yes. The Company plans to begin pre-construction activities before June 2, 2022. A. These pre-construction activities include moving heavy equipment to the project area, 474 475 ground survey work for transmission tower pads and access roads, and pre-construction 476 cultural and biological surveys, as required by the Bureau of Land Management. 477 Additionally, the contractor will obtain its storm water pollution prevention plan 478 permit, will identify sources of water for construction use to meet regulatory 479 stipulations, and will make the necessary pre-construction preparations required by 480 those permits. By undertaking these pre-construction activities prior to June 2, 2022, 481 the Company will be well positioned to begin actual construction once it has a CPCN.

483

482

See Figure 3 below:

Figure 3

EV 2024 - Gateway South Activities	April-22	June-22	1-Jun-22	Q3 22	Q4 22	Q1 23	Q2 23	Q3 23	Q4 23	Q1 24	Q2 24	Q3 24	31-0d-24
PRE-CONSTRUCTION ACTIVITIES													
Light grading, material delivery yards preparation, staking, surveys and mobilization of contractor equipment; procurement of long lead materials													
CONSTRUCTION ACTIVITIES													
Access road work, tower pads prep, foundation installation													
Materials staging, tower erection, conductor stringing													
Gean up, restoration, test & commission													
EN ER GIZATION													

484

NECESSITY OF THE TRANSMISSION PROJECTS

- 485 Q. Does Gateway South facilitate PacifiCorp's compliance with federal reliability486 related requirements?
- 487 Yes. PacifiCorp's obligation to operate its transmission system reliably primarily stems A. 488 from two main requirements: (1) PacifiCorp's obligation to comply with its federal 489 OATT that governs the rates, terms, and conditions of PacifiCorp's reliable provision 490 of transmission and interconnection services; and (2) PacifiCorp's obligation to comply 491 with federal mandatory reliability standards. As I will discuss in more detail in this 492 section, PacifiCorp used the federal OATT study process to identify the construction 493 of the Transmission Projects as a prerequisite to reliably meeting nearly 2,500 MW of 494 transmission and interconnection service requests, and the Transmission Projects were 495 listed in multiple FERC-jurisdictional executed contracts accordingly. In addition, the 496 Transmission Projects facilitate PacifiCorp's compliance with federal reliability 497 standards.
- 498 Compliance with OATT and Executed Contracts

499 Q. Can you provide some background on the creation of PacifiCorp's OATT?

A. Yes. I am not a lawyer, but I am aware that in 1996, FERC issued a landmark order
establishing its open access transmission policies.¹ In short, FERC required that
transmission providers offer third parties "open access" to their transmission systems.
To implement this requirement, FERC created a pro forma OATT with standardized
rates, terms, conditions, processes, and contracts to govern the provision of

¹ Promoting Wholesale Competition Through Open Access Non-discriminatory Transmission Services by Pub. Utils.; Recovery of Stranded Costs by Pub. Utils. and Transmitting Utils., Order No. 888, 61 Fed. Reg. 21,540 (May 10, 1996).

505	transmission services. All transmission providers must model their OATT after
506	FERC's pro forma OATT and maintain their FERC-approved OATT on file with FERC
507	at all times. Any deviations from the pro forma OATT must be filed with FERC for
508	approval.

- 509 Q. What services does the federal OATT govern?
- 510 A. The OATT primarily governs two basic services: (1) transmission service; and
 511 (2) generator interconnection service.
- 512 Q. How is OATT service requested?
- A. OATT service is requested through a FERC-mandated public website called the Open
 Access Same-Time Information System ("OASIS").
- 515 Q. What happens after PacifiCorp receives a request for OATT service?
- A. PacifiCorp must follow the OATT process to perform a series of increasingly more involved engineering studies that evaluate the cost and timing requirements associated with providing the requested service. PacifiCorp must issue reports summarizing the results of its OATT studies and make those reports publicly available by posting them on OASIS. At the end of the study process, PacifiCorp must tender the requesting party a standardized OATT contract that memorializes the cost and timing requirements identified in the study process.
- 523 Q. What do you mean by "cost and timing requirements" associated with providing
 524 the requested OATT service?
- 525 A. When PacifiCorp receives a request for OATT service, it must evaluate whether it can 526 reliably provide that service on its existing transmission system within the timeframe 527 requested. For example, if the existing transmission system is capable of reliably

delivering the requested amount of additional transfer capacity associated with a transmission service request or reliably interconnecting the requested amount of generation associated with a generator interconnection request, the OATT studies evaluating that request are likely to state that the service can be granted within the requested timeframe with minimal or no transmission system upgrade costs.

533 If, on the other hand, the existing transmission system is *not* capable of reliably 534 delivering or reliably interconnecting additional capacity in the area of the system 535 where the OATT service has been requested, PacifiCorp cannot simply conclude no 536 service can be provided and reject the service request. Rather, the OATT requires 537 PacifiCorp to identify what transmission system upgrades are needed to accommodate 538 the request, as well as the estimated cost and timing associated with constructing those 539 upgrades. Those upgrades then become requirements identified in the OATT 540 customer's OATT contract.

541 OATT Obligation to Construct Transmission System Upgrades

542 Q. Does the OATT require PacifiCorp to construct transmission system upgrades 543 necessary to grant OATT service requests?

A. Yes. The OATT requires PacifiCorp to construct transmission system upgrades
necessary to grant OATT requests for transmission service and OATT requests for
generator interconnection service. This obligation to construct is found in the OATT's
provisions governing: (1) network transmission service; (2) point-to-point transmission
service; and (3) generator interconnection service.

Page 27 – Direct Testimony of Rick A. Vail

549 Q. Can you describe the OATT's requirement to construct transmission system 550 upgrades in response to a network transmission service request?

A. Yes. The OATT's network transmission service provisions require a transmission provider to "plan, <u>construct</u>, operate and maintain its Transmission System in accordance with Good Utility Practice and its planning obligations in Attachment K in order to provide the Network Customer with Network Integration Transmission Service over the Transmission Provider's Transmission System" and "endeavor to <u>construct</u> and place into service sufficient transfer capability" to deliver network customer resources to load.²

558 Q. Can you describe the OATT's requirement to construct transmission system 559 upgrades in response to a point-to-point transmission service request?

560 A. Yes. The OATT's point-to-point transmission service provisions require a transmission

561 provider to "use due diligence to **expand or modify** its Transmission System to provide

- the requested Firm Transmission Service" if the transmission provider cannot
- 563 accommodate the request because of insufficient capability on its system.³ PacifiCorp's
- 564 OATT provides as follows:

565 In cases where the Transmission Provider determines that the Transmission System is not capable of providing Firm Point-To-566 567 Point Transmission Service without (1) degrading or impairing the reliability of service to Native Load Customers. Network 568 Customers and other Transmission Customers taking Firm 569 570 Point-To-Point Transmission Service, or (2) interfering with the 571 Transmission Provider's ability to meet prior firm contractual 572 commitments to others, the Transmission Provider will be 573 obligated to expand or upgrade its Transmission System pursuant to the terms of Section 15.4.4 574

² PacifiCorp OATT, Section 28.2 (emphasis added).

³ PacifiCorp OATT, Section 15.4 (emphasis added).

⁴ PacifiCorp OATT, Section 13.5 (emphasis added).

575 Q. Can you describe the OATT's requirement to construct transmission system 576 upgrades in response to a generator interconnection service request?

A. Yes. Sections 36-52 of PacifiCorp's OATT contain comprehensive rules for
interconnecting new generators, including the identification and construction of new
network upgrades if they are necessary to grant the request. Importantly, the OATT
process does not give PacifiCorp any tariff authority to refuse an interconnection
request simply because it would require new network upgrades.

582 Q. Has FERC clarified this OATT requirement?

- A. Yes. While I am not a lawyer, I am aware that in 2003, FERC issued another series of landmark "open access" orders specifically focused on the standardization of the rates, terms, conditions, processes, and contracts under which a transmission provider offers generator interconnection service.⁵ FERC established pro forma interconnection provisions to be included in every transmission provider's OATT on file with FERC and directed that transmission providers file any proposed deviations from the pro forma interconnection provisions with FERC for approval.
- In that interconnection proceeding, FERC explained that its pro forma interconnection services "provide for the <u>construction of Network Upgrades</u> that would allow the Interconnection Customer to flow the output of its Generating Facility onto the Transmission Provider's Transmission System in a safe and reliable manner."⁶

⁵ In 2003, FERC standardized its rules for large generators in the Order No. 2003 proceeding in FERC Docket No. RM02-1. In 2005, FERC standardized its rules for small generators in the Order No. 2006 proceeding in FERC Docket No. RM02-12.

⁶ Standardization of Generator Interconnection Agreements and Procedures, Order No. 2003, 104 FERC ¶ 61,103 at P 767 (2003) (emphasis added).

594

595

Q. Does the OATT obligation to construct in response to service requests apply even if the upgrades at issue are previously planned transmission projects?

596 Yes. The OATT obligation to construct applies to both (1) transmission system A. 597 upgrades triggered for the first time in response to an OATT request and (2) previously 598 planned transmission projects identified as necessary to grant an OATT request. By 599 way of background, FERC required transmission providers to amend their OATTs to 600 address transmission planning obligations and processes. For PacifiCorp, 601 Attachment K of its OATT sets forth inter-regional, regional, and local transmission 602 planning processes that are overseen by FERC, the North American Electric Reliability 603 Corporation ("NERC"), and the Western Electricity Coordinating Council ("WECC"). 604 As with all provisions in the OATT, PacifiCorp secured FERC approval of the 605 Attachment K provisions and must file any proposed changes with FERC.

606 Q. How does this FERC-approved OATT Attachment K process relate to the 607 OATT's obligation to construct transmission system upgrades?

A. PacifiCorp's FERC-approved Attachment K makes clear that once a planned
transmission project is required to be in service in order for PacifiCorp to grant an
OATT request for point-to-point transmission service or generator interconnection
service, PacifiCorp is obligated to construct the planned facilities: "Transmission
Provider shall use Point-to-Point Transmission Service usage forecasts and Demand
Resources forecasts to determine system usage trends, and such forecasts do not
obligate the Transmission Provider to construct facilities until formal requests for

Page 30 – Direct Testimony of Rick A. Vail

- either Point-to-Point Transmission Service or Generator Interconnection Service
 requests are received pursuant to Parts II and IV of the Tariff."⁷
- 617 Q. If PacifiCorp's ability to provide requested OATT service is contingent upon a

618 component of PacifiCorp's long-term transmission plan being in service, do the

- 619 **OATT studies and OATT contracts make that clear?**
- A. Yes. If PacifiCorp cannot reliably provide requested OATT service until a component
- 621 of PacifiCorp's long-term transmission plan is in place, that upgrade would be listed in
- 622 the OATT study and OATT agreement as a "Contingent Facility." FERC recently
- 623 formalized this definition with respect to generator interconnection service, and
- 624 approved the following definition for inclusion in PacifiCorp's OATT:
- 625 Contingent Facilities shall mean those unbuilt Interconnection 626 Facilities and Network Upgrades upon which the 627 Interconnection Request's costs, timing, and study findings are dependent, and if delayed or not built, could cause a need for 628 629 Re-Studies of the Interconnection Request or a reassessment of the Interconnection Facilities and/or Network Upgrades and/or 630 631 costs and timing.⁸

632 The Transmission Projects are Requirements in FERC-Jurisdictional Executed
 633 Contracts

634 Q. How do these OATT obligations to construct transmission system upgrades relate

635 to the Transmission Projects?

636 A. The Transmission Projects have become a lynchpin in PacifiCorp's ability to provide

- 637 thousands of MW of requests for FERC-jurisdictional OATT generator interconnection
- 638 service and transmission service. Stated more directly, under my signature as Vice
- 639 President of PacifiCorp Transmission, PacifiCorp has executed 13 transmission service

⁷ PacifiCorp OATT, Attachment K (emphasis added).

⁸ PacifiCorp OATT at section 36.

and generator interconnection service contracts that list either one or both of the
Transmission Projects Contingent Facilities. This means that PacifiCorp *cannot provide* the contracted services to 13 contractual counterparties without constructing
the Transmission Projects.

- 644 Transmission Service Contract Obligations
- 645 Q. Can you describe the transmission service contract obligations dependent on the
 646 Transmission Projects?
- A. Yes. PacifiCorp received an OATT request to provide 500 MW of point-to-point
 transmission service from Aeolus to Mona. In accordance with the OATT process I
 outlined above, PacifiCorp determined it could not deliver an additional 500 MW of
- 650 power on its existing transmission system, so it performed an OATT system impact
- 651 study to determine what transmission system upgrades would be required to do so.
- 652 PacifiCorp's OATT system impact study report, which is publicly posted to OASIS,⁹
- 653 states that PacifiCorp's planned Gateway South 500 kV line from the Aeolus substation
- 654 to the Clover substation near Mona, Utah must be in place to grant the requested FERC-
- 655 jurisdictional point-to-point transmission service.
- 656 Q. Why did PacifiCorp conclude that the requested transmission service could not
- 657 be provided on the existing transmission system?
- 658 A. The short answer is due to reliability concerns. As I walked through in more detail
- above, the OATT states that:
- 660where the Transmission Provider determines that the Transmission System is661not capable of providing Firm Point-To-Point Transmission Service without (1)662degrading or impairing the reliability of service to Native Load Customers,663Network Customers and other Transmission Customers taking Firm Point-To-

⁹ See Request No. Q2594 in PacifiCorp's transmission service queue, available at: http://www.oasis.oati.com/ppw/index.html.

664Point Transmission Service, or (2) interfering with the Transmission Provider's665ability to meet prior firm contractual commitments to others, the Transmission666Provider will be obligated to expand or upgrade its Transmission System667pursuant to the terms of Section 15.4.

That was the case here because the current transmission system could not reliably 668 669 support the transfer of an additional 500 MW of power from Aeolus to Mona. Under 670 steady-state conditions, increasing transfers between eastern Wyoming (Aeolus) and 671 central Utah (Mona) by 500 MW would result in a voltage collapse of the PacifiCorp 672 east side transmission system for a minor system contingency in Wyoming or northern 673 Utah. Such a voltage collapse would violate NERC and WECC reliability standards, 674 which I will address in more detail later in my testimony, would degrade the reliability 675 of service to other customers, and would negatively impact other utilities in the Western 676 Interconnection.

677 Q. Why did PacifiCorp identify Gateway South as the "contingent facility" solution 678 to the reliability concern?

A. As I noted above, the OATT service request is for 500 MW of point-to-point service
starting on January 1, 2024 from Aeolus to Mona—the exact path of the proposed
Gateway South line. Gateway South is estimated to provide an additional 1,700 MW
of transfer capability by the end of 2024. Therefore, Gateway South was identified as
the contingent facility that would allow PacifiCorp to provide the requested MW
amount, along the requested path, and in the same general requested timeframe.

685 Q. Could you provide the requested FERC-jurisdictional transmission service with a
 686 much smaller upgrade if you had not relied upon PacifiCorp's long-term plan for
 687 the upgrade solution?

688 No. As a threshold matter, I will note that identifying a long-term transmission plan A. 689 component as a contingent facility to providing requested service is consistent with the 690 OATT's directive that transmission providers make efficient use of the estimated 691 capabilities and estimated timelines associated with the transmission provider's long-692 term transmission plan. This may not always lead to the identification of a transmission 693 system upgrade that creates the precise amount of transfer or interconnection capability 694 needed to grant the requested service. That is the case here where Gateway South 695 creates more transfer capability than is needed to grant the point-to-point request. 696 However, I agree with FERC that it is generally far more efficient to identify planned 697 projects when possible because those projects have gone through extensive local, 698 regional and inter-regional planning coordination spanning multiple years. 699 Additionally, significant permitting efforts and other regulatory processes can take 700 years to get final approvals. Therefore, projects that are already well advanced in this 701 process are more likely to be successful.

702 Q. Did identifying Gateway South as a contingent facility for this specific point-to 703 point transmission service request result in those efficiencies?

A. Yes. In fact, the planned Gateway South project is not significantly greater than the
 transmission system upgrades that would be needed to grant just this isolated request
 based on an evaluation PacifiCorp performed in response to stakeholders in the
 Company's 2019 Integrated Resource Plan proceeding before the Commission.

Page 34 – Direct Testimony of Rick A. Vail

708 Specifically, stakeholders asked PacifiCorp to provide information about how its 709 preferred portfolio and system costs might be impacted if Gateway South is assumed to be removed from the preferred portfolio. In response, PacifiCorp explained that, even 710 711 if Gateway South is not constructed, it is unrealistic to assume that PacifiCorp 712 transmission would not be obligated to construct any transmission system upgrades out 713 of eastern Wyoming to accommodate FERC-jurisdictional requests for OATT 714 interconnection service and transmission service. PacifiCorp continued that, even 715 conservatively ignoring the transmission system upgrades that would be required to 716 grant all of the requests it has received for FERC-jurisdictional interconnection and 717 transmission service and focusing only on the 500 MW point-to-point transmission 718 service request I described above, PacifiCorp estimated it would need to construct, at a 719 minimum, a 230-kV transmission line by the end of 2023, at a cost of approximately 720 \$1.4 billion.

Q. So does the OATT obligation to construct apply only to a 230-kV transmission line, rather than a 500-kV transmission line, from Aeolus to Mona?

A. No. PacifiCorp estimated that a 230-kV line would be required to grant the 500 MW
transmission service request, and *only* that request. As I will discuss in more detail in
the next section, PacifiCorp has far more than a single request for OATT service in
Wyoming, and PacifiCorp could not grant all of the requests with only a 230-kV line.

- 727 Q. Did you execute a FERC-jurisdictional transmission service contract with the
 728 entity requesting the 500 MW of point-to-point transmission service?
- A. Yes. PacifiCorp followed the OATT transmission service study process, which ends
- 730 with the transmission provider tendering to the transmission customer an OATT pro

Page 35 – Direct Testimony of Rick A. Vail

- forma draft transmission service agreement along with the system impact study report
 I described above. The transmission customer executed the transmission service
 agreement.
- 734 Interconnection Service Contract Obligations

735 Q. Can you describe the interconnection service contract obligations dependent on

736

the Transmission Projects?

737 Yes. PacifiCorp has received approximately 15,000 MW of requests for generator A. 738 interconnection service in eastern Wyoming. In accordance with the OATT process I 739 described above, PacifiCorp has determined it cannot reliably accommodate any 740 additional generator interconnections in that area without improvements in place. As a 741 result, PacifiCorp has performed and posted to OASIS many system impact studies 742 identifying either one or both of the components of the Transmission Projects (Gateway 743 South and Gateway West Segment D.1) as contingent facilities necessary to grant 744 requested interconnection service. Table 2 below identifies these results at a high 745 level:10

¹⁰ The studies provide additional detail on these requirements and are available by cross-referencing the queue numbers in this table with PacifiCorp's interconnection queue, available at: http://www.oasis.oati.com/ppw/index.html.

Table 2

Q #	MW	One or Both Transmission Projects Required
Q409	320	Gateway South
Q713	350	Gateway South, Gateway West Segment D.1
Q719	280	Gateway South, Gateway West Segment D.1
Q783	30	Gateway South, Gateway West Segment D.1
Q784	80	Gateway South, Gateway West Segment D.1
Q785	100	Gateway South, Gateway West Segment D.1
Q789	74.9	Gateway South, Gateway West Segment D.1
Q801	80	Gateway South, Gateway West Segment D.1
Q802	50	Gateway South, Gateway West Segment D.1
Q807	75.9	Gateway South, Gateway West Segment D.1
Q835	190	Gateway South, Gateway West Segment D.1
Q836	400	Gateway South, Gateway West Segment D.1

747 Q. Why did PacifiCorp conclude that the requested generator interconnections could

748

not be provided on the existing transmission system?

749 A. Again, the short answer is due to reliability concerns. As I walked through in more 750 detail above, FERC requires transmission providers to identify the transmission system 751 upgrades that need to be constructed to allow the interconnection customer to "flow the 752 output of its Generating Facility onto the Transmission Provider's Transmission 753 System in a safe and reliable manner." Here, interconnecting additional generation in 754 the eastern Wyoming area without construction of the Transmission Projects would 755 result in a voltage collapse of the PacifiCorp east side transmission system for a minor 756 system contingency in Wyoming or northern Utah. Such a voltage collapse would 757 violate NERC and WECC reliability standards, as I discuss in more detail later in my 758 testimony, would degrade the reliability of service to other customers and would 759 negatively impact other utilities in the Western Interconnection.

Page 37 – Direct Testimony of Rick A. Vail

Q. Would you have been able to reliably grant the requested generator
 interconnections with a much smaller upgrade if you had not relied upon
 PacifiCorp's long-term plan for the upgrade solution?

- A. No. In fact, PacifiCorp transmission performed an analysis to test this question. First, we assumed there was no plan to construct the Transmission Projects. Next, we evaluated what, if any, transmission upgrades would be required to grant the first generator interconnection request that required the Transmission Projects. We continued to add projects and evaluate individual incremental interconnection requirements one at a time until we had added all of the requests currently dependent on the Transmission Projects.
- 770 The analysis showed that while no single project individually triggered the need 771 for a 500-kV line, because of the cumulative nature of the project-specific studies, the 772 Company would have been required to construct more and more 230-kV and 345-kV 773 transmission lines. In total, the Company could interconnect an estimated 1,441 MW 774 of additional generation resources, which represent 10 interconnection requests, before 775 the next request triggered the need for a 500-kV line to interconnect. To interconnect 776 those 10 projects, however, would cost approximately \$1.53 billion dollars, the 777 Company would have achieved only 814 MW of incremental transfer capability, and it 778 would still have remaining interconnection requests in need of upgrade identification. 779 By comparison, the Transmission Projects are estimated to cost \$2.4 billion and provide 780 approximately 1,700 MW of transfer capability and 2,030 MW of interconnection 781 capability.

782

Q. What conclusions can you draw from the analysis you performed?

783 My primary conclusion is that PacifiCorp's identification of the planned Transmission A. 784 Projects as the upgrade solution to reliably interconnect additional generation in eastern 785 Wyoming did not lead to more significant upgrades than would have been otherwise 786 required. The analysis demonstrates that the Company likely would have ended up in largely the same spot (i.e., identifying a 500-kV line) with fewer financial, 787 788 interconnection, transmission, and operational efficiencies. As a result, it was not only 789 consistent with the OATT to identify components of PacifiCorp's long-term 790 transmission plan as contingent facilities in the interconnection studies, but it was also 791 beneficial.

792It is also important to remember that this analysis looked at interconnection793requests in isolation, without regard to transmission service requests like the 500 MW794point-to-point request I discussed at length previously. In reality, the OATT requires795PacifiCorp to identify the transmission system upgrades necessary to grant *all* of the796requests it receives, not just some. Based on the analysis I have discussed in my797testimony, it would be impossible to do that without constructing Transmission Projects798or their functional equivalent.

799 Q. Have you executed interconnection agreements identifying the Gateway South as 800 a contingent facility?

A. Yes. I have executed 12 interconnection agreements that identify the Transmission
 Projects, i.e., Gateway South or Gateway South *and* Gateway West Segment D.1, as
 contingent facilities. The counterparties to these executed agreements have, in total,

secured contractual rights to all of the estimated 2,030 MW of interconnection
capability of the Transmission Projects.

806 Q. Does FERC's recent approval of PacifiCorp's interconnection queue reform 807 proposal change PacifiCorp's obligation to comply with its executed 808 interconnection contracts?

A. No, it reaffirms it. By way of background, in June 2019, PacifiCorp initiated a sixmonth stakeholder process to examine potential interconnection processing reforms to
address the significant congestion in its interconnection queue, which at the time had
234 requests for over 40,000 MW of interconnection capacity.¹¹ PacifiCorp hosted a
series of in-person stakeholder meetings and phone calls, including at PacifiCorp's
corporate headquarters in Salt Lake City, Utah on October 9, 2019.

815 One of the primary issues discussed throughout the stakeholder process was 816 how to transition from serial-queue processing that cumulatively studies each 817 individual interconnection request and does not test the "commercial readiness" of any 818 generator (i.e., FERC's long-standing, first-come, first-served process) to a first-ready, 819 first-served process that studies requests in groups (called "clusters") on an annual basis 820 and requires large, FERC-jurisdictional generators to demonstrate readiness as a 821 prerequisite to receiving an interconnection study. Readiness may be proven by, for 822 example, providing evidence that the generator has an executed term sheet, executed 823 power-purchase agreement, or has been selected in a competitive solicitation process. One of the most critical elements to this transition discussion was whether any 824

¹¹ PacifiCorp posted all materials related to this stakeholder process, including issue lists, stakeholder written comments, straw proposals, and meeting dates, times, and attendees on OASIS: http://www.oasis.oati.com/ppw/index.html.

generators should be allowed to keep their serially processed studies or agreementswithout demonstrating readiness.

827 Initially, stakeholders strongly supported applying the new readiness testing 828 requirements to all interconnection customers, even those that were already at the end 829 of the study process or that had executed an interconnection agreement. The 830 stakeholders reasoned that allowing parties with executed interconnection contracts to maintain their contractual rights without demonstrating any type of commercial 831 832 readiness would prevent PacifiCorp from effectively clearing out its congested queue. 833 In response, PacifiCorp initially included this broad application of the transition 834 requirements in its straw proposals issued in September 2019 and November 2019 and 835 planned to make it part of its ultimate proposal filed with FERC. After additional 836 stakeholder discussions, however, it became clear there would be significant opposition 837 to this approach, particularly from counterparties having executed contracts. FERC 838 staff similarly signaled resistance to a proposal that would abrogate executed 839 interconnection agreements.

As a result of this feedback, PacifiCorp's January 31, 2020, filing with FERC¹² reflected a modified transition proposal that: (1) allows generators to retain executed interconnection agreement rights without demonstrating commercial readiness; and (2) allows "late stage" generators, defined as any interconnection customer that reached the facilities study agreement stage or later by April 1, 2020, the option to keep their serially processed studies and proceed to an agreement reflecting those study results as long as, for large generators, they can demonstrate commercial readiness. In addition,

¹² PacifiCorp filed its queue reform proposal on January 31, 2020, in FERC Docket No. ER20-924.

847 given that the vast majority of the projects in PacifiCorp's interconnection queue are 848 large, FERC-jurisdictional generators, PacifiCorp proposed not to require small, 849 FERC-jurisdictional generators or state-jurisdictional qualifying facility generators of 850 any size to provide evidence of commercial readiness at this time. PacifiCorp proposed 851 these requirements to be reflected in PacifiCorp's very first cluster study, the "transition cluster," that will begin no later than October 31, 2020, and take approximately six 852 853 months to complete. PacifiCorp also proposed limitations for requests that were too 854 early in the process by limiting eligibility for the initial October 2020 transition cluster 855 to only those interconnection customers that had a queue position by January 31, 2020.

In its May 12, 2020, order, FERC approved this transition approach, noting in particular with respect to the executed contracts that "PacifiCorp's Transition Process appropriately protects interconnection customers that are in the late stages of interconnection *by not disrupting already signed interconnection agreements* and continuing to process late-stage interconnection requests under the currently serial process, provided they meet the commercial readiness criteria."¹³

As I noted above, FERC's queue reform order does not change PacifiCorp's obligation to provide interconnection service under executed contracts, but rather emphasizes the importance of adhering to their terms.

865 Q. What would it mean for FERC-jurisdictional service requests with executed
 866 contracts if Gateway South is not constructed?

A. I cannot speak to the legal implications of the failure to construct the Gateway South
for lack of a CPCN, or any resulting tension between state certificate law and federal

¹³ PacifiCorp, 171 FERC ¶ 61,112 at P 144 (2020) (emphasis added).

869 requirements to expand the transmission system. I can, however, say that PacifiCorp, 870 in good faith, acted consistently with the federal OATT process and obligations when 871 it identified Gateway South as a transmission system upgrade that must be constructed 872 to reliably provide the requested service. PacifiCorp also acted consistently with the 873 federal OATT process when it listed Gateway South (and Gateway West Segment D.1) 874 as a contingent facility in the executed contracts—contracts that are on file with FERC. 875 If PacifiCorp is put in a position where it cannot construct Gateway South for lack of a 876 CPCN, and it cannot provide the requested OATT service reliably on the existing 877 system, the OATT would still require PacifiCorp to pursue transmission system 878 upgrades out of eastern Wyoming that are necessary to accommodate FERC-879 jurisdictional requests for OATT service.

880 Compliance with Reliability Standards

Q. You mentioned above that there are two main drivers behind PacifiCorp's obligation to operate its transmission system reliably. Can you describe the second driver?

A. Yes. In addition to the reliability components of the OATT related to accommodating
new service requests which I just discussed, FERC expanded the reliability-related
elements of the federal regulatory structure in implementing the reliability directives
contained in the Energy Policy Act of 2005. FERC did this by instituting mandatory
reliability standards that all users of the bulk electric system ("BES") must follow,
including transmission providers.

Page 43 – Direct Testimony of Rick A. Vail
890 Q. Who oversees development of and compliance with transmission provider 891 reliability standards?

A. FERC delegated authority to NERC to develop reliability standards to ensure the safe
and reliable operation of the BES in the United States in a variety of operating
conditions. On April 1, 2005, NERC established a set of transmission operations
reliability standards.

896 Q. Is compliance with the reliability standards optional?

A. No. The reliability standards are a federal requirement, subject to oversight and
enforcement by WECC, NERC, and FERC. PacifiCorp is subject to compliance audits
every three years, and may be required to prove compliance during other NERC or
WECC reliability initiatives or investigations. Failure to comply with the reliability
standards could expose the Company to penalties of up to \$1 million per day, per
violation.

903 Q. Is there a set of reliability standards most relevant to Gateway South?

A. Yes. A subset of the transmission reliability standards called the transmission planning
standards ("TPL Standards") are most relevant to both the Transmission Projects. The
purpose of the TPL Standards is to "establish transmission system planning
performance requirements within the planning horizon to develop a BES that will
operate reliably over a broad spectrum of system conditions and following a wide range
of probable contingencies."¹⁴ The TPL Standards, along with regional planning criteria
(*i.e.*, regional planning criteria established by WECC and utility-specific planning

¹⁴ See NERC Standard TPL-001-4, Transmission System Planning Performance Requirements, available at http://www.nerc.com/files/tpl-001-4.pdf.

911 criteria), define the minimum transmission system requirements to safely and reliably912 serve customers.

913 Q. How do NERC's and WECC's standards and criteria influence the need for the 914 Transmission Projects?

A. The mandatory standards, particularly NERC's TPL-001-4 standard, require the
Company to have a forward-looking transmission plan to reliably serve current and
anticipated customer demands under all expected operating conditions, including
normal system operations (all system elements in service) and during system
contingencies (where multiple elements of the transmission system are out of service),
both planned or otherwise.

The Company performs annual reliability assessments to determine whether its transmission system complies with minimum mandatory system performance standards, which require that during loss of any single transmission system element ("N-1 single contingencies") that firm service is maintained, no system overloads exist, and there is no loss of customer demand. The Company must also plan how it will respond to the second outage (this type of scenario is referred to as an N-1-1 condition).

927 The Transmission Projects, as part of Energy Gateway, have been included in
928 the Company's annual TPL-001-4 assessment as part of its short- and long-term plans
929 to dependably meet NERC and WECC reliability requirements for eight years.
930 Gateway South's new transmission segment is particularly effective in increasing
931 system reliability under the various multiple contingency categories of the TPL-001-4
932 standard.

Page 45 – Direct Testimony of Rick A. Vail

933 Q. Absent construction of Gateway South, would the Company still need to
934 demonstrate reliable operations under the various contingency categories of the
935 TPL-001-4 standard and continue to construct transmission facilities in eastern
936 Wyoming?

937 Yes. The only way PacifiCorp could stop pursuing construction of any transmission A. 938 facilities in eastern Wyoming and maintain compliance with the TPL-001-4 standard 939 is if the transmission system experienced *no* changes in loads or resources. As I 940 discussed above, however, PacifiCorp has received, processed, and executed contracts 941 associated with thousands of megawatts of requests for OATT service in eastern 942 Wyoming-service that cannot be reliably provided absent construction of the 943 Gateway South (and Gateway West Segment D.1) or their functional equivalent. Stated 944 another way, the system impact studies for those OATT service requests identified that 945 addition of any of the incremental generation projects requesting service would result 946 in system deficiencies during N-1 or N-1-1 conditions in violation of TPL-001-4 if 947 allowed to interconnect absent the Transmission Projects.

948Separate from the incremental generation dependent on the Transmission949Projects, the 2019 TPL-001-4 planning assessment identified three deficiencies on the950existing system that are mitigated by the Transmission Projects and four additional951deficiencies that are projected to happen by 2029 due to typical system changes and952normal load growth. Further TPL-001-4 issues could arise with other types of system953changes as well, such as a significant loss or addition of load. For these reasons, I do954not believe it is reasonable to assume the Company could realistically stop pursuing

Page 46 – Direct Testimony of Rick A. Vail

955		construction of any transmission facilities in eastern Wyoming and maintain
956		compliance with reliability standards.
957		BENEFITS OF GATEWAY SOUTH
958	Q.	Please describe the benefits associated with construction of the Gateway South.
959	А.	PacifiCorp's bulk transmission network is designed to reliably transport electric energy
960		from a broad array of generation resources to load centers. There are many benefits
961		associated with a robust transmission network, including:
962		• Reliable delivery of a diverse energy supply to continuously changing customer
963		demands under a wide variety of system operating conditions.
964		• Ability to meet aggregate electrical demand and customers' energy
965		requirements at all times, taking into account scheduled outages and the ability
966		to maintain reliability during unscheduled outages.
967		• Economic dispatch of resources within PacifiCorp's diverse system.
968		• Economic transfer of electric power to and from other systems as facilitated by
969		the Company's participation in the market, which reduces net power costs and
970		provides opportunities to maintain resource adequacy at a reasonable cost.
971		• Access to some of the nation's best wind and solar resources, which provides
972		opportunities to develop geographically diverse low-cost renewable assets.
973		• Protection against market disruptions where limited transmission can otherwise
974		constrain energy supply.

975 Q. Please describe in more detail how Gateway South will improve overall system 976 reliability.

977 The transmission grid can be affected in its entirety by what happens on an individual A. 978 transmission line or path. For example, the transmission system between southern and 979 northern Utah is comprised of several individual transmission lines or line segments. 980 Figure 4 is a diagram of the existing Utah transmission system. A single outage on any 981 of the individual lines or line segments due to storm, fire, or other interference can and 982 does cause significant reductions in transmission capacity and can negatively impact 983 the Company's ability to serve customers. The addition of the Gateway South provides 984 another path into Utah to reliably serve customers during such line outages, such as 985 outages of the transmission lines that form the Huntington / Sigurd cutplane, as shown 986 in Figure 4. The line outages on this cutplane significantly reduces PacifiCorp's 987 capability to bring resources from southern Utah. Line outages require the Company to 988 significantly curtail generation resources to stabilize system voltages and require less 989 efficient re-dispatch of system resources to meet network load requirements.

In the event of a line outage, the redundancy provided by Gateway South will allow the Company to continue to meet native load service obligations and continue to meet other contractual obligations to third parties. Strengthening this transmission and increasing system redundancy with Gateway South will benefit all customers by reducing the risk of outages and inefficient dispatch resulting from those outages. The addition of the Gateway South line at Clover, adds stability to that region for line outages in the area. 997In addition, Gateway South will improve the Company's ability to perform998required maintenance without significant operational impacts to the system and will999reduce impacts to customers during planned and forced system outages. Transmission1000line and substation maintenance windows are currently limited because the system is1001highly used. By relieving congestion and providing additional transmission paths,1002Gateway South will allow greater flexibility for the Company.

1003

Figure 4



1004 Q. Please describe the reliability benefits specific to Gateway South.

1005 A. Construction of Gateway South will provide a parallel transmission path for southeast1006 Wyoming generation resources to be transferred to PacifiCorp customers in Utah and

1007throughout the Company's service area. If one path is out of service, the other path will1008provide backup transmission service capability, within the limits of the remaining path.1009These parallel paths will improve system reliability by reducing the number and1010magnitude of transmission schedule reductions during line outage conditions.

1011 Q. Please describe the economic dispatch benefits of Gateway South in more detail.

1012 A. As I explained earlier in my testimony, Gateway South, together with Gateway West 1013 Segment D.1, will allow the Company to interconnect an additional 2,030 MW of 1014 generation resources in eastern Wyoming and increase the system transfer capability 1015 by approximately 875 MW from the Windstar/Dave Johnston area south to the Shirley 1016 Basin/Aeolus area, which will create approximately 1,700 MW of incremental transfer 1017 capability from eastern Wyoming (Aeolus) to the central Utah energy hub 1018 (Mona/Clover). Connecting into the Mona/Clover market hub provides the Company 1019 additional flexibility to use least-cost resources from eastern Wyoming or Utah to serve 1020 Utah customer load. The increased capacity also provides improved access to existing 1021 generation resources, and increased opportunities to move incremental energy from 1022 Wyoming to offset higher-priced generation in the PacifiCorp system or other energy 1023 imbalance market participants' systems, as noted by Mr. Link.

1024 Q. Please describe how Gateway South can provide cost savings in the form of 1025 reduced energy and capacity losses.

1026A.Reduced energy and capacity losses on the transmission system have the potential to1027provide significant cost savings over time. Generally, the addition of a new1028transmission path in parallel with existing lines, like Gateway South, will reduce the1029energy and capacity losses by reducing the impedance of the transmission system.

Page 50 – Direct Testimony of Rick A. Vail

1030 Reduced line losses mean more efficient delivery of energy and capacity at reduced1031 costs.

1032 Q. Please describe the anticipated improvements in Wyoming and Utah reliability.

1033 Gateway South will enhance the reliability of the Wyoming and Utah transmission A. 1034 system by providing increased system strength (fault duty) and improved transmission 1035 voltage performance during both steady-state and line outage conditions. This 1036 Wyoming transmission reliability enhancement is as a result of the Aeolus – Clover 1037 500-kV transmission line linking the two geographically separate areas of eastern 1038 Wyoming and central Utah. The project also enhances Wyoming transmission 1039 reliability during Aeolus - Bridger/Anticline line outage conditions as Gateway South 1040 provides an alternative path for transferring the remaining inadvertent flows. Gateway 1041 South can enhance reliability well beyond any one state's borders. Gateway South 1042 creates a potential future high voltage source and power delivery option to meet the 1043 projected oil expansion and corresponding load growth in eastern Utah (Ashley and 1044 Vernal area). The interconnected nature of the line will improve transmission reliability 1045 of both eastern Utah and central Utah due to the line linking the two geographical 1046 separate areas of eastern Wyoming and central Utah. If the line is ultimately connected 1047 to eastern Utah communities, the Gateway South project would provide another direct load center to the abundant and economic renewable resources located within 1048 1049 Wyoming.

1050 Q. Has Gateway South been recognized as providing reliability benefits to the 1051 broader Western Interconnection?

1052 Yes. Gateway South has undergone an extensive process to be formally included in Α. 1053 WECC path rating studies, which was a critical milestone for the project, and one that 1054 can only occur if a new transmission facility can, at a minimum, reliably operate at its 1055 approved rating without negatively impacting other neighboring systems. Gateway 1056 South is not only considered fully reliable under this standard, but regarded as an 1057 important transmission project that is necessary to support the long-term transmission 1058 expansion planning established in the Western Interconnection plans and in the most 1059 recent Northern Tier Transmission Group - Regional Transmission Plan.¹⁵ 1060 Additionally, through the coordination process established by the Western Planning 1061 Regions, including Northern Tier Transmission Group ("NTTG"), the California 1062 Independent System Operator, ColumbiaGrid and WestConnect, Gateway South has 1063 been included in each of the Western Planning Regions analysis efforts—providing a 1064 complete understanding of its reliability benefits to the broader Western 1065 Interconnection.

1066 Q. What is involved in the WECC path rating study process?

A. The WECC path rating studies follow a three-phase process established by the Planning
Coordination Committee ("PCC"), the predecessor to the existing Reliability
Assessment Committee ("RAC"), that uses peer review study groups, made up of the
project sponsor and other interested WECC members, to establish a path rating for a

¹⁵ Since the issuance of the Norther Tier Transmission Group ("NTTG") 2018-2019 Final Regional Transmission Plan in the fourth quarter of 2019, NTTG and ColumbiaGrid regional planning organizations merged into a single regional planning organization called NorthernGrid. NorthernGrid will address regional planning activities for the northern portion of the Western Interconnection required under FERC Order No. 1000.

1071given transmission path or set of transmission paths, which may exhibit simultaneous1072interactions with each other. Path rating studies use a transmission model of the1073Western Interconnection and will take multiple months to evaluate the performance of1074the new transmission facilities and to demonstrate that the proposed transmission1075project will have no negative impacts on previously established transmission path1076ratings. The path ratings that are established following this process represent the1077"Maximum Path Transfer Capability" of a transmission path.

1078Once projects complete the second phase of the path rating studies, they are1079granted an "Accepted" rating and placed in Phase 3 (construction phase) status. After1080the Accepted status is granted, other projects currently going through the WECC path1081rating process must recognize the project in their studies and cannot negatively impact1082the path rating for the project.

1083 Q. Please describe the WECC path rating study process for the Gateway South.

1084 Gateway South has been included in the WECC's Three Phase Rating Process and A. 1085 approved by WECC for Phase 3-Construction Phase status as part of the overall Energy 1086 Gateway project. The Aeolus South transmission path rating studies, evaluating 1087 Gateway South, have completed the Three Phase Rating Process and Gateway South 1088 was granted Phase 3 status on December 16, 2010. This WECC approval is necessary 1089 because it allows the Company to interconnect Gateway South to the wider 1090 transmission system in the area, which is part of the Western Interconnection, and to 1091 reliably operate the project at their approved ratings.

Page 53 – Direct Testimony of Rick A. Vail

1092 Q. Has Gateway South been included in Utah-specific transmission planning1093 assessments?

1094 Yes. On January 21, 2021, Energy Strategies, on behalf of the Utah Office of Economic Α. 1095 Development, released its "Utah Transmission Study: A Study of the Options and Benefits to Unlocking Utah's Resource Potential" (hereinafter, the "Utah Study").¹⁶ 1096 The Utah Study explains that, "[d]uring the 2019 Utah Legislative Session, Senate Bill 1097 1098 3 allocated funds for an analysis of the Utah electrical transmission grid" and that the 1099 "goal of the study was to identify transmission constraints to accessing Utah's resource potential and to provide options to address them."¹⁷ According to the study, "Unlocking 1100 1101 opportunities for continued investment in a broad suite of generation and storage technologies will leave Utah well positioned to compete in Western electricity markets 1102 while also providing its customers with low-cost and reliable power."¹⁸ 1103

1104 Q. How did the Utah Study account for Gateway South?

- A. For purposes of the study, Gateway South was assumed to be in service.¹⁹ Therefore,
 the results of the study rely on the transmission benefits and increased capacity
 provided by Gateway South as a baseline assumption. Even after assuming Gateway
 South was in service, the Utah Study concluded that additional transmission build-out
- 1109 is likely to be required to meet future Utah loads:
- 1110Transmission expansion along Utah's north-south backbone1111system will be required to address the grid constraints and to1112support the levels of generation and storage buildout envisioned1113in this study. This finding is based on power system modeling1114that confirms that Utah's current and planned grid is unlikely to

¹⁷ Utah Study at 1.

¹⁶ The study is available here: <u>https://energy.utah.gov/wp-content/uploads/Utah-Transmission-Study-Summary.pdf</u>

¹⁸ Utah Study at 3.

¹⁹ Utah Study at 18-19.

1115 be able to accommodate forecasted resource deployment 1116 without transmission system upgrades. While perhaps viable for specific projects, non-wires solutions were not effective at 1117 1118 providing the required magnitude of transfer capability. Therefore, new transmission is likely to be required.²⁰ 1119 1120 **ALTERNATIVE EVALUATION** 1121 0. How was the configuration and voltage level of Gateway South determined? 1122 Due to the broad scope and nature of the Energy Gateway Projects, a wide range of A. 1123 transmission configurations and voltage levels (from 345-kV up to 765-kV) were 1124 initially considered. Ultimately, the prevalence of 500-kV transmission in the Western 1125 Interconnection, size and location of future resources, level of projected transfers, and 1126 transmission loss reduction were determining factors in selecting the voltage class for 1127 Gateway South. 1128 Has there been any independent analysis performed to confirm the configuration 0. 1129 and voltage level of Gateway South? Yes. During the NTTG 2018–2019 biennial study cycle, Deseret Power, on behalf of 1130 A. 1131 itself and four other Utah stakeholders, requested an economic study be performed to 1132 evaluate up to two 345-kV transmission lines as a lower-cost alternative to the 500-kV 1133 Gateway West and Gateway South lines. 1134 Based on this request, an economic study was performed by the Planning 1135 Committee that demonstrated acceptable system performance for the proposed 345-kV 1136 lines. However, additional production cost model ("PCM") simulations indicated that 1137 the 345-kV lines would have lower overall transmission capacity than the planned 500-1138 kV transmission. This capacity limitation would result in increased flows on

²⁰ Utah Study at 59-60.

transmission exiting Wyoming and would force generation to increase in Utah in thePCM simulations, dispatching it without consideration of economics.

In addition to the economic and capacity limitations, securing permits and rights-of-way for the two proposed 345-kV lines could require an additional 12-to-15 years. The Planning Committee also noted that PacifiCorp already secured all rightsof-way and was currently building the Aeolus-to-Anticline 500-kV transmission system in Wyoming, scheduled for energization in 2020. Due to these limitations and because the proposed 345-kV option has no sponsor, the project was not considered in the NTTG Regional Transmission Plan for the 2018–2019 biennial study cycle.

Q. Subsequent to the NTTG analysis of a 345-kV alternative to the Transmission Projects, has any additional analysis been performed?

1150 Yes. As discussed by Mr. Link, when evaluating the Company's 2019 IRP, the A. 1151 Commission was concerned that that "PacifiCorp excluded from its modeling a 1152 potential alternative transmission expansion case evaluated by NTTG in its 2018-2019 1153 Regional Transmission Plan that demonstrated sufficient merit to warrant PacifiCorp's further study."²¹ The Commission reiterated this concern when approving the 2020AS 1154 1155 RFP.²² In response, PacifiCorp performed follow-up analysis that evaluated both 1156 performance and cost differences between Gateway South and the proposed 345-kV 1157 option presented as an alternative study in the NTTG plan.

²¹ PacifiCorp's 2019 Integrated Resource Plan, Docket No. 19-035-02, Order at 22 (May 13, 2020).

²² Application of Rocky Mountain Power for Approval of Solicitation Process for 2020 All Source Request for Proposals, Docket No. 20-035-05, Order Approving 2020 All Source RFP at 14-15 (July 17, 2020).

1158 Q. Was the system performance significantly different between the two1159 configurations?

1160 Yes. Technical studies demonstrated that by replacing Gateway South with 345-Α. 1161 kV/230-kV alternative transmission improvements between Aeolus - Anticline -1162 Populus, as illustrated in Figure 5 below, eastern Wyoming wind generation additions would have to be significantly reduced from 1,882 MW to 1,441 MW. For this 1163 1164 alternative transmission configuration, transfers from Wyoming - (Idaho) - Utah 1165 would be reduced from 1,700 MW to 814 MW due to Path C (Idaho to Utah) 1166 transmission path limitations. During the analysis, some Path C 2,250 MW 1167 transmission path restrictions specific to the underlying 138-kV system were ignored 1168 to achieve a higher rating of 2,414 MW from Idaho to Utah. Under the transfer level 1169 evaluated, all transmission paths would be near their path ratings and no 1170 thermal/voltage violations would be evident during facility outage conditions. The 1171 report identified additional transmission facilities that would be required to support 1172 generation additions and transfer level noted above were estimated to cost \$1.539 1173 billion to construct.



1174

PERMITTING STATUS

1175 Q. Please describe all of the permits that are required to facilitate the construction of

1176 Gateway South.

A. A list of the required Federal, State and local permits is included with the Applicationas Exhibit 1.

1179 Q. Has the Company received all the required permits?

- 1180 A. The Company has received many of the required permits and will obtain all permits
- ahead of construction. Many of the construction related permits will be obtained by the
- 1182 construction contractor. The status of each permit is included in Exhibit 1.

1183 **RECOMMENDATION AND CONCLUSION**

1184 Q. Please summarize your recommendation to the Commission.

- 1185 A. I recommend that the Commission approve the Company's Application. Gateway
- 1186 South will provide substantial benefits to its customers and is necessary and in the
- 1187 public interest. Based on this conclusion, I recommend that the Commission grant the
- 1188 Company a CPCN for Gateway South by June 1, 2022.
- 1189 **Q.** Does this conclude your direct testimony?
- 1190 A. Yes.

Rocky Mountain Power Exhibit RMP___(RAV-1) Docket No. 21-035-54 Witness: Richard A. Vail

BEFORE THE PUBLIC SERVICE COMMISSION OF THE STATE OF UTAH

ROCKY MOUNTAIN POWER

Exhibit Accompanying Direct Testimony of Richard A. Vail

One-Line Diagrams

October 2021



























Rocky Mountain Power Docket No. 21-035-54 Witness: Rick T. Link

BEFORE THE PUBLIC SERVICE COMMISSION OF THE STATE OF UTAH

ROCKY MOUNTAIN POWER

Direct Testimony of Rick T. Link

October 2021

1

Q. Please state your name, business address, and position with PacifiCorp.

A. My name is Rick T. Link. My business address is 825 NE Multnomah Street, Suite 600,
Portland, Oregon 97232. My position is Senior Vice President, Resource Planning,
Procurement and Optimization. I am testifying on behalf of PacifiCorp d/b/a Rocky
Mountain Power (the "Company").

6 Q. Please describe the responsibilities of your current position.

A. I am responsible for PacifiCorp's energy supply management and resource planning
and procurement functions, which includes the integrated resource plan ("IRP"),
structured commercial business and valuation activities, and long-term load forecasts.
Most relevant to this docket, I am responsible for the economic analysis used to screen
system resource investments and for conducting competitive request for proposal
("RFP") processes consistent with applicable state procurement rules and guidelines.

13 Q. Please describe your professional experience and education.

14 A. I joined PacifiCorp in December 2003 and assumed the responsibilities of my current 15 position in September 2021. Over this time period, I held several analytical and 16 leadership positions responsible for developing long-term commodity price forecasts, 17 pricing structured commercial contract opportunities and developing financial models 18 to evaluate resource investment opportunities, negotiating commercial contract terms, 19 and overseeing development of PacifiCorp's resource plans. I was responsible for 20 delivering PacifiCorp's 2013, 2015, 2017, 2019 and 2021 IRPs; have been directly 21 involved in several resource RFP processes; and performed economic analysis 22 supporting a range of resource investment opportunities. Before joining PacifiCorp, 23 I was an energy and environmental economics consultant with ICF Consulting (now

Page 1 – Direct Testimony of Rick T. Link

ICF International) from 1999 to 2003, where I performed electric-sector financial modeling of environmental policies and resource investment opportunities for utility clients. I received a Bachelor of Science degree in Environmental Science from the Ohio State University in 1996 and a Masters of Environmental Management from Duke University in 1999.

29 Q. Have you testified in previous regulatory proceedings?

30 Yes. I have testified in proceedings before the Utah Public Service Commission A. 31 ("Commission"), the Wyoming Public Service Commission ("Wyoming 32 Commission"), the Idaho Public Utilities Commission, the Public Utility Commission 33 of Oregon ("Oregon Commission"), the Washington Utilities and Transportation 34 Commission, and the California Public Utilities Commission.

35

PURPOSE AND SUMMARY OF TESTIMONY

36 Q. What is the purpose of your direct testimony?

37 A. I present and explain the economic analysis that supports PacifiCorp's decision to 38 construct Energy Gateway South (Segment F), a 416-mile, 500-kilovolt ("kV") 39 overhead transmission line between the Aeolus Substation, near Medicine Bow, 40 Wyoming, to the Clover substation near Mona, Utah ("Gateway South"). I summarize 41 PacifiCorp's assessment of Gateway South in the 2021 IRP, which was conducted 42 together with an assessment of Gateway West – Windstar-Aeolus (Segment D.1) 43 ("Gateway West Segment D.1"), (collectively, the "Transmission Projects"). Gateway West Segment D.1 is a 59-mile, 230-kV transmission line from the Shirley Basin 44 45 substation in southeastern Wyoming to the Windstar substation near Glenrock, 46 Wyoming and re-construction of an existing, 57-mile, 230-kV transmission line from the Shirley Basin substation to the Dave Johnston substation near Glenrock, Wyoming
("Gateway West Segment D.1"), (collectively, the "Transmission Projects"). My
testimony also summarizes PacifiCorp's 2020 all-source request for proposal
("2020AS RFP") to solicit new resources including those enabled by the Transmission
Projects and provides economic analysis demonstrating the customer benefits
associated with construction of the Transmission Projects.

Q. Why does your testimony address the Transmission Projects, when the Company is requesting a CPCN for Gateway South?

55 A. Gateway South and Gateway West Segment D.1 were analyzed together, both in the 56 2021 IRP and in this case, because each line is required to interconnect new generating 57 resources in eastern Wyoming, as described in more detail in the direct testimony of 58 Company witness Mr. Rick A. Vail. Because the economic benefits of Gateway South 59 include the ability to interconnect new, low-cost resources, and those low-cost 60 resources require both Gateway South and Gateway West Segment D.1 to interconnect, 61 the Company appropriately included the costs of both Transmission Projects in its 62 economic analysis. The requested Certificate of Public Convenience and Necessity 63 ("CPCN"), however, applies to only Gateway South because Gateway West Segment 64 D.1 is located entirely in Wyoming.

65 Q. Please summarize your direct testimony regarding the Transmission Projects.

A. The 2021 IRP confirmed that the Transmission Projects remain a key transmission
investment that will enable the procurement of low-cost wind facilities to reliably meet
the Company's need for additional resources to serve customers and are expected to
produce significant customer benefits. Critically, as discussed in detail by Mr. Vail, the

Transmission Projects will enable PacifiCorp to meet its Federal Energy Regulatory
Commission ("FERC") Open Access Transmission Tariff ("OATT") obligations in
13 executed interconnection service and transmission service contracts, including a
transmission service agreement to provide 500 megawatts ("MW") of firm point-topoint ("PTP") transmission service that requires Gateway South.

75 When applying the most conservative assumptions for unavoidable 76 transmission costs—a new 230-kV line to meet the Company's OATT requirements 77 for the firm PTP transmission service contract—customer benefits range from \$128 to 78 \$260 million when compared to resource portfolios without the Transmission Projects 79 using medium natural gas and medium carbon dioxide ("CO2") assumptions. When 80 assuming the cost of the Transmission Projects are unavoidable to meet the Company's 81 OATT requirements for all 13 interconnection service and transmission service 82 contracts, customer benefits range from \$610 million to \$742 million under medium 83 natural gas and medium CO₂ price inputs. The Transmission Projects are scheduled to 84 be in operation by the end of 2024, which ensures that potential new wind resources 85 selected in the 2020AS RFP that are dependent upon the Transmission Projects can 86 come online in time to qualify for the 60 percent federal production tax credit ("PTC").

PacifiCorp has identified the final shortlist of bids selected in the 2020AS RFP. Those shortlist bids include over 1,600 MW of new wind resources that require the Transmission Projects to interconnect to PacifiCorp's transmission system. PacifiCorp has analyzed the economic benefits of the Transmission Projects together with the wind resources that are enabled by the Transmission Projects using the modeling and assumptions from the 2021 IRP, which was completed and filed on September 1, 2021.

Page 4 – Direct Testimony of Rick T. Link

93

94

PacifiCorp requests that the Commission grant a CPCN no later than June 1, 2022, so that construction can begin no later than June 2, 2022.

95 Q. Please summarize your economic analysis of the Transmission Projects.

96 PacifiCorp's economic analysis demonstrates that the Transmission Projects are A. 97 necessary and will serve the public interest. As explained by Mr. Vail, PacifiCorp's 98 transmission system in eastern Wyoming must be upgraded to meet multiple 99 interconnection service and transmission service agreements. The Transmission 100 Projects address this need, while producing significant customer benefits by enabling 101 new wind resources capable of producing PTCs for 10 years. By qualifying for these 102 federal tax credits, the cost of these new wind resources, which already have no fuel 103 costs or emissions, are greatly reduced relative to other resource options that would 104 otherwise be needed to meet the Company's projected transmission and generation 105 resource needs. These wind resources will also generate renewable-energy credits ("RECs"), which can be sold in the market to create additional revenues that would 106 107 offset costs.

108 PacifiCorp's economic analysis here uses consistent modeling inputs as those 109 used in the 2021 IRP, including the expected net costs associated with the bids selected 110 in the 2020AS RFP that require the Transmission Projects. The analysis reviewed the 111 change in revenue requirement due to the Transmission Projects, and associated 112 resources that are dependent upon the Transmission Projects, using the Company's IRP 113 modeling tool across five different scenarios that pair varying natural gas price 114 assumptions with varying CO₂ policy assumptions ("price-policy scenarios"). The 115 price-policy scenarios include:

Page 5 – Direct Testimony of Rick T. Link
116	• Medium natural gas prices paired with medium CO ₂ prices, which I
117	refer to as the "MM" price-policy scenario;
118	• Medium natural gas prices without a CO ₂ price, which I refer to as the
119	"MN" price-policy scenario;
120	• High natural gas prices paired with high CO ₂ prices, which I refer to as
121	the "HH" price-policy scenario;
122	• Low natural gas prices without a CO ₂ price, which I refer to as the
123	"LN" price-policy scenario; and
124	• The Social Cost of Greenhouse Gas, which I refer to as the "SCGHG"
125	price-policy scenario.
126	For each of these price-policy scenarios, PacifiCorp calculated the change in
127	system revenue requirement between cases with and without the Transmission Projects
128	and the associated wind resources through 2040, where capital revenue requirement is
129	levelized.
130	The results of my economic analysis confirm that the Transmission Projects are
131	expected to generate customer benefits. Under the MM price-policy scenario, the
132	present-value revenue requirement differential ("PVRR(d)") customer benefit when
133	using the most conservative assumptions for unavoidable transmission is \$128 million
134	and the risk-adjusted PVRR(d) benefits are \$260 million. When assuming the cost of
135	the Transmission Projects are unavoidable, the PVRR(d) under the MM price-policy
136	scenario yields a \$610 million customer benefit and a risk-adjusted benefit of
137	\$742 million. These benefits conservatively do not assign any value to the RECs that
138	will be generated by new resources made available due to the Transmission Projects.

Page 6 – Direct Testimony of Rick T. Link

139		The risk-adjusted results indicate that the Transmission Projects add significant risk
140		mitigation benefits associated with volatility in market prices, loads, hydro generation,
141		and unplanned outages.
142		I also calculated the change in annual nominal revenue requirement through
143		2040 to provide a sense of potential rate pressures relative to a case that does not include
144		the Transmission Projects.
145		2021 INTEGRATED RESOURCE PLAN
146	Q.	Does the 2021 IRP identify a need for additional resources to serve PacifiCorp's
147		customers?
148	A.	Yes. The primary focus of the 2021 IRP is to forecast the need for resources and then
149		evaluate different ways to meet that need over time. In the 2021 IRP, the assessment of
150		resource need is presented in Volume I, Chapter 6. The load-and-resource balance
151		shows that PacifiCorp has a capacity deficit in all years of the planning horizon-
152		starting at 1,071 MW in 2021 and then rising over time to over to 6,600 MW by 2040. ¹
153		In 2025, the first full year that the Transmission Projects will be online, the resource
154		need is 1,627 MW. Consistent with prior IRPs, in the 2021 IRP all resource portfolios
155		produced that were considered as candidates for the preferred portfolio contain new
156		supply-side, demand-side, and market resources necessary to fill this need.
157	Q.	How does the preferred portfolio identified in the 2021 IRP respond to the
158		identified resource need?
159	A.	The 2021 IRP preferred portfolio represents PacifiCorp's least-cost, least-risk plan to
160		reliably meet customer demand over a 20-year planning period. Using a range of cost

Page 7 – Direct Testimony of Rick T. Link

¹ See 2021 IRP, Vol. I, Table 6.12.

and risk metrics to evaluate numerous resource portfolios, PacifiCorp selected a preferred portfolio that reflects a cost-conscious plan that includes near-term investments in renewable resources that can capture tax credits before they expire or decrease and new transmission infrastructure to facilitate the interconnection and delivery of these resources. These new resources and transmission investments are lower cost than other resource and transmission alternatives and are necessary to reliably serve our customers.

168 Q. Are the Transmission Projects a part of the 2021 IRP preferred portfolio?

A. Yes. As described in Volume I, Chapter 4 of the 2021 IRP, the preferred portfolio
includes both Gateway South and Gateway West Segment D.1. In the 2021 IRP, the
Transmission Projects are assumed to be placed in service by the end of 2024,
consistent with current construction timelines discussed by Mr. Vail. The Transmission
Projects will enable the addition of new wind facilities that contribute to meeting
1,627 MW of projected resource need beginning 2025.

Q. Was the modeling used in the 2021 IRP able to endogenously select transmission resources?

177A.Yes. For the first time in the 2019 IRP, the Company configured the System Optimizer178("SO") model so that it could select certain transmission investments necessary to179enable new resource selections as part of its objective to minimize total system costs.180The Company upgraded to the more advanced Plexos model for the 2021 IRP181(discussed in more detail below), which also has the ability to endogenously view costs182and transmission capability associated with certain transmission upgrades and allows183for selection of specific transmission investments that coincide with new resource

184 additions. Endogenous transmission modeling capabilities in the Plexos model include 185 the consideration of 1) new incremental transmission options tied to resource 186 selections; 2) existing transmission rights tied to the use of post-retirement brownfield 187 sites; 3) costs associated with these transmission options; and 4) transmission options 188 that interact with multiple or complex elements of the IRP transmission topology. 189 When the 2021 IRP modeling evaluated transmission investments, it accounted for the 190 assumed cost for those investments and the value generated by those investments by 191 enabling low-cost resource options and better optimizing how resources are used to 192 serve load or lower system costs.

193 Q. Were the Transmission Projects included as an element of the least-cost portfolios 194 evaluated during the 2021 IRP portfolio-development process?

A. Yes. The Transmission Projects, and the associated 2020AS RFP bids dependent on
the Transmission Projects for interconnection, were included as a least-cost element of
all portfolios except those explicitly designed to eliminate them for the purpose of
calculating a PVRR(d).

199 Q. What new transfer capability and interconnection capacity do the Transmission 200 Projects add to PacifiCorp's system?

A. Completion of the Transmission Projects will increase the transfer capability between
the Aeolus substation in eastern Wyoming and the Clover substation located near
Mona, Utah by 1,700 MW and enable the interconnection of 2,030 MW of new
resources in eastern Wyoming.

Page 9 - Direct Testimony of Rick T. Link

205

Q. Please describe key factors supporting the inclusion of the Transmission Projects 206 in PacifiCorp's 2021 IRP preferred portfolio.

207 The Transmission Projects allow PacifiCorp to implement system improvements, A. 208 support the full capacity rating of Gateway South and West, and enable the addition of 209 incremental Wyoming renewable resources to support customer needs and deliver 210 value for customers in the most cost-effective way. As noted earlier, the Transmission 211 Projects will come online by the end of 2024, and that timing allows the Company to 212 meet its projected resource need beginning 2025 with low-cost resources that can 213 qualify for federal tax credits before they are reduced or phased out. This timing also 214 enables PacifiCorp to cost-effectively meet its obligation to provide nearly 2,500 MW 215 of interconnection and transmission service requests, including 500 MW of firm PTP 216 transmission service to a third-party customer, as described by Mr. Vail. Gateway 217 South will increase transfer capability between the Aeolus substation in eastern 218 Wyoming and the Clover substation near Mona, Utah, which will help PacifiCorp 219 better optimize its resources used to serve system load.

220 **Q**. Please describe the reliability benefits of the Transmission Projects identified in 221 the 2021 IRP.

222 Chapter 5 of the 2021 IRP addresses reliability and resiliency, including a discussion A. 223 of the Transmission Projects' contributions to a reliable and resilient system to serve 224 customers. Gateway South directly connects eastern Wyoming to central Utah while 225 enhancing reliability throughout PacifiCorp-served regions. Connecting into the 226 Mona/Clover market hub provides additional flexibility in the use of least-cost 227 resources from eastern Wyoming or Utah to serve customer load.

Moreover, by allowing additional generation resources to interconnect and serve load, the Transmission Projects will lessen PacifiCorp's reliance on volatile and potentially diminishing market transactions to serve load. Given concerns over regional resource adequacy, reducing reliance on the market better ensures a stable and reliable supply of capacity and energy going forward.

233 In addition, Gateway South improves reliability by relieving the stress on the 234 transmission system in eastern Wyoming and central Utah. For example, the 2021 IRP 235 explains that the addition of the Gateway South line in Wyoming relieves stress on the 236 underlying 230-kV transmission system while improving the reliability in that region. 237 Similarly, the addition of the Gateway South line in central Utah unloads the underlying 238 345-kV transmission system improving reliability in that region. Essentially, the 239 500-kV line brings two distant areas closer to each other in a way that improves 240 regional reliability.

241 The 2021 IRP also addresses the reliability benefits resulting from the 242 construction of Gateway West Segment D.1. In particular, the IRP explains that 243 Gateway West Segment D.1 provides a new transmission path allowing for resource 244 development in the area. The addition of this line improves the reliability of the 245 transmission system during certain identified outage conditions (Dave Johnston to Amasa 230-kV outage or Amasa - Shirley Basin 230-kV outage). Construction of 246 247 Gateway West Segment D.1 is also a prerequisite for interconnecting new resources, 248 including those selected in the 2020AS RFP, which I discuss in more detail below.

249 Mr. Vail's testimony addresses transmission system reliability and 250 interconnection issues in greater detail.

Page 11 – Direct Testimony of Rick T. Link

251	Q.	Did PacifiCorp include action items for the Transmission Projects in its 2021 IRP	
252		action plan?	
253	A.	Yes. The 2021 IRP action plan, which lists the specific steps PacifiCorp will take over	
254		the next two to four years to deliver resources in the preferred portfolio, includes the	
255		following action items associated with the Transmission Projects:	
256		Gateway South:	
257 258		• By the second quarter of 2022, obtain CPCNs from this Commission and the Wyoming Commission;	
259 260		• By the end of the first quarter of 2022, obtain Bureau of Land Management notice to proceed to construct Gateway South.	
261 262		• In the third quarter of 2024, construction of Gateway South is expected to be completed and placed in service.	
263		Gateway West Segment D.1:	
264 265		• By the second quarter 2022, obtain CPCN from the Wyoming Commission;	
266 267		• By the third quarter of 2022 complete rights-of-way easement acquisition;	
268 269		• In the third quarter of 2024, construction of Gateway West Segment D.1 to be completed and placed in service.	
270	Q.	Was Gateway South also included in the preferred portfolio selected in the 2019	
271		IRP?	
272	A.	Yes. Like the 2021 IRP, the 2019 IRP preferred portfolio also included Gateway South.	
273	Q.	Did the Commission acknowledge the 2019 IRP?	
274	A.	The Commission acknowledged the 2019 IRP generally, but declined to specifically	
275		acknowledge the Action Plan, which included construction of Gateway South. ² The	

² PacifiCorp's 2019 Integrated Resource Plan, Docket No. 19-035-02, Order (May 13, 2020) (hereinafter "2019 IRP Order").

Commission made clear, however, that, "Declining to acknowledge or approve the Action Plan does not constitute denial of any specific resource."³ Instead, whether the Commission's order "has any impact on resource approval dockets or other proceedings will be evaluated in those separate dockets."⁴

- 280 Q. Did the Commission provide any specific guidance regarding the evaluation of
 281 Gateway South?
- A. Yes. First, the Commission was concerned that PacifiCorp "did not model the Preferred Portfolio without the yet-to-be-built Gateway South as a presumed component," which was "inadequate" because the 2019 IRP Action Plan called for "nearly immediate construction of the line without identifying and justifying selection of the specific resources that will rely on it and, in particular, their geographic location."⁵
- 287 Second, the Commission was concerned that PacifiCorp did not model a 288 "potential alternative transmission expansion case evaluated by [Northern Tier 289 Transmission Group ("NTTG")] in its 2018-2019 Regional Transmission Plan that 290 demonstrated sufficient merit to warrant PacifiCorp's further study."⁶

Q. Has the Company addressed the Commission's concerns in the 2021 IRP and in this filing?

A. Yes. First, the Company's economic analysis, which is the same analysis included in
the 2021 IRP, explicitly modeled the preferred portfolio with and without the
Transmission Projects and the resources that rely on Transmission Projects. Moreover,
the modeling with and without the Transmission Projects used the actual wind

- ³ *Id.* at 26.
- ⁴ Id.
- ⁵ *Id.* at 22.
- ⁶ Id. at 22.

Page 13 – Direct Testimony of Rick T. Link

resources selected in the 2020AS RFP, which addressed the Commission's concern that
the 2019 IRP did not identify the specific resources that would rely on Gateway South.
The results of this analysis demonstrated substantial customer benefits from
constructing Gateway South and interconnecting over 1,600 MW of new PTC-eligible
wind resources.

302 Second, in this filing, the Company included a specific sensitivity that modeled 303 the NTTG alternative discussed by the Commission, as discussed in more detail below. 304 The results of this analysis favored construction of Gateway South by a significant 305 margin. Mr. Vail's testimony provides additional analysis demonstrating that the 306 NTTG case is not a reasonable alternative to Gateway South.

307

2020 ALL SOURCE REQUEST FOR PROPOSALS

308 Q. Please provide an overview of the 2020AS RFP.

A. The 2020AS RFP is an all-source RFP seeking resources to meet the Company's projected resource needs that were identified in the 2019 IRP. Based on the cost-andperformance assumptions for proxy resources in the 2019 IRP, the Company expected that new wind, solar and battery energy storage systems ("BESS") were likely to be the most cost-competitive types of resources offered into the 2020AS RFP. However, bidders could offer proposals for other types of resources (*i.e.*, natural gas, pumped storage, *etc.*).

316The Commission approved the 2020AS RFP on July 2, 2020, in Docket No. 20-317035-05. The Company also received approval of the 2020AS RFP from the Oregon

Page 14 – Direct Testimony of Rick T. Link

318 Commission in Docket No. UM 2059⁷ and the 2020AS RFP was then released to 319 market.

Q. Although the 2019 IRP contemplated that the new resources would reach commercial operation by the end of 2023, did the 2020AS RFP require that resources offering bids reach commercial operation by the end of 2023?

323 A. No. When the 2019 IRP was filed, PacifiCorp assumed new wind resources would need 324 to achieve commercial operation by the end of 2023 to be eligible for a 40 percent PTC. 325 Similarly, PacifiCorp assumed that solar resources or solar collocated with BESSs 326 would need to achieve commercial operation by the end of 2023 to qualify for the 30 327 percent investment tax credit ("ITC"). After the 2019 IRP was filed, federal legislation 328 was passed that extended the PTC to allow wind projects to come online as late as 2024 329 and qualify for a 60 percent PTC. While the timing for the phased reduction of the ITC 330 has not changed since the 2019 IRP was filed, in response to the new legislation that 331 extends and increases the value of the PTC, PacifiCorp accepted bids into the 2020AS 332 RFP that can achieve commercial operation by the end of 2024.

333 Q. What was the market response to the 2020AS RFP?

A. The 2020AS RFP elicited a robust market response that produced over 28,000 MW of
 conforming bids with an additional 12,500 MW of bids that did not conform with

- 336 minimum requirements set forth in the 2020AS RFP. Bids for 24 projects totaling over
- 337 9,000 MW of resource capacity located in eastern Wyoming were submitted.

⁷ The Oregon Commission has established competitive bidding requirements for certain resource acquisitions by Oregon's investor-owned utilities. *See In the Matter of the Rulemaking Regarding Allowances for Diverse Ownership of Renewable Energy Resources*, Docket No. AR 600, Order No. 18-324, Appendix A (Aug. 30, 2018).

338

339

Q. What were the proposed commercial operation dates for the eastern Wyoming bids that rely on the Transmission Projects for interconnection?

A. The bids that rely on the Transmission Projects for interconnection all proposed 2024
commercial operation dates, which enabled PacifiCorp to defer construction of the
Transmission Projects an additional year relative to the timing assumed in the 2019
IRP.

Q. How did the Company evaluate the bids that were submitted?

345 The first step in the process was identification of the initial shortlist, which was made Α. 346 public on October 29, 2020. The initial shortlist included 5,453 MW of renewable 347 resource capacity: 2,974 MW of solar or solar with storage (1,130 MW of battery 348 storage), 2,479 MW of wind, and 200 MW of standalone BESS. PacifiCorp then 349 initiated the capacity factor evaluation process (performed by third-party expert WSP 350 Global). The initial shortlist contained a mix of various ownership structures, including 351 proposals for power-purchase agreements ("PPAs"), build-transfer agreements 352 ("BTAs"), and battery storage agreements ("BSAs").

353 Q. Please describe how PacifiCorp selected the final shortlist.

A. Consistent with the bid evaluation and selection process outlined in the 2020AS RFP, the final shortlist selection process was implemented in two basic phases using the IRP modeling tools: the portfolio-development phase and the scenario-risk phase. At the time it conducted this analysis, the Company was still relying on the SO model and Planning and Risk ("PaR") used in the 2019 and previous RFPs and IRPs.

Page 16 – Direct Testimony of Rick T. Link

359

Q. Please describe the analysis conducted in the portfolio-development phase.

360 A. The portfolio-development phase identified the least-cost combination of bids using a
 361 methodology consistent with the approach used to produce resource portfolios in
 362 PacifiCorp's 2019 IRP.

363 First, the best-and-final pricing for each bid was processed and incorporated364 into the SO model and PaR as modeling inputs.

365 Second, the SO model was used to develop bid portfolios, reflecting corrected 366 model inputs, containing the least-cost combination of bids over a 20-year planning 367 horizon (2019 through 2038). The SO model optimized its resource portfolio selections 368 from all the bids included in the initial shortlist, as well as from all other proxy-resource 369 alternatives used to develop resource portfolios in PacifiCorp's 2019 IRP (e.g., front-370 office transactions or "FOTs," RFP demand-side management resources, etc.). 371 PacifiCorp did not force the SO model to select any bid or any combination of bids. 372 PacifiCorp initially developed bid portfolios for three price-policy scenarios, which 373 reflect different pairings among three natural-gas price forecasts and three CO₂ price 374 forecasts (i.e., an LN, MM, and HH bid portfolio). Three additional resource portfolios, 375 one for each price-policy scenario, that did not allow any bid selections were used to 376 calculate a PVRR(d) between two system simulations—one that included the 2020AS 377 RFP bids and the Transmission Projects, and one without.

378 **Q.** Please describe the scenario-risk phase.

A. The scenario-risk phase of the bid-evaluation process was implemented by evaluating
the different resource portfolios (those produced when LN, MM, and HH price-policy
assumptions were applied) under each of the three price-policy scenarios. This step

382 provides insight as to how each of the three bid portfolios perform under a range of 383 conditions. The Company also performed sensitivities to test bid selections and system 384 costs under alternative market price assumptions, market sale assumptions, and federal 385 tax incentive assumptions.

386 Q. Did the Company also perform additional RFP modeling related specifically to 387 Gateway South?

388 Yes. During the Utah RFP-approval process, parties expressed concern that the RFP A. 389 "did not fully and effectively consider transmission scenarios that did not include the unbuilt Gateway South. . . transmission line."8 To address this concern, parties 390 391 recommended that the Company's modeling include scenarios without Gateway South. The Commission "found these concerns compelling as it did not appear the 392 393 transmission costs associated with scenarios that did not entail construction of Gateway 394 South would be accurately and fairly compared with those that assumed and relied on its construction."9 In response to these concerns, the Company agreed to the following, 395 which the Commission concluded "are reasonable and adequately address the issues": 396 397 1) Inasmuch as the final shortlist evaluation includes bids dependent upon Gateway 398 South, the Company will perform, at minimum, a sensitivity that removes 399 Gateway South and all bids that require Gateway South; and 400 2) Inasmuch as the final shortlist evaluation includes bids dependent upon Gateway 401 South, the Company will perform a sensitivity that replaces Gateway South with 402 an alternative transmission build-out scenario that is reasonably aligned with 403 options identified in the NTTG's 2018-2019 Regional Transmission Plan.¹⁰

⁸ Application of Rocky Mountain Power for Approval of Solicitation Process for 2020 All Source Request for Proposals, Docket No. 20-035-05, Order Approving 2020 All Source RFP at 14 (July 17, 2020).

⁹ Order Approving 2020 All Source RFP at 14.

¹⁰ Order Approving 2020 All Source RFP at 15.

404 Q. Did the Company provide modeling required by the Commission when approving 405 the 2020AS RFP?

- 406 A. Yes. As discussed above, the Company performed the with and without Gateway South
 407 study as part of the portfolio-development phase of the 2020AS RFP. The Company
 408 also performed that same analysis in this case (discussed below). The Company also
 409 modeled the NTTG alternative (discussed below).
- 410 Q. What resources were identified for inclusion on the final shortlist based on the bid
 411 evaluation and selection process outlined above?
- A. After evaluating a range of potential bid portfolios, and after accounting for bid updates
 resulting from interconnection study results, the Company selected the final shortlist,
- 414 which includes:¹¹
- 415 1,792 MW of new wind capacity
- 416 590 MW as BTAs
- 417 1,202 MW as PPAs
- 418 1,302 MW of solar capacity as PPAs
- 419 697 MW of BESS

421

- 420 497 MW of BESS capacity is paired with solar bids
 - 200 MW is standalone BESS capacity as a BSA

¹¹ The final shortlist originally included an additional solar bid collocated with BESS. Shortly after the bidder was notified its project was on the final shortlist, it withdrew the bid from the 2020AS RFP. As summarized, this bid is not included in the total capacity shown.

422 Q. Which resources selected to the final shortlist are dependent on the Transmission

- 423 **Projects for interconnection?**
- A. Six final shortlist bids, representing over 1,600 MW of wind generation, require the
 Transmission Projects to interconnect to PacifiCorp's transmission system. Table 1
 summarizes the wind bids that require the Transmission Projects to achieve
 interconnection.
- 428 429
- 430

Table 1.2020AS RFP Wind Bids that Requirethe Transmission Projects to Achieve Interconnection

Project	Bidder	Structure	Capacity (MW)
Cedar Springs IV	NextEra	PPA	350
Boswell Springs	Innergex	PPA	320
Two Rivers	BlueEarth Renewables LLC and Clearway Renew LLC	PPA	280
Anticline	NextEra	PPA	101
Rock Creek I	Invenergy	BTA	190
Rock Creek II	Invenergy	BTA	400

431 Q. Did PacifiCorp conduct the 2020AS RFP under the oversight of independent 432 evaluators?

A. Yes. PacifiCorp conducted the solicitation process in accordance with the approvals
received from the Commission and the Oregon Commission and with the
comprehensive oversight of two independent evaluators—one retained by the
Commission (Merrimack Energy Group) and one retained by PacifiCorp and appointed
by the Oregon Commission (PA Consulting Group, Inc.).

438 Q. What were the independent evaluators' conclusions regarding the 2020AS RFP?

439 A. Both independent evaluators concluded that the process was fair and transparent and

the bids selected to the final shortlist were reasonable.

Page 20 – Direct Testimony of Rick T. Link

441	Q.	Please describe the Utah independent evaluator's conclusions regarding the
442		2020AS RFP.
443	A.	In its Shortlist Report, ¹² the Utah independent evaluator concluded that the RFP was
444		fair, reasonable, and in the public interest. In particular, the Utah independent evaluator
445		concluded:
446 447 448 449		• The market response to the RFP was robust and, "Based on the unbelievable response from the market it is safe to say that the solicitation process resulted in a very competitive process with many more proposals generally submitted than the expected requirements by bubble identified by PacifiCorp." ¹³
450 451		• PacifiCorp engaged the bidders throughout the process in a timely manner to ensure that all bidders were treated fairly.
452 453		• All bidders were treated the same, had access to the same information at the same time, and had an equal opportunity to compete.
454 455 456 457		• PacifiCorp implemented its evaluation and selection process consistent with its proposed evaluation and selection process as outlined in the RFP in a structured and consistent manner designed to result in the selection of a portfolio of projects that would result in a least cost solution.
458 459 460		• PacifiCorp subjected all bidders to the same information requirements and conducted a consistent evaluation process with all proposals treated equally in terms of the evaluation methodology and information required of each bidder.
461 462 463		• The selection process was unbiased with respect to ownership structures, i.e., the process did not unreasonably favor bids that resulted in a utility-owned resource.
464	Q.	Please describe the Oregon independent evaluator's conclusions regarding the
465		2020AS RFP.
466	A.	In its Closing Report, ¹⁴ the Oregon independent evaluator concluded that the final
467		shortlist reflected a diverse portfolio of competitive resources that achieves the resource

 ¹² The Shortlist Report (hereinafter, the "Utah IE Shortlist Report") was filed with the Commission in Docket No. 20-35-05 on September 2, 2021, and is available here: <u>https://psc.utah.gov/2020/01/24/docket-no-20-035-05/</u>.
 ¹³ Utah IE Shortlist Report at 74.
 ¹⁴ The Closing Report was filed by PacifiCorp in Oregon Commission docket UM 2059 on June 15, 2021, and is available here: <u>https://apps.puc.state.or.us/edockets/DocketNoLayout.asp?DocketID=22320</u>.

468		adequacy and least cost goals set forth in PacifiCorp's IRP, based on the following	
469		conclusions:	
470 471		• PacifiCorp's procurement process, scoring methodology and results were fair and free of bias across all bids and bidders.	
472 473 474		• PacifiCorp applied the rules of the 2020AS RFP in an unbiased manner, communicated transparently with the independent evaluators regarding their modelling processes and with stakeholders regarding their decisions.	
475 476		• PacifiCorp's bid price scores were on average consistent with the independent evaluator's independent scoring methodology.	
477 478		• PacifiCorp's utilization of an outside consultant, WSP Global, to evaluate wind, solar, and battery storage benefitted stakeholders.	
479		• The final shortlist was reasonably aligned with the 2019 IRP preferred portfolio.	
480		MODELING ASSUMPTIONS	
481	Q.	Were the assumptions used in your economic analysis in this filing consistent with	
482		the assumptions used to develop the 2021 IRP?	
483	A.	Yes. The assumptions used in the economic analysis discussed below are the same	
484		assumptions that were used to develop the 2021 IRP.	
485	Q.	Please summarize the natural gas and CO ₂ price assumptions used in the	
486		economic analysis.	
487	A.	The economic analysis of the Transmission Projects includes five price-policy	
488		scenarios-the MM, MN, HH, LN, and SCGHG price-policy scenarios. These	
489		assumptions can influence the value of system energy, the dispatch of system resources,	
490		and PacifiCorp's resource mix. Consequently, wholesale-power prices and CO2 policy	
491		assumptions affect net-power costs ("NPC") benefits, non-NPC variable-cost benefits,	
492		and system fixed-cost benefits associated with the Transmission Projects. Because	
493		wholesale power prices and CO ₂ policy outcomes are both uncertain and important	

Page 22 – Direct Testimony of Rick T. Link

drivers to the economic analysis, it is important to evaluate a range of assumptions for
these variables. Table 2 summarizes the price-policy scenarios used to analyze the
Transmission Projects.

497

Table 2. Price-Policy Scenario Assumption Overview

Price-Policy Scenario	Henry Hub Natural Gas Price (Levelized \$/MMBtu)	CO ₂ Price Description	
MM	\$4.44	\$9.93/ton starting 2025 rising to \$57.94/ton in 2040	
MN	\$4.44	None	
НН	\$5.64	\$22.57/ton starting 2025 rising to \$102.48/ton in 2040	
LN	\$2.94	None	
SCGHG	\$4.44	\$74.10/ton starting 2021 rising to \$150.38/ton in 2040	
*Nominal levelized Henry Hub natural gas price from 2025 through 2040.			

498 Q. Please describe the natural-gas price assumptions used in the price-policy 499 scenarios.

500 The medium natural gas price assumptions are from PacifiCorp's official forward price A. 501 curve ("OFPC") dated March 31, 2021, which was the most current OFPC available 502 when PacifiCorp prepared its modeling inputs for the 2021 IRP. The first 36 months of 503 the OFPC reflect market forwards at the close of a given trading day (March 31, 2021, 504 in this case). As such, these 36 months are market forwards as of March 2021. The 505 blending period (months 37 through 48) is calculated by averaging the month-on-month 506 market forwards from the prior year with the month-on-month fundamentals-based 507 price from the subsequent year. The fundamentals portion of the natural gas OFPC 508 reflects an expert third-party, multi-client "off-the-shelf" price forecast. The 509 fundamentals portion of the electricity OFPC reflects prices as forecast by

Page 23 – Direct Testimony of Rick T. Link

510 AURORAXMP4 ("Aurora"), a WECC-wide market model. Aurora uses the expert 511 third-party natural gas price forecast to produce a consistent electricity price forecast 512 for market hubs in which PacifiCorp participates. Figure 1 shows Henry Hub natural-513 gas price assumptions for the medium, high, and low natural gas price scenarios.

514

515

516

Figure 1. Natural Gas Price Assumptions



517

518 Q. Please describe the CO₂ price assumptions used in the price-policy scenarios.

519 PacifiCorp used four different CO₂ price scenarios in the 2021 IRP-zero, medium, A. 520 high, and a price forecast that aligns with the social cost of greenhouse gases. The 521 medium and high scenario are derived from expert third-party, multi-client "off-the-522 shelf" subscription services. Both scenarios apply a CO₂ price as a tax beginning 2025. 523 PacifiCorp also incorporated the social cost of greenhouse gas, which is assumed to 524 start in 2021. The social cost of greenhouse gases is applied such that the price for the 525 social cost of greenhouse gas is reflected in market prices and dispatch costs for the 526 purposes of developing each portfolio (i.e., incorporated into capacity expansion 527 optimization modeling). Figure 2 shows the three non-zero CO₂ price assumptions used 528 to analyze the Transmission Projects.



530 Q. How did PacifiCorp pair the natural gas and CO₂ price assumptions for purposes 531 of its analysis of the Transmission Projects?

532 Scenarios pairing medium gas prices with alternative CO₂ price assumptions reflect A. OFPC forwards through April 2024 before transitioning to a fundamentals forecast. 533 534 Scenarios using high or low gas prices, regardless of CO₂ price assumptions, do not 535 incorporate any market forwards because these scenarios are designed to reflect an 536 alternative view to that of the market. As such, the low and high natural gas price 537 scenarios are purely fundamental forecasts. Low and high natural gas price scenarios 538 are also derived from expert third-party, multi-client "off-the-shelf" subscription services. 539

540

MODELING METHODOLOGY

- 541 Q. Please describe the modeling methodology that PacifiCorp used in its analysis of
 542 the Transmission Projects.
- 543 PacifiCorp calculated a system PVRR by identifying least-cost resource portfolios and A. 544 dispatching system resources through 2040, which aligns with the 20-year forecast 545 period used in the 2021 IRP. Net customer benefits are calculated as the PVRR(d) 546 between two simulations of PacifiCorp's system. One simulation includes the 547 Transmission Projects, and the other simulation excludes them. In addition, because 548 wind bids selected to the 2020AS RFP final shortlist that are located in eastern 549 Wyoming cannot interconnect without the Transmission Projects, these wind resources 550 are also eliminated from the simulation without the Transmission Projects. When the 551 two simulations are compared, changes to system costs are attributable to the 552 Transmission Projects. The simulation with the Transmission Projects can add wind 553 bids located in eastern Wyoming that are on the 2020AS RFP final shortlist. Beyond 554 2024, proxy resource options from the 2021 IRP are available to meet system needs.

555 Customers are expected to realize benefits when the system PVRR from the 556 simulation with the Transmission Projects is lower than the system PVRR without the 557 Transmission Projects. Conversely, customers would experience increased costs if the 558 system PVRR with the Transmission Projects were higher than the system PVRR 559 without the Transmission Projects. 560 Q. Are there any other costs that differ between the simulations with and without the
561 Transmission Projects?

562 Yes. The simulation that excludes the Transmission Projects includes the cost of A. 563 transmission upgrades necessary to accommodate PacifiCorp's obligation to provide 564 500 MW of firm PTP transmission service to a third-party customer. As explained in 565 more detail by Mr. Vail, these transmission upgrade costs were included because, even 566 conservatively ignoring all the executed interconnection service and transmission 567 service contracts listing the Transmission Projects as prerequisites and focusing solely 568 on the upgrades required to provide service under one transmission service contract, 569 PacifiCorp assumed it would need to construct a 230-kV line by the end of 2024 at an 570 estimated cost of approximately \$1.4 billion.

571 Further, this \$1.4 billion cost is the minimum cost for the alternative 572 considering that it includes only the upgrades required to provide service under a single 573 transmission service contract. Additional costs would be incurred to provide service 574 under all interconnection service contracts listing the Transmission Projects as 575 prerequisites. To provide service under all these contracts, it is likely the alternative 576 would be to construct the Transmission Projects, which means that construction of 577 these transmission investments are unavoidable given PacifiCorp's federal open access 578 transmission tariff obligations to grant interconnection and transmission service 579 requests.

Page 27 – Direct Testimony of Rick T. Link

580 Q. Has PacifiCorp upgraded the modeling tools used to evaluate the Transmission 581 Projects?

- A. Yes. While the methodology has remained the same, as noted above, in the 2021 IRP
 PacifiCorp used the more advanced Plexos modeling system, rather than the SO model
 and PaR that were used in prior IRPs.
- 585 Q. Please describe the Plexos model.

A. The Plexos modeling system provides three platforms of the Plexos tool (referred to as Long-term ("LT"), Medium-term ("MT") and Short-term ("ST")), which work on an integrated basis to inform the optimal combination of resources by type, timing, size, and location over PacifiCorp's 20-year planning horizon. The Plexos tool also allows for improved endogenous modeling of resource options simultaneously, greatly reducing the volume of individual portfolios needed to evaluate impacts of varying resource decisions.

593 Q. Please describe how PacifiCorp used the LT model.

A. PacifiCorp used the LT model to produce unique resource portfolios across a range of different planning cases. Informed by the public-input process, PacifiCorp identified case assumptions that were used to produce optimized resource portfolios, each one unique regarding the type, timing, location, and amount of new resources that could be pursued to serve customers over the next 20 years. Portfolios from the LT model are informed by an hourly review of reliability based on ST model simulations (described below). This ensures that each portfolio meets minimum reliability criteria in all hours.

Page 28 – Direct Testimony of Rick T. Link

601 Q. Please describe how PacifiCorp used the MT model.

A. PacifiCorp used the MT model to perform stochastic risk analysis of the portfolios.
Each portfolio was evaluated for cost and risk among five price-policy scenarios (MM,
MN, HH, LN, and SCGHG). A primary function of the MT model is to calculate an
optimized risk-adjustment, representing the relative risk of a portfolio under
unfavorable stochastic conditions for that portfolio.

607 Q. Please describe how PacifiCorp used the ST model.

A. PacifiCorp used to ST model to evaluate each portfolio to establish system costs over
the entire 20-year planning period. The ST model accounts for resource availability and
system requirements at an hourly level, producing reliability and resource value
outcomes as well as a PVRR, which serves as the basis for selecting least-cost, leastrisk portfolios. As noted above, ST model simulations were also used to identify the
potential need for resources in the portfolio to maintain system reliability.

614 Q. How did each of the three Plexos models work together to inform the economic 615 analysis presented here?

616 In the first step, resource portfolios (with and without the Transmission Projects and A. 617 associated wind resources) were developed using the LT model. The LT model operates 618 by minimizing operating costs for existing and prospective new resources, subject to 619 system load balance, reliability, and other constraints. Over the 20-year planning 620 horizon, the model optimizes resource additions subject to resource costs and load constraints. These constraints include seasonal loads, operating reserves and regulation 621 622 reserves plus a minimum capacity reserve margin for each load area represented in the 623 model.

624 To accomplish these optimization objectives, the LT model performs a least-625 cost dispatch for existing and potential planned generation, while considering cost and 626 performance of existing contracts and new demand-side management ("DSM") 627 alternatives within PacifiCorp's transmission system. Resource dispatch is based on 628 representative data blocks for each of the 12 months of every year. Dispatch also 629 determines optimal electricity flows between zones and includes spot market 630 transactions for system balancing. The model minimizes the system PVRR, which 631 includes the net present value cost of existing contracts, market purchase costs, market 632 sale revenues, generation costs (fuel, fixed and variable operation and maintenance, 633 decommissioning, emissions, unserved energy, and unmet capacity), costs of DSM 634 resources, amortized capital costs for existing coal resources and potential new 635 resources, and costs for potential transmission upgrades.

Each portfolio developed by the LT model must have sufficient capacity to be reliable over the IRP's 20-year planning horizon. The resource portfolios reflect a combination of planning assumptions such as resource retirements, CO₂ prices, wholesale power and natural gas prices, load growth net of assumed private generation penetration levels, cost and performance attributes of potential transmission upgrades, and new and existing resource cost and performance data, including assumptions for new supply-side resources and incremental DSM resources.

643 Q. What is the next step in the modeling process?

A. In the second step, the Company conducted a reliability assessment using the ST model.
The ST model begins with a portfolio from the LT model that has not yet benefited
from a reliability assessment conducted at an hourly level. The ST model is first run at

an hourly level for 20 years in order to retrieve two critical pieces of data: 1) shortfalls
by hour; and 2) the value of every potential resource to the system. This information is
then used to determine the most cost-effective resource additions needed to meet
reliability shortfalls, leading to a reliability-modified portfolio. The ST model is then
run again with the modified portfolio to calculate an initial PVRR, which is riskadjusted by outcomes of MT model stochastics that occurs in the third step of the
process.

654 Q. Please describe how the MT model is used to conduct cost and risk analysis.

655 Α. In the third step, the resource portfolios developed by the LT model and adjusted for 656 reliability by the ST model are simulated in the MT model to produce metrics that 657 support comparative cost and risk analysis among the different resource portfolio 658 alternatives. The stochastic simulation in the MT model produces a dispatch solution 659 that accounts for chronological commitment and dispatch constraints. The MT 660 simulation incorporates stochastic risk in its production cost estimates by using the 661 Monte Carlo sampling of stochastic variables, which include load, wholesale electricity 662 and natural gas prices, hydro generation, and thermal unit outages. The MT results are 663 used to calculate a risk adjustment which is combined with ST model system costs to 664 achieve a final risk-adjusted PVRR.

665 Q. Is the Plexos model appropriate for analyzing the customer benefits of the 666 Transmission Projects?

A. Yes. The Plexos model is the appropriate modeling tool when evaluating significant
capital investments that influence PacifiCorp's resource mix and affect least-cost
dispatch of system resources. Like the prior SO model, the LT model simultaneously

Page 31 - Direct Testimony of Rick T. Link

670 and endogenously evaluates capacity and energy trade-offs associated with resource 671 and transmission capital projects and is needed to understand how the type, timing, and 672 location of future resources might be affected by the Transmission Projects. The ST 673 and MT models, like PaR, provide additional granularity on how the Transmission 674 Projects are projected to affect system operations while assessing stochastic risks. 675 Together, the LT, MT, and ST models are best suited to perform a benefit analysis for 676 the Transmission Projects that is consistent with long-standing least-cost, least-risk 677 planning principles applied in PacifiCorp's IRP and resource procurement activities.

678 Q. When developing resource portfolios with the Plexos model, did you perform a 679 reliability assessment?

A. Yes. As described above, the ST model was used to establish system costs for each
portfolio over the entire 20-year planning period. The ST model accounts for resource
availability and system requirements at an hourly level, producing reliability and
resource value outcomes that will reveal whether an initially reliable portfolio selected
by the LT model leaves shortfalls at an hourly level, which can then be addressed.

685 Q. What portfolios did you analyze using the Plexos model in this case?

A. While the description provided above describes generally how the 2021 IRP portfolios
were developed, analyzed, and selected, for purposes of this case the two portfolios
analyzed are portfolios with and without the Transmission Projects and, as noted above,
the without case also removes the wind resources selected in the 2020AS RFP that
require the Transmission Projects.

Page 32 – Direct Testimony of Rick T. Link

691 Q. Did PacifiCorp analyze how other assumptions affect its economic analysis of the 692 Transmission Projects?

- A. Yes. PacifiCorp analyzed the Transmission Projects under five price-policy scenarios.
 The economic analysis also includes sensitivities that quantify how changes in new
 resource capital costs for the two BTA wind projects and capital cost assumptions for
- the Transmission Projects influence projected customer benefits.
- 697 Q. Mr. Vail's testimony indicates that the Transmission Projects will enable up to
 698 2,030 MW of new resources to interconnect in eastern Wyoming. Why does your
- 699 analysis only account for 1,640 MW?
- A. As discussed earlier in my testimony, the economic analysis reasonably accounted for
 only those wind resources that were selected to the 2020AS RFP final shortlist.
- 702 Q. Please summarize the key cost-and-performance assumptions for the
 703 Transmission Projects and the new wind resources dependent upon the
 704 transmission projects that are included in your economic analysis.
- A. Cost-and-performance assumptions for the Transmission Projects and the 1,640 MW
 of new wind resources are summarized in Confidential Exhibit RMP (RTL-1).
- 707 Q. Does PacifiCorp assume that all the up-front capital costs of the Transmission
 708 Projects will be paid by its retail customers?
- A. No. The cost of the Transmission Projects is net of revenue credit from other
 transmission customers. PacifiCorp assumed retail customers would pay 80 percent of
 the revenue requirement from the up-front capital cost for the Transmission Projects
 after accounting for an assumed 20 percent revenue credit from other transmission
 customers.

714

PRICE-POLICY SCENARIO RESULTS

715 Q. Please summarize the PVRR(d) results calculated from the Plexos model.

A. Table 3 summarizes the PVRR(d) results for each price-policy scenario. The data that
was used to calculate the PVRR(d) results shown in the table are provided as
Exhibit RMP (RTL-2).

719

Table 3. PVRR(d) (Benefit)/Cost of the Transmission Projects (\$ million)

Price-Policy Scenario	PVRR(d)	Risk-Adjusted PVRR(d)
MM	(\$128)	(\$260)
LN	\$755	\$670
MN	\$393	\$289
HH	(\$932)	(\$1,100)
SCGHG	(\$2,568)	(\$2,819)

720 As shown above, system costs increase when the Transmission Projects are 721 removed from the portfolio in the MM, HH, and SCGHG price-policy scenarios. 722 Conversely, costs decrease in the LN and MN price-policy scenarios. Without the 723 Transmission Projects, emissions from PacifiCorp's generation resources increase 724 considerably-ranging from 8.4 percent in the MN price-policy scenario to 725 17.8 percent in the SCGHG price-policy scenario. The LN and MN scenarios 726 unrealistically fail to account for the risk that there will be some form of policy action 727 taken to impute a cost or penalty on greenhouse gas emissions over the planning period. 728 It is also unlikely that gas prices will be suppressed for many decades to come, as 729 assumed in the LN price-policy scenario. Further, cost-and-risk results indicate that 730 there is a tremendous opportunity cost of not building the Transmission Projects should 731 policies develop that impose costs on greenhouse gas emissions. This is seen with the

disproportionate increase in costs under the HH and SCGHG price-policy scenarios
 relative to the size of cost reductions in the unlikely LN and MN price-policy scenarios.

Considering that the removal of the Transmission Projects increases system costs among the MM, HH, and SCGHG price-policy scenarios, significantly increases emissions and associated costs and risks, and significantly increases market-reliance risk (discussed further below), this analysis supports the necessity of the Transmission Projects and indicates that they are likely to result in robust customer benefits.

739 Q. Earlier in your testimony, you stated the cost for the 230-kV alternative that is 740 assumed to provide service under a single transmission service contract was a 741 conservative cost floor, and that the Transmission Projects are the likely 742 alternative to providing service under all interconnection contracts listing the 743 Transmission Projects as prerequisites. Did you calculate how the PVRR(d) 744 results presented above would change if you assumed the Transmission Projects 745 would be required to provide service under all these interconnection and 746 transmission service contracts?

A. Yes. This would increase the cost of the "alternative" to equal the cost of the
Transmission Projects, which represents a \$971 million increase in unavoidable capital
relative to what is shown in the table above. This translates into \$482 million on a
PVRR basis. Table 4 shows the PVRR(d) results with this level of unavoidable capital.
When this higher cost is applied to the results, the MN price-policy scenario now shows
there are significant customer benefits from the Transmission Projects.

Page 35 - Direct Testimony of Rick T. Link

753Table 4. PVRR(d) (Benefit)/Cost of the Transmission Projects Assuming the754Transmission Projects are Unavoidable (\$ million)

Price-Policy Scenario	PVRR(d)	Risk-Adjusted PVRR(d)
MM	(\$610)	(\$742)
LN	\$273	\$188
MN	(\$90)	(\$194)
HH	(\$1,414)	(\$1,582)
SCGHG	(\$3,050)	(\$3,301)

755 Q. Please describe the impact of removing the Transmission Projects and associated 756 wind resources from the 2021 IRP's preferred portfolio.

Figure 3 shows the cumulative (at left) and incremental (at right) portfolio changes 757 A. 758 when the Transmission Projects are eliminated under the MM price-policy scenario. A 759 positive value indicates an increase in resources and a negative value indicates a 760 decrease in resources when the Transmission Projects are eliminated. Without the 761 Transmission Projects, the 1,640 MW of wind resources selected in the 2020AS RFP 762 are removed from the portfolio in 2024 (shown as a reduction in 2025, the first full year 763 these resources would be online). An additional 289 MW of wind is eliminated in 2030. 764 In 2034, the absence of the new wind resources triggers the addition of an advanced 765 nuclear plant that displaces solar co-located with storage resources.

766

Figure 3. Changes in the Resource Portfolio without the Transmission Projects



Page 36 – Direct Testimony of Rick T. Link

767 Q. Does the removal of the Transmission Projects and associated wind resources 768 increase the Company's reliance on market purchases?

A. Yes. Figure 4 shows how market purchases change when the Transmission Projects are removed from the portfolio under the MM price-policy scenario. With fewer resources, market purchases increase by nearly 20 percent on an annual basis. This creates higher risk as the Company is forced to rely on market purchases at a time when there are increasing resource adequacy concerns throughout the western interconnect. This increased market and reliability risk is not reflected in the PVRR(d) results.



Figure 4. Changes in Market Purchases without the Transmission Projects



776 Q. How do system costs change with and without the Transmission Projects?

777 Figure 5 summarizes changes in system costs (conservatively assuming only the cost A. 778 for a 230-kV alternative is unavoidable), based on ST model results using MM price-779 policy assumptions, when the Transmission Projects are eliminated from the portfolio. 780 The graph on the left shows annual changes in cost by category and the graph on right 781 shows annual net changes in total costs (the solid black line) and the cumulative 782 PVRR(d) of changes to net system costs over time (the dashed black line). Through 783 2040, the PVRR(d) shows that the portfolio without the Transmission Projects is 784 \$128 million higher cost than the portfolio with the Transmission Projects. On a risk-

Page 37 – Direct Testimony of Rick T. Link

785adjusted basis, which factors in the risk associated with low-probability, high-cost786events through stochastic simulations, the portfolio without the Transmission Projects787is \$260 million higher cost than the portfolio with the Transmission Projects. The risk-788adjusted results indicate that the Transmission Projects add significant risk mitigation789benefits associated with volatility in market prices, loads, hydro generation, and790unplanned outages.

791 792

Figure 5. Increase/(Decrease) in System Costs when the Transmission Projects are Removed from the Portfolio



793 Q. Is there incremental customer upside to the PVRR(d) results?

794 Yes. The PVRR(d) results presented in Table 3 do not reflect the potential value of A. 795 RECs generated by the incremental energy output from the renewable projects enabled 796 by the Transmission Projects. Customer benefits for all price-policy scenarios would 797 improve by approximately \$42 million for every dollar assigned to the incremental 798 RECs that will be generated through 2040. Beyond potential REC-revenue benefits, the 799 economic analysis of the Transmission Projects does not reflect the reliability benefits 800 that these investments will provide to the transmission system, which are described by Mr. Vail. 801

802 Q. How do the risk-adjusted PVRR(d) results compare to the stochastic-mean 803 PVRR(d) results?

- A. The risk-adjusted PVRR(d) results show an increase in the benefits of the Transmission
 Projects when compared to the reported ST-model PVRR(d) results. This indicates that
 the Transmission Projects provide stochastic risk benefits by making the system less
 susceptible to low-probability combinations of load, market price, hydro generation,
 and thermal outage volatility that can increase system costs.
- 809 ANNUAL REVENUE REQUIREMENT CALCULATIONS
- Q. In addition to the modeling used to calculate present-value net benefits over a
 20-year planning period, has PacifiCorp forecasted the change in nominal revenue
 requirement due to the Transmission Projects and the associated resources
 enabled by these projects?
- 814 Yes. The system PVRR from the Plexos model was calculated from an annual stream A. 815 of forecasted revenue requirement over the period 2021 through 2040, consistent with 816 the planning period in the 2021 IRP. The annual stream of forecasted revenue 817 requirement captures nominal revenue requirement for non-capital items (*i.e.*, NPC, 818 fixed operations and maintenance, PTCs, etc.) and levelized revenue requirement for 819 capital expenditures. To estimate the annual revenue-requirement impacts of the 820 Transmission Projects and associated resources, capital costs need to be considered in 821 nominal terms (*i.e.*, not levelized).

Page 39 - Direct Testimony of Rick T. Link

822 Q. Why is the capital revenue requirement used in the calculation of the system 823 PVRR from the Plexos model levelized?

824 A. Levelization of capital revenue requirement is necessary in these models to avoid 825 potential distortions in the economic analysis of capital-intensive assets that have 826 different lives and in-service dates. Without levelization, this potential distortion is 827 driven by how capital costs are included in rate base over time. Capital revenue 828 requirement is generally highest in the first year an asset is placed in service and 829 declines over time as the asset depreciates. In the context of long-term resource 830 planning that is conducted over a finite planning horizon, this can inappropriately favor 831 less capital-intensive assets or assets with longer lives even if those assets might 832 increase system costs over their remaining life.

833 Q. How did PacifiCorp forecast the annual revenue-requirement impacts of the 834 Transmission Projects?

835 In the simulations that include the Transmission Projects and associated resources, the A. 836 annual stream of levelized revenue requirement associated with the initial capital for 837 the Transmission Projects and the associated resources, inclusive of assumed 838 interconnection network upgrades, are recalculated as nominal revenue requirement 839 through 2040, which aligns with the period for which modeled outcomes are available. 840 Similarly, the annual stream of levelized revenue requirement associated with the initial 841 capital for the transmission upgrades necessary to accommodate PacifiCorp's 842 obligation to provide 500 MW of firm PTP transmission service under an executed, 843 FERC-jurisdictional contract is recalculated as nominal revenue requirement through 844 2040. This stream of nominal costs represents revenue requirement that can be avoided

Page 40 – Direct Testimony of Rick T. Link

with the Transmission Projects. The differential in the remaining stream of annual
costs, which includes all system costs except for those associated with the Transmission
Projects, the resources associated with the Transmission Projects, inclusive of assumed
interconnection network upgrades, and the costs avoided by the Transmission Projects,
represents the net system benefit caused by the Transmission Projects.

850

ANNUAL REVENUE REQUIREMENT CALCULATION RESULTS

851 Q. Please describe the change in annual nominal revenue requirement from the 852 Transmission Projects.

853 A. Figure 6 shows the estimated change in annual nominal-revenue requirement due to the 854 Transmission Projects for the MM price-policy scenario on a total-system basis 855 (conservatively assuming that only the cost for a 230-kV alternative is unavoidable). 856 The annual revenue requirement shown in the figure reflects all costs for the 857 Transmission Projects and associated generation, including capital revenue 858 requirement (*i.e.*, depreciation, return, income taxes, and property taxes), operations 859 and maintenance expenses, the Wyoming wind-production tax, net of avoided 860 transmission costs, transmission revenue credits, and PTCs. The project costs are netted 861 against system impacts of the Transmission Projects and associated resources, 862 reflecting the change in NPC, emissions, non-NPC variable costs, and system fixed 863 costs that are affected by, but not directly associated with, the Transmission Projects.


Figure 6. Total-System Change in Annual Revenue Requirement Due to the Transmission Projects (\$ million)



866 In 2025, the first full year the Transmission Projects are in service, the total-867 system nominal revenue requirement increases by \$79 million. This figure rapidly declines and crosses over from a net increase in nominal revenue requirement to a 868 869 decrease in nominal revenue requirement in 2027. Thereafter, the net revenue 870 requirement impact as a result of the Transmission Projects trends toward increasing 871 benefits over time as the new assets depreciate. In 2035, there is a modest increase in 872 net revenue requirement following the expiration of PTC benefits for the BTA wind 873 resources associated with the Transmission Projects. With on-going depreciation of the 874 Transmission Projects and associated zero-fuel cost, zero-emission resources, annual 875 revenue requirement benefits are expected to persist and grow beyond 2040.

Page 42 – Direct Testimony of Rick T. Link

876

SENSITIVITY ANALYSIS RESULTS

- 877 Q. Have you calculated how changes in the capital cost for the wind resources
 878 associated with the Transmission Projects might affect customer benefits?
- A. Yes. Two of the six wind resources (approximately 36 percent on a capacity basis) are
 BTAs. For these two projects, a one percent increase in the initial capital costs would
 reduce PVRR benefits by \$7.2 million. In the MM price-policy scenario, capital costs
 for the two BTA wind resources would need to increase by 36 percent to eliminate
 projected customer benefits on a risk-adjusted PVRR(d) basis.

884 Q. Have you calculated how changes in the capital cost for the Transmission Projects 885 might affect customer benefits?

886 A. Yes. A one percent increase in the initial capital costs associated with the Transmission 887 Projects would reduce PVRR benefits by \$4.8 million. This estimate conservatively 888 assumes that there is no change in transmission costs that will be avoided with the 889 construction of the Transmission Projects. In the MM price-policy scenario, capital 890 costs for the Transmission Projects would need to increase by 54 percent to eliminate 891 customer benefits on a risk-adjusted basis. This demonstrates that the projected 892 customer benefits are robust to potential variations in capital costs for the Transmission 893 Projects, particularly when considering that the cost estimates used in the economic 894 analysis of the Transmission Projects reflect PacifiCorp's experience with the recent 895 construction of Gateway West Segment D.2 and the associated 230-kV network 896 upgrades reflecting current market conditions.

897 Q. Did you perform a sensitivity study that evaluated any other alternatives to the 898 Transmission Projects?

Yes. Consistent with the Commission's direction in the 2019 IRP¹⁵ and 2020AS RFP,¹⁶ 899 A. 900 the Company evaluated an alternative to Gateway South based on a transmission expansion case evaluated in the 2018-2019 biennial study cycle of the NTTG. This 901 902 alternative (the "NTTG Alternative") is described by Mr. Vail. Consistent with this 903 commitment, a sensitivity was performed, using MM price-policy scenario 904 assumptions, to evaluate the NTTG Alternative. Table 5 summarizes how the 905 assumptions for the NTTG Alternative compare to assumptions in the Company's 906 analysis of the Transmission Projects.

907

 Table 5. Assumptions in the NTTG Alternative Sensitivity

	CPCN Transmission Projects	NTTG Alternative
In-Service Date	12/31/2024	1/1/2027
In-Service Capital	\$2.07 billion	\$3.22 billion
Interconnection Capacity	2,030 MW	872 MW
Transfer Capability	1,700 MW from eastern WY to Mona UT	848 MW from eastern WY to Bridger; 562 MW from Bridger to Borah

908 Q. What are the results of the NTTG Alternative Sensitivity?

A. Table 6 shows the PVRR(d) impact of the NTTG Alternative, which excludes the
Transmission Projects and associated new resources when using MM price-policy
assumptions. In other words, the PVRR(d) results are calculated the same way that the
PVRR(d) results for the price-policy scenarios are calculated except that the NTTG
Alternative is assumed to replace the Transmission Projects. However, because the

¹⁵ 2019 IRP Order at 23.

¹⁶ Order Approving 2020 All Source RFP at 15.

914 NTTG Alternative cannot achieve an in-service date that aligns with the 13 executed 915 transmission contracts described by Mr. Vail, the transmission investment that would 916 otherwise be required for these executed contracts cannot be avoided. Considering that 917 the NTTG Alternative is higher cost, enables less new resource interconnection at a 918 later date (beyond the period where PTCs and the 30 percent ITC can be used to lower 919 resource costs), and limits the incremental transfer capability out of eastern Wyoming, 920 the NTTG Alternative does not deliver projected customer benefits. The NTTG 921 Alternative is approximately \$2 billion more costly for customers than the 922 Transmission Projects proposed by the Company.

923

924

Table 6. (Benefit)/Cost of the NTTG Alternative (\$ million)

Price-Policy Scenario	ST PVRR(d) Through 2040	ST Risk-Adjusted PVRR(d) Through 2040
MM	\$1,958	\$2,028
	CONCLUSION	

925 Q. Please summarize the conclusions of your direct testimony.

926 A. PacifiCorp's analysis shows that Gateway South is necessary and in the public interest, 927 supporting the issuance of the requested CPCN. Under the MM price-policy scenario, 928 the Transmission Projects produce significantly lower total system costs-ranging 929 from \$128 to \$260 million when using the most conservative assumptions for avoided 930 transmission and ranging from \$610 million to \$742 million when assuming the 931 Transmission Projects are unavoidable. The Transmission Projects are also lower risk 932 than alternative scenarios without the resources. Most notably, without the 933 Transmission Projects and accompanying wind resources, the Company is forced to 934 rely heavily on market purchases to serve load, which increases risk related to market 935 volatility and creates reliability concerns given the region's well established resource

Page 45 – Direct Testimony of Rick T. Link

936	adequacy concerns. By proactively constructing the Transmission Projects, the
937	Company can not only save customers money (as evidenced by the savings in the MM
938	price-policy scenario) but also reduce customer risk, which is a non-quantifiable benefit
939	that strongly favors the Transmission Projects. The updated economic analysis of the
940	Transmission Projects demonstrates that net benefits more than outweigh net project
941	costs.

- 942 Q. Does this conclude your direct testimony?
- 943 A. Yes.

REDACTED

Rocky Mountain Power Exhibit RMP___(RTL-1) Docket No. 21-035-54 Witness: Rick T. Link

BEFORE THE PUBLIC SERVICE COMMISSION OF THE STATE OF UTAH

ROCKY MOUNTAIN POWER

REDACTED

Exhibit Accompanying Direct Testimony of Rick T. Link

Cost-and-Performance Assumption for the Transmission Projects

October 2021

Wind Resources

Facility Information and Up-front Capital	(All Projects Oualify	v for 60% PTC)								
Anticline (PPA) Boswell Springs (PPA) Cedar Springs IV (PPA) Rock Creek I (BTA) Rock Creek II (BTA) Two Rivers (PPA)	Capacity (MW) 100.5 320 350.4 190 400 280	Annual Energy (GWh)	Capacity Factor	In-Service Capital (Sm) S0 S0 S0 S0	In-Service Capital (S/kW) S0 S0 S0					
Total	1,640.9	5,851	40.7%	\$968	\$590					
Run-Rate Operating Costs (Sm)		l	l	l	l	l	l	l	l	
Wind Projects	<u>2021</u> <u>\$0.0</u>	<u>2022</u> \$0.0	<u>2023</u> <u>\$0.0</u>	<u>2024</u> \$0.03	<u>2025</u> \$9.3	<u>2026</u> <u>\$9.5</u>	$\frac{2027}{89.7}$	<u>2028</u> <u>89.7</u>	<u>2029</u> \$10.3	<u>2030</u> \$10.9
Wind Projects	<u>2033</u> \$13.0	<u>2034</u> \$13.9	<u>2035</u> \$14.8	<u>2036</u> \$15.7	<u>2037</u> \$16.6	<u>2038</u> \$17.6	<u>2039</u> \$18.5	<u>2040</u> \$19.5		
Purchase Power Agreement (\$m)	l									
Wind Projects	<u>2021</u> \$0.0	<u>2022</u> \$0.0	<u>2023</u> \$0.0	<u>2024</u> \$8.3	<u>2025</u> \$98.7	<u>2026</u> \$99.3	<u>2027</u> \$99.8	<u>2028</u> \$100.8	<u>2029</u> \$101.0	<u>2030</u> \$101.6
Wind Projects	<u>2033</u> \$103.5	<u>2034</u> <u>\$104.1</u>	<u>2035</u> \$104.8	<u>2036</u> \$105.8	$\frac{2037}{\$106.1}$	<u>2038</u> \$106.8	$\frac{2039}{\$107.5}$	<u>2040</u> \$108.6		
Turnerstore										

Transfer Capability and Up-Front Capital (Sm)

	In-Service	Transfer	
	Capital (Sm)	Capacity (MW)	
Gateway South	\$2,074.0	1,700*	
Gateway West Segment D.1	\$283.2	875	
Avoided 230-kV Transmission	\$1,385.9	500	

*Modeled as 1,200 MW assuming a 500 MW point-to-point contract will consume a portion of the transfer capability.

<u>2032</u> \$103.2

 $\frac{2031}{\$102.2}$

 $\frac{2032}{\$12.2}$

<u>2031</u> \$11.6

Rocky Mountain Power Exhibit RMP___(RTL-2) Docket No. 21-035-54 Witness: Rick T. Link

BEFORE THE PUBLIC SERVICE COMMISSION OF THE STATE OF UTAH

ROCKY MOUNTAIN POWER

Exhibit Accompanying Direct Testimony of Rick T. Link

PVRR(d) of the Transmission Projects

October 2021

E	
0	
-	
Ξ	
Ξ	
A	
-	
2	
2	
e	
1	

0
$\overline{\mathbf{O}}$
-
2
=
.=
-
ē
-
.2
2
7 8
\mathbf{U}
-
=
=
3
÷.
-

(Benefit) /Cost	PVRR(d)	2021	2022
Cost of Project	\$1,837	\$0	80
New Wind Capital Cost	\$397	\$0	\$0
Wind Run-Rate Fixed Costs	\$327	\$0	\$0
PPA	\$1,332	\$0	\$0
PTC Credits	(\$748)	\$0	\$0
Wind Tax	\$14	\$0	\$0
Transmission GWS	\$1,261	\$0	\$0
Transmission D.1	\$185	\$0	\$0
Avoided Transmission - Base 230 kV	(\$843)	\$0	\$0
Transmisison Network Wind	\$41	\$0	\$0
Transmission OATT Credit	(\$129)	\$0	80
Change in NPC	(\$1,345)	(80)	\$0
Change in Emissions	(\$488)	\$0	\$0
Change in VOM & Driver Adjustments	(S40)	(80)	\$0
Change in DSM	(\$41)	\$0	(\$1)
Change in Deficiency	(\$4)	(80)	\$0
Change in System Fixed Cos-	(\$48)	(80)	(\$0)
Net (Benefit)/Cost	(\$128)	(80)	(\$1)
Risk Adjustment	(\$132)		
Net (Benefit)/Cost with Risk Adjustment	(\$260)		

\$301
\$17
\$17
\$132
\$132
\$132
\$132
\$133
\$133
\$133
\$133
\$133
\$133
\$1343
\$1423

\$298
 \$293
 \$16
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130
 \$130

\$225
 \$42
 \$56
 \$56
 \$528
 \$50
 \$51
 \$51
 \$51
 \$51
 \$51
 \$51
 \$51

2036

2035

2034

2028

2024

Medium Gas, No CO2																				
(Benefit) /Cost	PVRR(d)	2021	2022	2023	2024	2025	2026	2027	2028	2029 2	030 2	031 2(32 20	33 205	4 20	35 20:	36 203	7 2038	2039	2040
Cost of Project	\$1,811	\$ 0	\$0	\$0	\$0	\$194	\$195	\$201	\$215 5	\$217 \$	225 \$	231 \$2	34 \$2	40 \$16	7 \$2	7 \$3(1 \$29	8 \$300	\$304	\$309
New Wind Capital Cost	\$398	\$ 0	\$0	\$0	\$0	\$34	\$35	\$34	\$40	\$40 \$	42 9	45 \$2	15 \$4	7 \$5	1 \$9	3 \$9	4 \$94	. \$95	26\$	66S
Wind Run-Rate Fixed Costs	\$326	\$0	\$0	\$0	\$0	\$50	\$50	\$54	\$52	\$55 \$	56 9	57 S:	69 \$5	9 \$5	5 \$1	6 \$1	7 \$17	\$17	\$17	\$17
PPA	\$1,304	\$0	\$0	\$0	(80)	\$180	\$181	\$188	\$197	\$202 \$	208 \$	215 \$2	20 \$2:	24 \$14	9 \$1:	0 \$13	2 \$12	9 \$129	\$132	\$134
PTC Credits	(\$746)	\$0	\$0	\$0	\$0	(\$129)	(\$129)	(\$134)	(\$134) (\$139) (\$	140) (\$	143) (\$1	48) (\$1	48) (\$1 ²	·8) \$1	s(\$0	\$0	\$0	\$0
Wind Tax	\$14	\$0	\$0	\$0	\$0	\$2	\$2	\$2	\$2	\$2	22	\$2 \$	2	\$2	\$	S	\$2	\$2	\$2	\$2
Transmission GWS	\$1,261	\$0	\$0	\$0	\$0	\$138	\$138	\$138	\$138 5	5138 \$	138 \$	138 \$1	38 \$1:	88 \$13	8 \$1:	8 \$13	8 \$13	8 \$138	\$138	\$138
Transmission D.1	\$185	\$ 0	\$0	\$0	\$0	\$20	\$20	\$20	\$20	\$20 \$	20 5	20 \$2	0 \$2	0 \$2	\$2	0 \$2) \$20	\$20	\$20	\$20
Avoided Transmission - Base 230 kV	(\$843)	\$0	\$0	\$0	\$0	(\$92)	(\$92)	(\$92)	(\$92)	(392)	592) (5	(S) (S)	92) (\$9	v2) (\$9	2) (\$5	2) (\$9	2) (\$92	2) (\$92)	(\$92)	(\$92)
Transmisison Network Wind [1]	\$41	\$0	\$0	\$0	\$0	\$5	\$5	\$5	\$5	2	z	54 S	4	t \$4	\$	\$	2	2	\$4	\$4
Transmission OATT Credit	(\$129)	\$0	\$0	\$0	(80)	(\$14)	(\$14)	(\$14)	(\$14)	\$14) (3	514) (5	(\$ (\$	14) (\$	(\$1) (\$1	4) (\$]	4) (\$1	4) (\$1 ²	4) (\$14)	(\$14)	(\$14)
Change in NPC	(\$1,305)	\$1	\$ 0	(\$1)	(\$1)	(\$163)	(\$163)	(\$168)	(\$171) (\$172) (\$	202) (\$	197) (\$2	(\$1) (\$1	50) (\$15	2) (\$1	53) (\$1)	613) (\$19	0) (\$202	(\$215)	(\$251)
Change in Emissions	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	20	\$0 \$	۶ 0	. \$0	Š	8(\$0	\$0	\$0	\$0
Change in VOM & Driver Adjustments	(S49)	(80)	(80)	\$0	(80)	(\$7)	(\$8)	(\$8)	(\$4)	(\$4) (S4) (S4) (5	(4) \$3	4 (\$1	 (8) 	7) (\$1	7) (\$1'	7) (\$17	(\$17)	(\$16)
Change in DSM	(S41)	\$0	(\$1)	(\$2)	(\$3)	(\$3)	(\$3)	(\$4)	(\$5)	(\$5) (\$5) (\$5) (3	(s) (s)	5) (S:	() ()	2) (§	(\$6 (S6	(\$6)	(86)	(\$6)
Change in Deficiency	(\$4)	(80)	\$0	\$0	(\$1)	(\$3)	(80)	(\$1)	(\$1)	\$0	\$ 0)	50 S	0 (S	0) \$0	Š	(S)	() \$0	\$0	\$0	\$0
Change in System Fixed Cos	(\$20)	(\$0)	(\$0)	(80)	(80)	(80)	(80)	(80)	(\$0)	(\$0) \$	48 5	49 S-	-6 (\$ ²	0) \$3((\$~	 (\$4 	3) (\$4:	5) (\$46	(\$48)	(\$49)
Net (Benefit)/Cost	\$393	80	(\$1)	(\$2)	(\$5)	\$18	\$21	\$19	\$33	\$36 \$	62 \$	74 S'	0 \$8	0 \$2.	\$\$ \$8	0 \$6	3 \$39	\$28	\$20	(\$12)
Risk Adjustment	(\$104)																			
Net (Benefit)/Cost with Risk Adjustment	\$289																			

Vet (Benefit)/Cost with Risk Adjustment

ST Results (\$ million

High

High Gas, High CO2																					
Benefit) /Cost	PVRR(d)	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Cost of Project	\$1,808	\$0	\$0	\$0	\$0	\$193	\$194	\$199	\$214	\$217	\$225	\$231	\$234	\$240	\$167	\$298	\$301	\$298	\$300	\$304	\$309
New Wind Capital Cost	\$396	\$0	80	\$0	\$0	\$33	\$34	\$34	\$40	\$40	\$42	\$45	\$45	\$47	\$51	\$93	\$94	\$94	\$95	262	66S
Wind Run-Rate Fixed Costs	\$327	\$0	S 0	\$0	\$0	\$51	\$51	\$54	\$53	\$55	\$56	\$57	\$59	\$59	\$56	\$16	\$17	\$17	\$17	\$17	\$17
PPA	\$1,304	\$0	\$ 0	\$0	(80)	\$180	\$181	\$188	\$197	\$202	\$208	\$215	\$220	\$224	\$149	\$130	\$132	\$129	\$129	\$132	\$134
PTC Credits	(\$749)	\$0	\$0	\$0	\$0	(\$131)	(\$131)	(\$135)	(\$134)	(\$139)	(\$140)	(\$143)	(\$148)	(\$148)	(\$148)	\$0	\$0	\$ 0	\$0	\$0	\$0
Wind Tax	\$14	\$0	\$0	\$0	\$0	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2
Transmission GWS	\$1,261	S 0	S 0	\$ 0	\$0	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138

Transmission D.1	\$185	\$ 0	\$0	\$0	\$0	\$20	\$20 \$	20 \$	20 \$	20 \$2	0.	50 \$	20 \$	20 \$	20	\$20	\$20	\$20	\$20	\$20	\$20
Avoided Transmission - Base 230 kV	(\$843)	\$0	\$0	\$0	\$0	(\$92) (\$92) (5	§92) (\$	92) (S	92) (S	92) (\$	92) (\$	92) (§	92) (5	\$92) (\$92) ((\$92)	(\$92)	(\$92)	(\$92)	(\$92)
Transmisison Network Wind	\$41	\$0	\$0	\$0	\$0	\$5	\$5	\$5 \$	5 \$	2	*	4	4	2	\$4	\$5	\$4	2	2	2	\$4
Transmission OATT Credit	(\$129)	\$0	\$0	\$0	(80)	(\$14) (\$14) (5	§14) (\$	(14) (S	14) (\$	(5) (5)	14) (S	14) (\$	(14)	\$14) (\$14) ((\$14)	(\$14)	(\$14)	(\$14)	(\$14)
Change in NPC	(\$1,697)	\$ 0	\$1	\$1	(\$4) (\$185) (3	\$183) (\$	199) (S.	217) (S.	206) (\$2	32) (\$2	(15) (S)	259) (S	217) (\$	211) (5	\$237) (\$233)	(\$269)	(\$346)	(\$349) (\$339)
Change in Emissions	(\$936)	\$0	\$0	\$0	\$0	(871) (3) (623)	\$86) (\$	84) (\$	(8) (81)	60) (\$1	61) (\$	(8) (8)	125) (\$	153) (5	\$150) (\$186)	(\$188)	(\$130)	(\$170) (\$203)
Change in VOM & Driver Adjustments	(\$37)	(80)	\$0	\$0	\$0	(\$3)	(\$3) (\$3) (5	53) (5	53) (\$	2) (5	(2)	53) \$	34 (5	\$16) (\$16) ((\$16)	(\$17)	(\$17)	(\$19)	(\$18)
Change in DSM	(S41)	\$0	(\$1)	(\$2)	(\$3)	(\$3)	(\$3) (S4) (5	§5) (S	§5) (§	5) (3	()) (98	§5) (\$5)	(\$5)	(\$6)	(86)	(86)	(86)	(\$6)
Change in Deficiency	(88)	(\$3)	\$0	\$0	(\$1)	(\$3)	\$0 (\$1) (5	53) \$	90 (}	s) (0	00	52) (§0)	(05	\$0	\$0	\$0	\$ 0	\$0	\$0
Change in System Fixed Cos	(\$20)	(80)	(\$0)	(\$0)	(\$0)	(\$0)	(80) (\$0) (S	80) (3	80) \$-	8. S	49 \$	49 (\$	40) \$	30 (\$42) ((\$43)	(\$45)	(\$46)	(\$48)	(\$49)
Net (Benefit)/Cost	(\$932)	(\$3)	(\$1)	(\$1)	(88)	(\$72) (\$75) (5	8) (8	(86) (86)	106) (\$1	25) (\$1	30) (\$	154) (\$	113) (\$	3) (681	\$154) ((\$183)	(\$227)	(\$246)	(\$287) (\$306)
Risk Adjustment	(\$168)																				
Net (Benefit)/Cost with Risk Adjustment	(\$1,100)																				

Low Gas, No CO2

(Benefit) /Cost	PVRR(d)	2021	2022	2023	2024	2025	2026	2027	2028 2	2029 2	030	031	2032	2033 2	034	2035 2	2036	2037	2038 2	039 20	140
Cost of Project	\$1,838	80	8 0	80	\$0	\$194	\$195	\$200 \$	3214 S	217 S	225 9	231 9	234 5	240 S	238 \$	298 \$	301 5	\$298	\$300 \$	304 \$3	60
New Wind Capital Cost	\$397	80	80	\$0	\$0	\$34	\$34	\$34	\$40 S	\$40 \$	42	345	\$45	\$47 \$	51	593 S	594	\$94	\$95	97 \$	60
Wind Run-Rate Fixed Costs	\$326	\$ 0	\$ 0	\$0	\$0	\$51	\$51	\$54	\$53	\$55 \$	56	557	\$59	\$59 \$	56	516 5	\$17	\$17	\$17 \$	17 \$	2
PPA	\$1,332	\$ 0	\$ 0	\$0	(80)	\$180	\$181	5188 \$	s 197 \$	202 \$	208 5	215 9	220 5	\$224 \$	220 \$	130 \$	132 \$	\$129	\$129 \$	132 \$1	34
PTC Credits	(\$748)	\$0	\$0	\$0	\$0	(\$130)	(\$130) (\$134) (5	\$134) (\$	§139) (\$	140) ()	(143)	6148) (5148) (5	(148)	\$0	\$0	\$0	\$0	80	0
Wind Tax	\$14	\$0	\$0	\$0	\$0	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	82	5
Transmission GWS	\$1,261	\$0	\$0	\$0	\$0	\$138	\$138	\$138 \$	s138 \$:138 \$	138 5	138 5	138 3	s138 \$	138 \$	138 \$	138 5	\$138	§138 \$	38 \$1	38
Transmission D.1	\$185	\$0	\$0	\$0	\$0	\$20	\$20	\$20	\$20	\$20 \$	20	\$20	\$20	\$20	520	520 5	\$20	\$20	\$20	20 \$	0
Avoided Transmission - Base 230 kV	(\$843)	\$0	\$0	\$0	\$0	(\$92)	(\$92)	(\$92) (\$92) (\$92) (5	592) (\$92) (\$92)	\$92) (\$92) (\$92) (\$92) ((\$92)	(\$92) ((S) (S)	92)
Transmisison Network Wind [1]	\$41	\$0	\$0	\$0	\$0	\$5	\$5	\$5	\$5	2	z	\$4	\$4	\$4	\$4	\$5	\$4	2	2	2	4
Transmission OATT Credit	(\$128.78)	\$0.00	\$0.00	\$0.00	(\$0.07)	(\$14.19) (\$14.17) (\$	(14.14) (\$	14.13) (S	14.11) (\$1	4.10) (\$	(4.08) (\$	14.06) (\$	14.05) (\$	(4.04) (\$	14.14) (\$	14.12) (\$	(14.10) (\$	(14.08) (5)	4.07) (\$1	1.06)
Change in NPC	(\$948)	(80)	\$0	\$0	(\$2)	(\$105)	(\$109) (\$115) (3	\$120) (5	\$119) (\$	141) (3	(141) (5147) (\$118) (\$	(123)	\$122) (\$	6130) (\$151) (\$159) (\$	165) (\$:	(00)
Change in Emissions	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	80	<u></u>	\$ 0	\$0	\$0	\$ 0	\$0	\$0	\$0	\$0	50 \$	0
Change in VOM & Driver Adjustments	(\$40)	\$0	\$0	\$0	\$0	(\$4)	(\$5)	(86)	(\$3)	(\$2) (\$2)	(\$3)	(\$3)	\$34 (817) (\$17) (\$17) ((212)	(217) (617) (\$	17)
Change in DSM	(\$41)	\$0	(\$1)	(\$2)	(\$3)	(\$3)	(\$3)	(\$4)	(\$5)	(\$5) (\$5)	(\$5)	(\$6)	(\$2)	\$5)	(\$5) ((86)	(\$6)	(\$6)	20) (;	(9
Change in Deficiency	(\$5)	(80)	\$0	\$0	(\$2)	(\$3)	(80)	(\$1)	(\$2)	(0\$)	\$0)	\$0	\$0	(80)	80	(20)	(20)	\$0	\$0	50 \$	0
Change in System Fixed Cos	(\$48)	(\$0)	(80)	(80)	(80)	(80)	(\$0)	(80)	(80)	(\$0) \$	48	349	\$49	\$40) ()	\$41) (\$42) ()	\$43) ((\$45)	(\$46) (548) (\$	49)
Net (Benefit)/Cost	\$755	(0\$)	(\$1)	(\$2)	(86)	879	277	\$74	\$84	\$ 06\$	125 5	132 \$	128	1111	52 \$	111 \$	105	618	\$72 \$	\$ 69	88
Risk Adjustment	(\$85)																				
Net (Benefit)/Cost with Risk Adjustment	\$670																				

SC-GHG																						
(Benefit) /Cost	PVRR(d)	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	
Cost of Project	\$1,836	\$0	\$0	\$0	\$0	\$192	\$194	\$199	\$214	\$217	\$225	\$231	\$234	\$240	\$238	\$298	\$301	\$298	\$300	\$304	\$309	
New Wind Capital Cost	\$396	\$0	\$0	\$0	\$0	\$33	\$34	\$34	\$40	\$40	\$42	\$45	\$45	\$47	\$51	\$93	\$94	\$94	\$95	\$97	66\$	
Wind Run-Rate Fixed Costs	\$328	\$0	\$0	\$0	\$0	\$51	\$52	\$54	\$53	\$55	\$56	\$57	\$59	\$59	\$56	\$16	\$17	\$17	\$17	\$17	\$17	
PPA	\$1,332	\$0	\$0	\$0	(80)	\$180	\$181	\$188	\$197	\$202	\$208	\$215	\$220	\$224	\$220	\$130	\$132	\$129	\$129	\$132	\$134	
PTC Credits	(\$750)	\$0	\$0	\$0	\$0	(\$131)	(\$131)	(\$135)	(\$134)	(\$139)	(\$140)	(\$143)	\$148)	(\$148)	(\$148)	\$0	\$0	\$0	\$0	\$0	\$0	
Wind Tax	\$14	\$0	\$0	\$0	\$0	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	
Transmission GWS	\$1,261	\$0	\$0	\$0	\$0	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	\$138	
Transmission D.1	\$185	\$0	\$0	\$0	\$0	\$20	\$20	\$20	\$20	\$20	\$20	\$20	\$20	\$20	\$20	\$20	\$20	\$20	\$20	\$20	\$20	
Avoided Transmission - Base 230 kV	(\$843)	\$0	\$0	\$0	\$0	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	(\$92)	
Transmisison Network Wind	\$41	\$0	\$0	\$0	\$0	\$5	\$5	\$5	\$5	2	2	\$4	\$4	\$4	\$4	\$5	\$4	2	2	\$4	\$4	
Transmission OATT Credit	(\$129)	\$0	\$0	\$0	(80)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	(\$14)	
Change in NPC	(\$2,129)	\$0	(\$1)	(86)	(\$ 4)	(\$217)	(\$230)	(\$243)	(\$260)	(\$296)	(\$363)	(\$350)	\$357)	(\$286)	(\$288)	(\$292)	(\$304)	(\$380)	(\$270)	\$291)	(\$359)	
Change in Emissions	(\$1,919)	(80)	\$3	\$5	(\$3)	(\$317)	(\$264)	(\$266)	(\$245)	(\$246)	(\$286)	(\$286)	(\$296)	(\$198)	(\$218)	(\$229)	(\$260)	(\$257)	(\$274)	\$274)	(\$260)	W
Change in VOM	(\$30)	\$0	(80)	\$0	\$0	(\$1)	(\$1)	(\$2)	(\$2)	(\$2)	(\$1)	(\$2)	(\$2)	\$35	(\$16)	(\$16)	(\$15)	(\$22)	(\$15)	(\$14)	(\$17)	itn
Change in DSM	(\$41)	\$0	(\$1)	(\$2)	(\$3)	(\$3)	(\$3)	(\$4)	(\$5)	(\$5)	(\$5)	(\$5)	(\$6)	(\$5)	(\$5)	(\$5)	(\$6)	(86)	(\$6)	(\$6)	(86)	es
Change in Deficiency	(\$236)	(08)	\$0	(\$15)	(\$3)	(\$67)	(\$38)	(\$16)	(\$25)	(\$4)	(\$126)	\$0	\$0	\$0	(80)	\$0	(\$1)	(\$233)	\$ 0	\$0	\$69	SS:
Change in System Fixed Cos	(\$48)	(80)	(\$0)	(\$0)	(80)	(80)	(\$0)	(S0)	(80)	(\$0)	\$48	\$49	\$49	(\$40)	(\$41)	(\$42)	(\$43)	(\$45)	(\$46)	(\$48)	(\$49)	R
Net (Benefit)/Cost	(\$2,568)	(\$1)	\$1	(\$18)	(\$13)	(\$412)	(\$343)	(\$331)	(\$322)	(\$336)	(\$508)	(\$363)	(2377)	(\$254)	(\$331)	(\$287)	(\$328)	(\$646)	(\$312)	\$328)	(\$312)	icł
Risk Adjustment	(\$251)																					۲ ۲
Not (Damafit) (Cost with Diels A diretenant	(010 (3/																					

CERTIFICATE OF SERVICE

Docket No. 21-035-54

I hereby certify that on October 7, 2021, a true and correct copy of the foregoing was served by electronic mail to the following:

Utah Office of Consumer Services

Michele Beck	mbeck@utah.gov
<u>ocs@utah.gov</u>	
Division of Public Utilities	
dpudatarequest@utah.gov	
Assistant Attorney General	
Patricia Schmid	pschmid@agutah.gov
Justin Jetter	jjetter@agutah.gov
Robert Moore	rmoore@agutah.gov
Victor Copeland	vcopeland@agutah.gov
Rocky Mountain Power	
Data Request Response Center	datarequest@pacificorp.c
Jana Saba	jana.saba@pacificorp.cor utahdockets@pacificorp.d

John Hutchings

om <u>n</u> com john.hutchings@pacificorp.com

Savan

Katie Savarin Coordinator, Regulatory Operations