



Public Service Commission

THAD LeVAR
Chair

DAVID R. CLARK
Commissioner

RON ALLEN
Commissioner

State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

January 4, 2022

Ms. Jana Saba
Rocky Mountain Power
1407 West North Temple, Suite 330
Salt Lake City, UT 84116

Data Request Response Center
PacifiCorp
825 NE Multnomah St., Suite 2000
Portland, OR 97232

Re: *Request of Rocky Mountain Power for Major Event Exclusion for the Snowstorm in Smithfield, Utah on October 12, 2021 – Major Event No. 51; Docket No. 21-035-63*

Dear Ms. Saba:

The Public Service Commission (PSC) reviewed the November 16, 2021 filing by Rocky Mountain Power (RMP) requesting Major Event exclusion for events related to a severe snowstorm on October 12 2021 (“Event”). RMP indicates if the request is approved, outage information for these events will be excluded from RMP’s network performance reporting and from customer guarantee failure payments.

The PSC also reviewed the Division of Public Utilities’ (DPU) December 16, 2021 comments. DPU states it determined the System Average Interruption Duration Index (SAIDI) value of 7.23 minutes relating to this Event exceeds the daily SAIDI threshold value of 4.54 minutes that defines a Major Event under the method adopted by the PSC,¹ and should be excluded from RMP’s network performance reporting. DPU also indicated it considers RMP’s restoration efforts to have been adequate. Accordingly, DPU recommends the PSC approve RMP’s application for a Major Event exclusion.

Based on the PSC’s review of RMP’s filing and DPU’s comments and recommendation, RMP’s request for a Major Event exclusion is approved.

Sincerely,

/s/ Gary L. Widerburg
PSC Secretary
DW#321816

¹ Institute of Electrical and Electronic Engineers’ 2.5 Beta method, approved by the PSC in Docket No. 98-2035-04.