

**FORMAL COMPLAINT FORM
PUBLIC SERVICE COMMISSION
Heber M. Wells State Office Building
160 East 300 South, Fourth Floor
P.O. Box 45585
Salt Lake City, Utah 84114**

Complaints are public documents and are maintained on the Public Service Commission website. Further information on formal complaints is available at: <https://psc.utah.gov/complaint-process/>

1. Name of Complainant: Glenn Mickelson

Address: 4909 S Warehouse Road, Kearns, UT 84118

Telephone No.: 801-550-3043

Email Address: glenn@peakmobile.com

Preferred method of contact: Email or U.S. Mail

If represented by counsel, list:

Name: _____

Address: _____

Telephone No.: _____ Email Address: _____


2. The utility being complained against is: Rocky Mountain Power

3. What did the utility do which you (the Complainant) think is illegal, unjust, or improper?
Include exact dates, times, locations and persons involved, as closely as you can.

Rocky Mountain Power has not properly buried its 7200 volt line to a code required depth of 30 inches in the lower 1-1/2 miles of the Water Fork Rose Canyon road.

4. Why do you (the Complainant) think these activities are illegal, unjust or improper?
I have documented and photographed the cable exposed on the road surface. As a licensed Master Electrician, I understand the imminent danger that exists with such a high voltage line exposed on the surface of the road or minimally covered with only a few inches of dirt. Any rain showers will rapidly re-expose the high voltage cable. This hazard presents significant risk to life and safety of anyone in the area.

5. What relief does the Complainant request?
Work should immediately be scheduled and completed with the most earnest and expeditious of efforts of Rocky Mountain Power. The exposed cable presents an immediate public safety danger. Hikers, Equestrian enthusiasts, and their families frequent the area. In addition, I feel the depth of the electrical line should be certified by an independent third party for approximately 1-1/2 miles of the Rose Canyon road.

6. Signature of Complainant 

Date: 5/18/2023

NOTE: Submit complaint by email or U.S. mail. (<https://psc.utah.gov/psc-filing-requirements/>)



Photograph of the exposed 7200 volt power line approximately 194 feet above the first gate just above the parking area adjacent to the Yellow Fork Trailhead.
Lat: 40°27'51.70"N, Long: 112° 5'7.40"W