

May 30, 2024

Utah Public Service Commission

160 East 300 South, 4th Floor

Salt Lake City UT 84111

RE: Wildland Fire Protection Plan Annual Compliance Report

To Whom it may concern,

Utah Code 54-24-203(3) establishes the process for the electric cooperatives to prepare a wildland fire protection plan. In April 2024, Bridger Valley Electric Association, in coordination with BKI Engineering has reviewed and revised a wildland fire protection plan. The Wildland Fire Protection Plan has been submitted with this compliance report to be filed with the Public Service Commission for public inspection as required by 54-24-203(5)(a).

Additionally, Utah code 54-24-203 (4) states that an electric cooperative must file an annual report detailing the cooperatives compliance the approved wildland fire protection plan, this filling confirms that Bridger Valley Electric Association has presented the revised Wildfire Protection Plan to its governing authority at a regular board meeting held on 5-21-24. This report includes our actions taken over the course of the year. BVEA is trimming right of ways, putting beakers to non-reclosing, and raptor guarding, also implementing mitigation strategies, as outlined in the April,2024 BVEA Wildland Fire Protection Plan.

Bridger Valley Electric Association has complied with the statutory requirements of 54-24-203 (3) and is available for further questions from the Commission if needed.

Thank You

Bob Larsen

BVEA Operations Manager

307-780-8948

Bobby@bvea.coop