

P.S.C.U. Docket No. 13-057-05

Data Request No. 10.07

Requested by Division of Public Utilities

Date of QGC Response September 19, 2013

DPU 10.07 All other things being equal what would the Impact Radius be for an average IHP?

Answer: The Potential Impact Radius (PIR) for IHP lines of various sizes operating at 60 psi is as follows:

IHP diameter	8"	10"	12"	14"	16"	20"	24"
PIR	43'	53'	64'	75'	86'	107'	128'

Prepared by: Brad Hasty, General Manager Engineering/Project Management, Questar Gas Company