

# Francis City Clearance

Date 7/16/18

Address 402 Aspen Rd

City Francis

Subdivision Wild Willow Lot G-18

Owner/Builder Todd Defendis

Fuel Line Size 1 1/4 Load 546,000 BTU

Pressure-2lb. 4oz.

Permit # 16029

Building Inspector E. C. Pruitt

Comments Gas line was tested 15 lbs

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Confirmation  
# 18813

### FUEL GAS INSTALLATION FORM

(Revised 3/14/06)

Address: Todd Lot/Unit # \_\_\_\_\_

Subdivision: \_\_\_\_\_

PERMIT # \_\_\_\_\_

List of Equipment/Appliances:

Furnace(s) 20F 200,000 BTU's

Water Heater(s) 20F 100,000 BTU's

Dryer(s) \_\_\_\_\_ BTU's

Barbecue(s) 75,000 BTU's

Range/Cook Top(s) 100,000 BTU's

Boiler(s) \_\_\_\_\_ BTU's

Fireplace(s) 20F 70,000 BTU's

Other Equipment Specify: \_\_\_\_\_ BTU's

\_\_\_\_\_ BTU's

\_\_\_\_\_ BTU's

\_\_\_\_\_ BTU's

TOTAL: 545,000 BTU's

NATURAL GAS  LPG

FUEL INLET LINE SIZE: 1 1/4

SYSTEM OPERATING PRESSURE:

2 LBS. \_\_\_\_\_ 4 OZ.

OTHER: \_\_\_\_\_

**THIS FORM SHALL BE FILLED OUT  
AND ON SITE FOR INSPECTION.  
INSPECTION AND CLEARANCE WILL BE  
DENIED IF ANY OF THE INFORMATION  
REQUESTED IS NOT PROVIDED  
AND/OR FORM IS NOT ON SITE.  
ALSO, A RE-INSPECTION FEE AND A  
48 HOUR WAIT WILL BE IMPOSED.**

#### CONTRACTOR INFORMATION

Builder's Name: Todd Gen. Contractor ( ) Owner Builder   
(Check which one applies)

Business Phone: ( ) \_\_\_\_\_ License # \_\_\_\_\_

Mechanical Contractor: JJ sheet metal

Business Phone: (801) 556-4505 License # 5796294-5501

I hereby certify that the entire mechanical fuel-line system for the structure located at the address listed above has been sized and pressure tested in accordance with the applicable codes currently adopted by the State of Utah.

Jesse J. [Signature]  
Printed Name of Installer

[Signature]  
Signature of Installer

6/25/18  
Date