

Requested by the American Natural Gas Council
Date of EGU Response: August 25, 2025

ANGC 2.13: Please indicate whether EGU requires telemetering of Interruptible Service customers. If so, please identify where in the Company's tariff requirements for telemetering of Interruptible Service customers are set forth. If not, please explain why telemetering is not essential for ensuring compliance with interruption requests for such customers.

Answer: All interruptible sales service customers are required to use telemetry equipment for metering to limit usage to the daily contract limit that is outlined in section 4.01 of the Tariff. While not explicitly stated in the Company's Tariff, telemetry equipment is required in order for the Company to be able to limit usage.

Prepared by: Jordan Parks, Regulatory Analyst