



Report on Smart Grid Technologies

Table of Contents

Executive Summary	3
An Introduction to the Smart Grid	4
Technologies under Consideration and Evaluation	8
Challenges and Risks of Implementing Smart Grid	23
Regulatory Considerations	27
Smart Grid Economic Review	28
Smart Grid Implementation	34
Conclusion	34

Executive Summary

PacifiCorp (“Rocky Mountain Power” or the “Company”) has conducted an internal study of smart grid technologies for implementation across its six-state service territory. Through this effort, Rocky Mountain Power analyzed smart grid technologies currently available in the market and those expected to be available within the foreseeable future. The study considered both the operational characteristics and financial impacts of implementing smart grid technologies. The results and conclusions of this study were relied upon as the primary source of information used by Rocky Mountain Power while compiling this report.

In the electric utility industry, “smart grid” is a loosely defined term that refers to a wide variety of technologies and equipment owned by utilities and customers. Generally speaking, smart grid involves a communication network coupled with the power grid. For Rocky Mountain Power, the smart grid definition started with a review of the relevant technologies for transmission, substation and distribution systems, including smart metering and home area networks which enable customers to respond to market price fluctuations. As these technologies were reviewed, it was recognized that the most critical infrastructure decision is the communications network selected. The network must provide robust, high-speed low latency communication for critical applications, while maintaining existing characteristics that accommodate both normal and emergency operation of the electrical system. And the network must be available at all times, even during the first critical moments of a large scale disturbance to the system.

The focus for Rocky Mountain Power relative to smart grid technologies remains with those technologies that can be readily integrated with the existing infrastructure – technologies that do not require major electrical system changes. The technologies chosen for Rocky Mountain Power’s internal study were narrowed down to advanced metering systems with demand response programs, distribution management systems and transmission synchrophasors. Technologies not considered for the study included auto-healing distribution systems, distributed energy systems (including electric vehicles) and direct load control programs.

Each of the components examined have identifiable costs and quantifiable benefits that were used to estimate the rough potential of investing in those technologies. While there are not always proven costs or savings for each of the components, qualified estimates can be used to gauge costs and there is enough theoretical data established for savings opportunities on which a suitable analysis can be built to gauge the relative potential of various alternatives. Many of the benefits are highly variable and dependent on external factors, especially factors that involve changes in consumer behavior, values of the forward capacity and energy markets, percentage of the customer base participating in dynamic pricing programs and the energy conservation achieved by those customers.

Rocky Mountain Power’s study of smart grid revealed that these technologies do show promise for future improvements in the operation and management of the transmission and distribution systems. However, the cost to implement a comprehensive smart grid system throughout the Rocky Mountain Power territory outweighs the benefits of implementation at this time. Modification of consumer behavior would be central to realizing many benefits. Changes in usage and improved conservation have the potential to dramatically transform the electric industry; however, most of the benefits associated with customer behavior changes are based on

optimistic assumptions regarding the number of customers who will change their energy usage. Questions surrounding the sustainability of any consumer behavior change remain uncertain.

In order to prudently manage the costs and risks to the Company and our customers of investing in smart grid technologies, Rocky Mountain Power believes it is necessary to allow additional time for smart grid technologies to more fully mature, i.e. allow time for technology leaders to emerge and ensure that system interoperability can be verified. The Company believes that valuable insight can be gained by analyzing the results of early adopter smart grid deployments.

Rocky Mountain Power will continue to monitor the technology advances and developmental activities throughout the nation as more advanced metering and other smart grid related projects are built. This will allow for improved estimates of both costs and benefits. Over the past year, approximately 100 smart grid projects have received funding through the American Recovery and Reinvestment Act (ARRA). American Electric Power, Duke Energy, San Diego Gas and Electric and Southern California Edison are at the forefront of these smart grid projects and are utility leaders in advancing deployment of smart grid technologies. Presently, there are 52 smart grid demonstration projects underway in the United States; 54 utilities deploying some component of smart grid; and 34 industry organizations involved in smart grid development. Rocky Mountain Power is actively monitoring industry movements and the demonstration projects with a keen interest in assessing the costs of installation and operation of the smart grid technologies and the benefits realized (both operational and economic) through the smart grid systems.

An Introduction to the Smart Grid

Investor-owned utilities are finding themselves at the crossroads of an evolution involving advanced technologies, collectively referred to as a smart grid, and the traditional operational practices. The technologies associated with smart grid are being accelerated by recent federal legislation – including the Energy Policy Act of 2005 (EPAct), the Energy Independence and Security Act of 2007 (EISA) and the American Recovery and Reinvestment Act of 2009 (ARRA). Traditional operational practices are being sustained by lower operating costs and effectively managed customer costs, but have come under increasing scrutiny as the interest in smart grid expands across the country.

Both the EPAct and the EISA have required that each state review the requirements of the legislation and make a determination of whether or not to adopt the standards included within. While each of the states within our service territory have elected not to adopt most of the standards, they have voiced an interest in understanding what Rocky Mountain Power's current and future plans are for implementing the smart grid technologies.

The public interest in smart grid has also hit a crescendo due to the marketing efforts by the companies positioned to take advantage of the investments funded by the recently passed ARRA legislation (the "stimulus" package). Inquiries into the Company's ability to provide a smart grid or to participate with a local city or municipality on a smart grid pilot project continue to increase. The interest in smart grids within Rocky Mountain Power's service territory will continue to grow as neighboring states and utilities expand their advanced technologies and more information becomes available in the public sector.

With the increase in smart grid industry activities and the number of pilot projects initiated recently, Rocky Mountain Power has acknowledged the need to create a dedicated organization within the Company to oversee the related activities within the Company and throughout the industry. The Company has created an internal smart grid department lead by the director of smart grid technologies; this position reports directly to the president of Rocky Mountain Power. This department will be responsible for the management and coordination of all smart grid related technologies and activities within the Company, including the monitoring and assessment of smart grid pilot projects throughout the United States.

This department will develop and manage a comprehensive strategy for smart grid and will be actively engaged with industry workgroups to learn best practices as the technologies continue to evolve. The department will create and manage an active business case to continue to assess the economic viability of the individual and combined functionalities of smart grid. This will position the Company to benefit from the experience of other utilities who are actively engaged in piloting and implementing smart grid technologies. Rocky Mountain Power believes that with a focused and concentrated effort, the mitigation of the risks associated with new, emerging and unproven technologies will benefit customers.

The purpose of Rocky Mountain Power's internal study was to define the scope of smart grid for Rocky Mountain Power, identify the suitable technologies that would be required to meet the scope and examine the financial characteristics of such an investment. This report is designed to provide the reader with a basic understanding of the smart grid definition and components along with their costs and benefits. It is not intended to provide a detailed level of understanding or an ideological explanation of the details behind every technology that can be used to migrate to a smart grid system throughout Rocky Mountain Power.

The following definitions are presented as a fundamental base line upon which to define Rocky Mountain Power's smart grid.

The Electric Power Research Institute (EPRI) defines the smart grid as:

- A power system made up of numerous automated transmission and distribution (T&D) systems, all operating in a coordinated, efficient and reliable manner,
- A power system that handles emergency conditions with 'self-healing' actions and is responsive to energy – both market and utility needs, and
- A power system that serves millions of customers and has an intelligent communications infrastructure enabling the timely, secure, and adaptable information flow needed to provide power to the evolving digital economy.

According to the Modern Grid Initiative, a smart grid has the following characteristics:

- “It will enable participation by consumers.” Smart grid enables consumers to have access to new information, control, and options to engage in electricity markets. Consumers will be able to see what they use, when they use it, and what it costs them. This will enable them to manage their energy costs, invest in new devices and sell resources for revenue or environmental stewardship. In addition, grid operators will have new resource options that will enable them to reduce peak load and prices and improve reliability.

- “It will accommodate all generation and storage options.” Smart grid will seamlessly integrate all types and sizes of electrical generation and storage systems. This will move the system from one dominated by central generation to a more decentralized model as more smaller distributed sources and plug-and-play convenience come into the system.
- “It will enable new products, services and markets.” Smart grid will link buyers and sellers, support the creation of new electricity markets, and provide for consistent market operation across regions. That is, instead of the current not well-integrated, limited wholesale markets, smart grid will lead to mature, well-integrated wholesale markets and growth of new electricity markets.
- “It will provide power quality for the digital economy.” The smart grid will provide utilities with the ability to better monitor, diagnose, and respond to power quality issues thus reducing consumer losses due to power quality.
- “It will optimize asset utilization and operate efficiently.” Smart grid will enhance asset operations by improving load data, reducing system losses, and integrating outage management. It will also improve the maintenance and resource management processes. This will lead to reduced utility costs, both O&M and capital.
- “It will anticipate and respond to system disturbances.” With smart grid, the system will be able to self-heal by performing continuous self-assessment, detecting, analyzing, and responding to any disturbances, and restoring the grid components or network sections.
- “It will operate resiliently against attack and natural disaster.” Smart grid enables system-wide solutions to physical and cyber security thereby reducing threats and vulnerabilities.

In August 2005, Congress passed the Energy Policy Act of 2005. Section 1252, entitled “Smart Metering”, laid the framework for time-based pricing for electrical energy consumption. This bill required that each regulated utility offer time-based rates and each state commission investigate demand response and time-based metering.

On December 19, 2007, the Energy Independence and Security Act of 2007 was passed and has ushered in a new era in the policy decisions of state regulatory commissions as well as electric utility companies within their jurisdictions. This Act is applicable to all electric utility companies; investor-owned, public and municipal. The policy statement contained in Section 1301 of the Act has broad implications that will affect all utilities and their decisions regarding the deployment of automated metering, advanced metering and smart metering technologies.

Section 1301 of the Act, Statement of Policy on Modernization of Electricity Grid, defines the “smart grid” and indirectly, smart metering. It is more inclusive than the definition of smart metering found in Section 1252 of the Energy Policy Act of 2005. Section 1301 of the Energy Information and Security Act of 2007 defines the Smart Grid as a “the modernization of the Nation's electricity transmission and distribution system to maintain a reliable and secure electricity infrastructure that can meet future demand growth and to achieve each of the following, which together characterize a Smart Grid:

- (1) Increased use of digital information and controls technology to improve reliability, security, and efficiency of the electric grid.
- (2) Dynamic optimization of grid operations and resources, with full cyber-security.
- (3) Deployment and integration of distributed resources and generation, including renewable resources.

- (4) Development and incorporation of demand response, demand-side resources, and energy-efficiency resources.
- (5) Deployment of ‘smart’ technologies (real-time, automated, interactive technologies that optimize the physical operation of appliances and consumer devices) for metering, communications concerning grid operations and status, and distribution automation.
- (6) Integration of ‘smart’ appliances and consumer devices.
- (7) Deployment and integration of advanced electricity storage and peak-shaving technologies, including plug-in electric and hybrid electric vehicles, and thermal-storage air conditioning.
- (8) Provision to consumers of timely information and control options.
- (9) Development of standards for communication and interoperability of appliances and equipment connected to the electric grid, including the infrastructure serving the grid.
- (10) Identification and lowering of unreasonable or unnecessary barriers to adoption of smart grid technologies, practices, and services.”

To meet the intent of these generally accepted definitions of a smart grid it can be deduced that intelligent electronic devices (IEDs) must be placed on every critical node of the end-to-end grid. It can also be concluded that a smart grid must have a robust, reliable, and secure communication network throughout the grid as well. Thus, to achieve a smart grid, the Company must merge the electricity generation and delivery infrastructure with the information and communication infrastructure.

Acronyms

The electric utility industry utilizes several acronyms that are easily confused with acronyms used in other industries. The evolution of the smart grid has increased the number of acronyms and, as technologies emerge and continue to be refined, several are used interchangeably creating confusion within the industry itself. Table 1 below lists several of the acronyms used in this report. Definitions, if necessary, for each will be given in the appropriate section.

Acronym	Name
AMI	Advanced Metering Infrastructure
AMS	Advanced Metering System
CBM	Capacitor Bank Maintenance
CES	Centralized Energy Storage
CPP	Critical Peak Pricing
CVR	Conservation Voltage Reduction
DMS	Distribution Management System
DR	Demand Response
FDIR	Fault Detection, Isolation and Restoration
HAN	Home Area Network
IED	Intelligent Electronic Device
IHD	In-Home Display
IVVO	Interactive Volt-Var Optimization
MDMS	Meter Data Management System

Acronym	Name
OMS	Outage Management System
PMU	Phasor Measurement Unit
PTR	Peak Time Rebate
RAS	Remedial Action Scheme
TSP	Transmission Synchrophasors
TOU	Time-Of-Use
WAN	Wide Area Network

Table 1

Technologies under Consideration and Evaluation

For Rocky Mountain Power, the smart grid definition started with a review of the relevant technologies for transmission, substation and distribution systems, including smart metering and home area networks to enable consumer demand response programs. As these technologies were reviewed, it was recognized that the most critical infrastructure decision is the communications network selected. The network must provide robust, high-speed and low latency communication for critical applications while maintaining existing characteristics that accommodate both normal and emergency operation of the electrical system. And the network must be available at all times, even during the first critical moments of a large scale disturbance to the system.

There are several broad categories for smart grid that remain relatively undefined as to the exact benefits and functions they provide. Distribution automation is one such category. For example, distribution automation is made up of several functionalities that have intelligent interoperability amongst themselves to enable a system that will maximize the system for efficiency and reliability. A system that can increase efficiency through integrated renewable and distributed generation resources, better system balancing, actively managed power factor and line losses and has the ability to identify, locate and isolate faulted conductors and automatically restore power to areas outside the fault zone will require that redundant and oversized systems be created. To enable the complete spectrum of distribution automation, a fully redundant system is required. This level of redundancy comes at a cost that will not, according to Rocky Mountain Power's analysis, support any economic based decision and, therefore, will not be addressed in this report.

The focus of Rocky Mountain Power's smart grid analysis was with those technologies that are easily integrated with the existing infrastructure – technologies that do not require major electrical system changes. The technologies chosen for the study were narrowed down to those systems shown in Table 2 below. Technologies not considered for the study include auto-healing distribution systems, distributed energy systems (including electric vehicles) and direct load control programs. Each of these components will utilize a common information technology and communications infrastructure to gain the maximum benefits through reduced duplication of facilities.

With the large capital investment required to enable these smart grid elements, it is essential that Rocky Mountain Power prudently consider all of the costs and benefits realized through these technologies. Investment in smart grid should only be made when the utility and its customers can be reasonably assured that net benefits, both financial and operational, will be realized through smart grid implementation. Rocky Mountain Power believes that additional time is required to allow the smart grid industry to develop and evolve. Allowing the market to more fully develop prior to investment by Rocky Mountain Power will ensure that market leaders are identified and that system interoperability is verified. The Company will also be able to glean valuable information from smart grid deployments of other utilities. With deployments beginning throughout North America, including California, Texas and Ontario and a myriad of pilots elsewhere enabled through the recent ARRA funding opportunities, the market leaders will become self-evident as the systems begin to mature during the next few years.

<p><u>Smart Grid Technologies Analyzed</u> Advanced Metering System Demand Response Home Area Networks Distribution Management System Interactive Volt-Var Optimization Conservation Voltage Reduction Capacitor Bank Maintenance Centralized Energy Storage Outage Management System Fault Detection, Isolation and Restoration Transmission Synchrophasors</p>

Table 2

Information and Communication Infrastructure

The backbone of the smart grid is the information and communication infrastructure and is critical to the success of the program. The system must be robust enough to not only handle the amount of data generated by the advanced metering system and the intelligent electronic devices (IEDs) deployed throughout the electricity delivery infrastructure, but have the intelligence to prioritize and react to the data delivered. Information related to system disturbances or outages must be given fast, preferential handling over lower priority items such as meter readings. The IT system must process the data and interpret which applications need the data and the format required. It must be able to store the data in an easily retrieved, archived format and utilize that data for historical comparative purposes when needed to make proper decisions for applying corrective actions to manage the electricity delivery infrastructure in an efficient manner.

Figure 1 portrays a smart grid information and communications architecture that must be developed to fully implement the entire scope of the Rocky Mountain Power smart grid. Note that the transmission synchrophasors are not part of the model. That system is best operated as a

stand-alone application due to the high-speed processing and handling requirements of the data received from the PMUs.




Figure 1

Communications Network

The backbone of a successful smart grid operation is a reliable, resilient, secure and manageable communication infrastructure. The broad scope of smart grid application areas, coupled with the large and diverse geographic expanse of Rocky Mountain Power’s service territory, dictates a large, complex, and costly smart grid communications network.

The intent of smart grids is to provide better efficiencies in the production, transport, and delivery of energy. This is realized in two ways:

- Better real-time control: the ability to remotely monitor and measure energy flows more closely and manage those flows in real time.
- Better predictive management: the ability to monitor the condition of different elements of the network to predict failure and direct proactive maintenance.

These mechanisms imply more measurement points, remote monitoring and management capabilities than exist today. It also requires a greater reliance on reliable, robust and highly available communications.

The new smart applications are dictating the need for a wider deployment of communications, through the distribution circuits and all the way down to the customer premises. These functions were never envisioned for Rocky Mountain Power’s existing communication systems. New communication services must support such endpoints as advanced metering systems (AMS), automated switches, power quality devices, fault indicators and capacitor banks. At the same time, the communications network must continue to support the operational services independently of external events, such as power outages or public service provider failures, yet be economical and feasible to maintain.

As depicted in Figure 2, the smart grid communications network will leverage existing investment in the bulk transport network by re-using the existing fiber and microwave systems where possible but expanding it significantly to support other services. To reach out to support customer and distribution assets, new wide area networks (WANs) will need to be built out or leased.




Figure 2

The vision is to efficiently leverage the long-haul communication assets currently deployed and not create “silos” of purpose-built networks. The key to ensuring this does not happen is to guarantee the smart grid components communicate with the networks using standardized protocols. This will also help promote interoperability of different vendor components, thereby encouraging competition, and lowering component and maintenance costs. One way to help achieve this is to ensure any smart grid roadmap aligns with the Smart Grid Interoperability Standards Project that is being developed by the National Institute of Standards and Technology (NIST). These standards are not slated to be fully ratified until 2012.

Advanced Metering System (AMS)

Advanced metering systems (AMS) provide the highest level of meter reading automation and satisfy all requirements for the smart grid system. AMS provides the data required to fully integrate meter reading, demand response, outage management, and distribution management functions. These systems have the capability to offer an “in-home display” of information to customers and integrate direct load control where the utility sends signals to cycle loads (e.g. A/C, water heaters, etc.). Furthermore, these systems are capable of integrating indirect load control where the utility sends pricing signals and consumers can program the behavior of their individual appliances to respond to changing prices.

Advanced metering infrastructures, commonly referred to as AMI, provide the same metering data levels as automated meter reading (or “drive-by”) systems but provide enhanced capabilities by collecting interval data from all meters. This interval data can be used for time-based rates and critical peak pricing programs but lack the direct customer notification and integration of in-home displays. These systems can provide additional benefits in the form of outage detection and restoration messages via the system. Demand response programs cannot be implemented directly through most AMI systems. Demand response programs are implemented with direct load control through a separate system (e.g. paging, etc.) and the impacts measured with the AMI system. Even with their advanced functionalities, AMI systems do not meet all the requirements for the smart grid.

The Federal Energy Regulatory Commission (FERC) has defined AMI as “a metering system that records customer consumption (and possibly other parameters) hourly or more frequently and that provides for daily or more frequent transmittal of measurements over a communication network to a central collection point. AMI includes the communications hardware and software and associated system and data management software that creates a network between advanced meters and utility business systems and which allows collection and distribution of information to customers and other parties such as competitive retail providers, in addition to providing it to the utility itself.”

Note that neither home area networks nor in-home displays are a required component of AMI as defined by FERC, although they offer benefits for demand response in addition to those possible with AMI-supported time-varying pricing alone. Also, control of distribution equipment (reclosers, sectionalizers, capacitors, etc.) is not a required component of AMI. In combination, these additional features begin the framework for a “smart grid”.

Automated meter reading (AMR) systems are typically defined as a system that only automates the manual meter reading process. These systems deliver accurate and reliable monthly meter readings to billing on a cycle basis at a cost typically lower than manual reading methods. Mobile or drive-by systems are the most commonly implemented automated meter reading solutions in the industry. Some AMR systems, including those installed by Rocky Mountain Power, are capable of migrating to a one-way fixed network system that meets the basic requirements of AMI as defined by FERC.

The term “AMI” is used routinely in many discussions and papers and to support the users’ own purposes for the system being proposed. AMI is used to define systems ranging from one-way fixed networks to two-way advanced metering systems. The functional requirements of the

metering system must be known to determine the reasonableness of the system proposed. By using identifying names for the systems and not relying solely on the acronym to differentiate systems will assist in the understanding of what the metering system will deliver to the user.

For the purpose of this report, the term “advanced metering system” will be used to maintain clarity. Advanced metering systems provide for the definition as outlined by FERC and include all the functionality required to support the smart grid. Automated meter reading systems, and most advanced metering infrastructures, cannot be migrated to an advanced metering system without significant costs.

Demand Response (DR)

One of the key requirements to encourage customers to change energy usage patterns is to make the proper pricing signals available that encourages changes in the time energy is utilized. The most common price signals in the industry today are time-of-use (TOU), critical peak pricing (CPP) or peak time rebate (PTR) programs. A combination of TOU/CPP or TOU/PTR pricing programs are the most prevalent and present the greatest opportunity for creating reductions in energy usage during the most critical times when system peaks are present.

TOU tariffs create pricing programs that present to the consumer the real-time or relative price of energy at various times during the day. By selling electrical energy at the real-time price, it is anticipated that consumers would shift their consumption from the peak periods, or higher priced hours, to times when the cost of energy is lower. This shift in consumption will reduce the peak demand and increase the load factor on the electrical system. The most common TOU programs have on-peak and off-peak pricing components and a few also incorporate shoulder pricing. Critical peak pricing schemes are included in more advanced pricing structures to encourage conservation of energy during those few hours, typically 100 hours or less, each year when electrical demand peaks and places stress on the system.

One of the unique characteristics of CPP programs is the “rebound” effect that occurs at the conclusion of the CPP event. This rebound effect is caused when the deferred load, primarily air conditioning, increases dramatically at the end of the CPP event in an effort to bring the customer’s residence back to a “normal” comfort state. If the CPP event occurs for an extended period of time, the rebound effect becomes more pronounced and can create a new daily system peak higher than what the normal peak may have been. This is an anomaly that does exist but has insufficient studies to make it possible to calculate the magnitude and overall system effect with any degree of accuracy.

It has been stated that, given the proper pricing signals, consumers will reduce their peak energy usage during critical peak pricing periods. However, to date, only simple pilots of CPP pricing programs have been conducted and have provided less than meaningful statistics on the sustainability of consumer behavior change. Thus, there is no history that would allow Rocky Mountain Power to understand how much and how long customers will voluntarily participate in a dynamic pricing program for the life of the program.

The PacifiCorp total company summer peak of 2009 was measured at 9,420 megawatts. If critical peak events were scheduled and targeted to address the top 100 hours of system peak, these events would have occurred over 19 days with events that would have ranged from two to

nine hours in duration. System daily peaks for this time period are shown in Figure 3. In reality, the ability to forecast the exact time periods of system peak and schedule the critical peak events is not possible.




Figure 3

Rocky Mountain Power has provided a comprehensive set of demand-side management programs to its customers since the 1970s. The programs are designed to reduce energy consumption and more effectively manage when energy is used, including management of seasonal peak loads. These early efforts involved the management of water heating, air conditioning and irrigation loads and laid the foundation for the air conditioning, irrigation, and business curtailment programs the Company operates today. Although these programs are voluntary and rely on site specific control equipment and communication protocols for controlling loads, the Company has built a control network of participating customer end use loads of several hundred megawatts. The control technology and load management practices employed are some of the most advanced in the industry and together with the Company's conservation and energy efficiency efforts demonstrate that Rocky Mountain Power is actively engaged in improving the efficiency and management of its system, in employing education, equipment, and price incentives to maximize system performance.

Moving from site specific investments in demand response technologies and a voluntary approach to participation to a broader system-wide deployment of information systems and a price responsive system to drive usage patterns marks a fundamental shift in philosophy on how to manage end-use loads and engage customers.

Home Area Networks (HAN)

In context of smart grid, the term “Home Area Network” has become synonymous with in-home displays, programmable communicating thermostats and home area networks. Each of these devices serves a different level of functionality enabling the consumer with more control over their energy usage. In-home displays and home area networks provide information to the consumer on which they can make operating decisions. Programmable communicating thermostats can be used for either direct-load control by the electric utility, when provided with the appropriate permissions and access by the customer, or used in a home area network scheme by the customer.

One of the key requirements to encourage customers to reduce energy usage is to make the proper pricing signals available to the consumer through either an In-Home Display (IHD) or through their Home Area Network (HAN). In-home displays range from simple “fridge magnets” equipped with three levels of indication via green, yellow and red lights to very sophisticated displays that interface with the customer’s home area network. The simple fridge magnet display warns the customer of an upcoming critical peak event, and the resultant increase in energy prices, with the yellow indicator. This “yellow light” warning allows the customer time to reduce their load prior to an increase in energy prices. The red indicator light remains on during the event time frame. When pricing structures return to normal on-peak or off-peak state, the indicator light reverts to green.

Home area networks (HANs) enable the customer to leverage the real-time information received via the advanced metering system into automated actionable tasks that can reduce their energy consumption at peak times as well as enabling overall energy conservation. The advanced metering system provides for transmission of key data, including usage and price signals, to the customer who can then use this information to manage and lower their consumption. To utilize the home area network, more sophisticated communicating devices are required to allow the customer to program automatic actions to pricing signals and critical peak events. Home-area networks coupled with automated home appliances can give individuals the sense of empowerment over their electricity consumption and will help drive consumer smart grid acceptance.

Distribution Management System (DMS)

As the distribution systems continue to become more sophisticated and optimized in their operation, greater precision in operational data and minute-by-minute management are keys to its long-term success. A Distribution Management System (DMS) brings to the utility a variety of advanced analysis and operating tools for management of the distribution system. It integrates several systems and functions that are currently operated independently in today’s environment. Specifically, outage management, switching operations, lock-out and tagging procedures, fault calculations, load flows and real-time state estimation routines. Additionally, when integrated with Interactive Volt-Var Optimization program (IVVO) functionality, the distribution management systems can start to manage voltage to minimize line losses and energy needs while optimizing the delivery of energy to consumers. A DMS utilizes strategically placed equipment, including distribution transformers, distribution reclosers, motor-operated switches, and fault detection devices, integrated with backbone communications as inputs to an electronic model

which records and calculates key values integral to operating the system. Upon these calculations, key settings are enabled via appropriate communications paths which increase the efficiency of the system.

Distribution management systems create an intelligent distribution network model that provides ongoing data analysis from field deployed IEDs to maximize the efficiency and operability of the distribution network. A complete distribution management system provides distribution engineers with near real-time system performance data and historical performance metrics. This decreases the planning time requirements, increases visibility of system status and improves reliability metrics through better application and management of the distribution capital budgets. With appropriate data inputs from field IEDs, the DMS will be able to analyze the distribution network for both normal and emergency states and performs the following functions required for the interactive volt-var and fault detection, isolation and restoration activities:

- Monitor unbalanced load flow and determine if there are any operational violations for normal state and reconfigured distribution feeders.
- Determine the optimal position and operating constraints for the various power transformer taps, line voltage regulators and capacitors along a distribution feeder and manage the open/close positions of these devices.
- Receive fault data and run a short circuit analysis to determine the possible location(s) of the fault.
- Analyze the system during faulted conditions and determine the redistribution of the available load to adjacent feeders and substations.
- Suggest the switching sequence required to isolate the fault and restore power to as much load as possible outside the fault zone.
- Suggest the switching sequence for line unloading should a condition arise where an operator needs to reduce load from a specific substation.

Prior to the integration of IVVO or fault detection, isolation and restoration systems as identified for Rocky Mountain Power's smart grid, it is required that detailed network models of the distribution systems be created including three-phase unbalanced and system connectivity models. Rocky Mountain Power has invested in software technologies that satisfy both of these requirements positioning itself for a functional distribution management system that will incorporate the emerging technologies for smart grid.

Interactive Volt-Var Optimization (IVVO)

Current standards for voltage delivery values, as established by the American National Standards Institute (ANSI), allow for values within the range $\pm 5\%$ of nominal at the point of delivery to electric service customers. For standard residential voltage of 120 volts nominal, this ANSI standard allows the Company to deliver voltages ranging from 114 to 126 volts.

To maintain the voltage within the specified range across the entire distribution circuit, the voltage at the distribution substation buss is set at the upper limit of the designed voltage. The line voltage continually degrades as a function of line length, impedance and loading and, if not properly managed, will degrade to levels below the lower limit of the voltage standard. At a point on the distribution system and prior to the where the voltage would have degraded below

the acceptable limit, a capacitor bank or voltage regulator is installed to increase the voltage level to an acceptable limit at a value less than the upper limit of the voltage standard.

The decision of which device to install is driven by the characteristics of the circuit at the point of application. The engineering consideration and design parameters used for this decision are complex and will not be discussed in detail other than to state that power factor, voltage levels and peak circuit loading must be considered. As power factor approaches unity (100%) across the distribution feeder length, line current is decreased and distribution system losses are reduced.

The IVVO program utilizes these strategically placed distribution voltage regulators and capacitor banks for voltage and power factor control to reduce system losses associated with line losses on the distribution system. With real-time communications installed at each device, the voltage regulators and capacitor banks are automatically controlled by a module in the DMS.

In a traditional distribution system the downstream devices are contingent on the upstream devices and their pre-programmed operational parameters. As the number of distributed generation sources increases, the present voltage and power factor management schemes will no longer be able to maintain satisfactory levels. The DMS actively manages the voltage levels and power factor and adjusts the regulators and capacitors independently to produce a level voltage profile across the distribution system. This leveled voltage profile is only achievable through the complete integration of direct communication with the field equipment and the algorithms in the DMS. Through power factor correction, a more regulated voltage level is created and maintained along each distribution feeder. By improving the power factor, line loading is decreased and, in turn, reduces the line losses across the distribution system.

In addition to minimizing line losses over the distribution system, the Company is exploring the need for voltage optimization programs in response to the impact of the Company's irrigation load control programs. When electrical system needs arise that require an immediate reduction in load, the Company has the ability to control large quantities of irrigation load in Idaho and Utah (through demand-side management programs approved by the Idaho Public Utilities Commission and the Public Service Commission of Utah, respectively) to reduce the stress on the generation, transmission and distribution systems. However, when large amounts of load are dispatched off the system in a short period of time, there are consequences with voltage rise that can adversely impact other customers on the system. While capacitor banks have been used in local control methods to correct voltage and power factor, these current methods are not responsive enough to prevent voltage excursions from occurring.

Rocky Mountain Power is conducting a formal exploration of voltage optimization programs to address this issue. The intelligent integration of the load control and voltage optimization programs will be required to minimize and eliminate voltage excursions associated with large scale load reduction. The Company is exploring several technology options, including both centralized and distributed intelligence, to ascertain the most prudent solution to this complex problem. This effort began in June 2011 and is expected to take up to six months to fully complete.

Conservation Voltage Reduction (CVR)

For those circuits where the load is primarily resistive (which is typical of residential loads), the utility can reduce system loading during peak hours and emergency conditions by lowering the line voltages. The ability to mitigate system losses by decreasing line currents is achieved by reducing voltages to minimally acceptable levels as defined by the American National Standards Institute.

A conservation voltage reduction (CVR) module can be added to the distribution management system and utilizes the same field components as the IVVO system. Once the CVR module is installed the system voltage can be reduced across the feeder length since the IVVO system has created a leveled system voltage profile along the feeder length. The CVR module of the DMS uses the advanced metering system to obtain delivery voltage information from selected metering endpoints along the circuit. The CVR system then adjusts the system voltage by switching capacitor banks or adjusting regulators to lower the system voltage. This in-turn reduces the delivery voltage to the customer and, assuming a resistive load, reduces the load current which reduces the system loading through a reduction in line current.

Rocky Mountain Power is concerned about the potential risk of increased customer complaints stemming from low voltage (i.e., malfunctioning equipment, flickering lights, shrunk TV screen, etc.). Reduced voltage can have the effect of increasing the exposure of sensitive customer equipment to voltage sags and nuisance tripping. This can be particularly problematic for sensitive and expensive laboratory and hospital equipment, as well as tools and computers. Increased customer complaints are generally received when service voltage falls below 114 volts at the customer meter. It is imperative that the IVVO/CVR system respond quickly to sub-standard voltage conditions to prevent unintended consequences and operational problems for customer's equipment.

In response to Washington state's Initiative Measure No. 937 (which requires investor owned utilities to pursue all cost effective electric conservation), the Company has initiated an in-depth analysis of the cost-effectiveness, reliability and feasibility of a conservation voltage reduction program in the state of Washington. The engineering analysis is being conducted by Commonwealth Associates, Inc. and the full report is expected to be finalized by the end of 2011. The report will review the distribution efficiency opportunities for 19 distribution circuits in the Company's Washington service territory. The results of this study will provide information necessary to determine if a distribution efficiency program of this nature can provide benefits to the system in each of the jurisdictions in which the Company provides service.

Capacitor Bank Maintenance (CBM)

Typically, capacitor banks are visually inspected once per year to determine their operational state and inspect for damaged tanks or blown fuses. If the capacitor bank fails or becomes inoperable in the interim, the complete benefits of the IVVO system and the individual capacitor banks go unrealized. With the IVVO system and its advanced reporting capabilities, it can detect when a capacitor bank has operational problems without the need for a field inspection. This reduces the costs of the annual inspection programs. When a problem is detected, the IVVO

module creates a trouble order for the problem. This reduces the time the capacitor bank is out-of-service and maximizes the benefits realized from the voltage and var optimization routines.

Centralized Energy Storage (CES)

One of the benefits of a smart grid is the ability to integrate renewable energy sources into an electricity delivery system that is dominated by fossil fuel generation. In contrast to fossil fuel generation, that is available on demand, renewable energy sources cannot be scheduled and must be considered as variable. If a significant percentage of generation capacity comes from these variable sources, the smart grid will not be able to pick up the slack when the wind doesn't blow or the sun is not shining. There are two primary ways to fill this generation gap without the use of fossil fuel generation: demand response programs and centralized energy storage (CES).

CES can be used to store wind or solar generated energy, which typically occurs at non-peak hours, and release that energy during peak hours. Several new technologies are currently being researched throughout the industry including electrical battery storage, pumped hydro storage, flywheel energy storage and compressed air energy storage. Each of these solutions has unique characteristics, applications and costs. Electrical battery and flywheel energy storage are the emerging technologies that show significant promise for widespread application and use in the utility industry.

Electrical battery storage for utility scale applications, in contrast to single cell rechargeable batteries used in cell phones and other small appliances, require energy levels that can only be produced by converting chemical energy to electrical energy. Lithium-ion batteries are common in small applications, but building large-scale lithium-ions remains prohibitively expensive. Flow batteries are touted by some as the leading option for practical, utility-scale, high-capacity electricity storage. Sodium-nickel-chloride and lithium-iron-phosphate batteries are being developed and show some promise for large scale applications. Some cutting-edge solutions aggregate many small amounts of battery storage – electric vehicle batteries or uninterruptible power supplies.

Electrical battery storage provides the quickest response to energy demands. Batteries have the ability to store electrical energy generated by renewable resources, usually during off-peak times, and then release that energy when required during on-peak times. When strategically located, these battery storage solutions can also be used to delay increases in substation power transformers which overload only during short periods and at peak hours of the year. For the purposes of Rocky Mountain Power's smart grid, this report will use battery storage for the centralized energy storage cost and benefit analysis.

Flywheel energy storage works by accelerating a rotor (flywheel) to a very high speed and maintaining the energy in the system as rotational energy. When energy is extracted from the system, the flywheel's rotational speed is reduced as a consequence of the principle of conservation of energy, conversely adding energy to the system results in an increase in the speed of the flywheel. Such flywheels can come up to speed in a matter of minutes and much quicker than some other forms of energy storage. Flywheel energy storage systems are also referred to as “electromechanical battery systems” as their ability to respond quickly to energy demands are similar to chemical battery systems. On July 14, 2011, Rocky Mountain Power filed

an application with the Public Service Commission of Utah to defer the costs (\$625,000 in total) of a flywheel battery energy storage demonstration project and to recover those costs through the Schedule 193 demand-side management surcharge.

Outage Management System (OMS)

All electrical distribution systems are subject to faults caused by storms and other external events as well as failures related to aging and overloaded systems. When these faults and failures occur, protective devices such as circuit breakers, reclosers, sectionalizers and fuses operate to limit the resultant outage to the smallest practical area. Information on the outage is currently obtained through SCADA systems, where available, and/or notifications to the Company's customer service call centers. These notifications, when interfaced into the Company's connectivity model, inform the Company that an outage exists and allows for the dispatch of personnel to manually identify the location and commence restoration to areas outside the fault zone. When appropriate amounts of data are received from customers, intelligence within the current outage management software can make assumptions as to where a fault may have occurred.

To accelerate service restoration times, the integration of intelligent electronic devices (IEDs) in distribution line equipment, specifically reclosers, sectionalizers and faulted circuit indicators, provide the outage management system with intelligence that can be used to isolate the faulted sections of the system in reduced time frames.

Fault Detection, Isolation and Restoration (FDIR)

A Fault Detection, Isolation and Restoration program (FDIR) utilizes strategically placed distribution reclosers, motor operated switches and fault detection devices to automate restoration. The program works by adding communication to existing reclosers, motor-operated switches and fault detection devices. The devices then communicate their status back to the DMS which tries to determine the fault location and then uses feeder ties to automate restoration to areas outside the fault zone where adjacent circuit capacity exists. The DMS then sends out a signal to open or close fault isolation devices and switches to restore the maximum number of customers. The switching is typically done within one to two minutes.

Once all automated restoration switching has been completed, the DMS can notify the distribution dispatch center of the faulted zone. The dispatch center can then send crews to identify the cause of the outage and make the repairs. By knowing the location of the faulted zone, the time related to line patrolling is reduced thus shortening the outage time.

Transmission Synchronphasors (TSP)

The existing Rocky Mountain Power transmission system relies on many electronic elements to ensure reliability and to maximize the transmission capacity available on individual lines and transmission paths including remedial action schemes and high speed digital relays. The NERC glossary defines a Special Protection System (SPS) as "An automatic protection system designed to detect abnormal or predetermined system conditions, and take corrective actions other than and/or in addition to the isolation of faulted components to maintain system reliability. Such action may include changes in demand, generation (MW and Mvar), or system configuration to

maintain system stability, acceptable voltage, or power flows. An SPS does not include (a) underfrequency or undervoltage load shedding or (b) fault conditions that must be isolated or (c) out-of-step relaying (not designed as an integral part of an SPS). Also called Remedial Action Scheme (RAS).” Rocky Mountain Power uses the term Remedial Action Scheme and will continue with that terminology throughout this report.

RAS have become more widely used in recent years to provide protection for power systems against problems not directly involving specific equipment fault protection. RAS, along with high speed digital relays, are the latest “smart” technologies used to maximize the operational efficiency of the transmission system. RAS are designed to monitor and protect electrical systems by automatically performing switching operations in response to adverse network conditions to ensure the integrity of the electrical system and avoid network collapse. RAS uses a combination of programmable logic controllers and high speed digital relays to provide this protection. For example, the sudden loss of one transmission line may require dropping a generator’s output to prevent the overloading of an adjacent and parallel transmission line. Without the RAS, the parallel line would become overloaded in a short period of time and trip itself off line to be protected from damage. Without the RAS, a cascading outage would not be easily avoided.

Transmission smart grid is generally synonymous with the phase measurement unit (PMU) (or synchrophasor) and the communication network to link many PMUs to a central processor. The PMU is the building block for transmission system smart grid applications. The intelligent use of PMU data can lead to a more reliable network by comparing phase angles of certain network elements with a base element measurement. The PMU can also be used to increase reliability by synchrophasor assisted protection because of better line condition data relayed faster through the communication network. Future applications of this precise data could be developed to dynamically rate transmission line capacity, real time and real condition line/path ratings and real time power factor optimization. Such dynamic ratings would require vast changes in the current contract path (a transmission owner’s rights to sell capacity are based on contracts not actual flows) transmission capacity methodology currently employed by Rocky Mountain Power and other transmission operators in the Western Electric Coordinating Council (WECC). PMU implementation and further development may enable transmission operators to integrate variable resources and potentially energy storage more effectively in to their balancing areas and minimize service disruptions. A self-healing transmission grid would reduce outages by “detouring” energy to other paths with available capacity.

Several suppliers offer PMU units that can be used today. In fact this technology has been around since 1979 according to General Electric. The communication network elements are generally available. PMU deployment is dependent on a wide area network of sufficient geographical coverage, bandwidth, reliability, security and latency to enable PMU functions. Specific data processing and decision logic would be required for operations.

A wide area network constructed to support a network of PMU devices would enable distribution improvements at transmission-distribution interface substations. These substations can serve as the common communication and data gathering node for both transmission and distribution data and control. The General Electric topology model envisions a PMU, a micro grid coordinator, and substation operations logic co-located at the substation.

The early benefits of synchrophasor installation and intelligent monitoring of the transmission system are focused on increased reliability of the transmission system. The deferral or elimination of new or upgraded transmission lines is not facilitated by the synchrophasor program as envisioned in this report. Much research is needed to implement dynamic ratings which could, in theory, reduce the future need for additional transmission lines. Transmission energy storage and load reductions could defer or eliminate the need for additional central station generation, which in turn would defer or eliminate some future transmission lines.

Synchrophasor Demonstration Project

Rocky Mountain Power is participating in the WECC Western Interconnection Synchrophasor Project (WISP) which includes matching funding under a Smart Grid Investment Grant (SGIG) of 50%. WISP is a collaborative effort between partners throughout the U.S. portion of the Western Interconnection.

Rocky Mountain Power has committed \$800,000 of funding in order to engage in planning, design, engineering and operational activities to identify and deploy synchrophasor technology at the most effective locations on Rocky Mountain Power's system to the benefit of customers and the WECC region.

The goal of the WISP program is to increase the coverage of PMUs throughout the west, implement a new secure, stable, high performance wide area network (WAN), and deploy enhanced situational awareness applications, tools and processes and to identify the benefits of the technology. Synchrophasor data and supporting technologies will be used by WECC and entity partners to identify and analyze system vulnerabilities and evolving disturbances on the western bulk electric system and take timely actions to avoid wide-spread system blackouts. The system will provide WECC Reliability Coordinators (RC) and Grid Operators in the Western Interconnection with the network, infrastructure, tools and applications necessary to leverage phasor measurement technology in the planning, analysis, operation and monitoring of the grid with the primary goal of improved reliability.

Technology Dependency

Many of the technologies required to migrate the existing electrical system to a smart grid are dependent upon preceding technology deployment. To gain the full benefit of the individual technologies, it is necessary that all interdependent and preceding technologies are fully integrated. The information and communications technologies are required for all smart grid applications and cannot be excluded in any program analysis. To harvest the full benefit of IVVO, the DMS must be developed and integrated into the information and communications systems prior to field deployment of the "smart" capacitors and line regulators. Figure 4 illustrates the technology dependencies for the Rocky Mountain Power smart grid. The illustration shows that the smart grid must be built from "the top down" and along the paths indicated to build a functional system. The only exception is the transmission synchrophasor system which can be built out independently of the others.




Figure 4

Challenges and Risks of Implementing Smart Grid

While there are expected to be many upsides to the smart grid, there are many challenges to its deployment and the future operations of the electric system. Some of these challenges relate to integration of communication standards (interoperability), ensuring proper security for devices, systems and customers, modifying communications with customers and finally the impact that disruptive technologies may create on the electric distribution system.

It must be recognized that the electric system in place today was a result of an expansion that was predicated upon economics; as such, the system is engineered to provide adequate service at low costs. As system growth has occurred that fundamental design precept has not been materially altered. Smart grid is now positioned such that the fundamental economics are no longer the most critical aspect of the system; rather the ability for the customer to engage with the electric delivery system is of higher priority. This shift will result in significant costs for current and all future system investment. Equipment, communications protocols and even staff will be more technologically advanced, and will require more routine “refreshing” to maintain compatibility with further advancements.

Interoperability Standards

The current lack of interoperability standards risks premature obsolescence of equipment and software installed prior to widespread adoption of such standards. As electric utilities continue to expand existing infrastructure or begin implementing new smart grid related systems, long-term

investments should support a strategic plan to minimize the risk of technology obsolescence. There are currently several working groups developing standards for the entire spectrum of equipment, devices and end points for the metering and smart grid systems, including interoperability of components. The Energy Independence and Security Act of 2007, has specified that the Department of Energy (DOE) champion this effort with a completion date of 2012. The DOE authorized the National Institute of Standards and Technology (NIST) to develop uniform protocols that facilitate information exchange between smart grid devices and systems. These standards, along with industry adoption, are crucial to the mitigation of risks associated with implementation and deployment of the smart grid throughout Rocky Mountain Power's service territory.

NIST is also drafting standards to address issues of inter-operability between AMI vendors and has issued its "roadmap" for developing the necessary standards (the draft NIST Framework and Roadmap for Smart Grid Interoperability Standards). This roadmap targets the end of 2010 for the release of the most important standards, but NIST has cautioned that "several hundred standards that are identified or developed over the span of several years may be required to achieve secure, end-to-end interoperability across a fully implemented Smart Grid."

The smart grid initiatives that have evolved over the past few years has given birth to an incredible array of new markets and opportunities based on innovative technologies Rocky Mountain Power probably wouldn't have imagined at the outset. That point also stresses how extremely important interoperability standards are to a functional, reliable smart grid.

Stakeholders who are not monitoring the NIST activities risk having current investments becoming prematurely obsolete and will be more challenged to achieve all the benefits that are expected from existing equipment. In addition, many of the smart grid standards under review are immature or not even developed while some prominent standards are not included – emphasizing the need for electric utilities and commissions to remain conservative in developing plans for "smart grid" systems until standards are established and proven to deliver expectations.

Security

The smart grid increases the amount of intelligent data to a level never before seen in the electric industry. This data includes priority data for electrical system operation, customer data and usage patterns and generation and transmission operational information. This data will be transmitted mainly over secure communication systems, many of which will have wireless components. The fact that the data is transmitted wirelessly increases the risk of cyber-attacks against the electrical infrastructure.

The security of customer and operational data presents one of the greatest unknown risks at this time. North American Electric Reliability Corporation (NERC) critical infrastructure protection (CIP) reliability standards were designed to protect the bulk power system against potential cyber security attacks. Yet, these standards do not address the evolving smart grid market and the vulnerabilities that may be present as more utilities install advanced communications networks. As utilities progress towards the smart grid, enhanced security measures and more stringent requirements will be necessary. Their enactment will increase the overall cost of managing the smart grid.

Customer Communications

The smart grid opens a whole new channel of communication between Rocky Mountain Power and its customers, but this new communications channel is fundamentally different from the past. Transmission of usage data can be conducted in real time, not just on a monthly basis as in the present. The need to broadcast pricing alerts to smart thermostats, email addresses and text messaging devices happens virtually instantaneously. Responses from customers can be immediate, as in the case of a customer who pushes a "button" on their smart thermostat or Rocky Mountain Power website to inquire about their charges-to-date. For the customer to maximize their experience with the evolving technology and to understand the actions they need to take to realize the benefits of advanced metering is an important element of a deployment.

Legacy system platforms were not designed to handle real time events such as the ones noted above. They were designed to operate on regularly scheduled cycles of batch processes. From Rocky Mountain Power's perspective, modifying or replacing those old reliable cycle-and-batch systems is an incredibly daunting prospect with a large potential for unforeseen challenges that can result in significant cost overruns.

Another challenge that Rocky Mountain Power will face is customer recruitment. Preferably, demand response programs (DRP) should be opt-out programs. In order to retain customer participation, Rocky Mountain Power will need to reach out to eligible customers and educate them on the benefits of these programs to maintain a significant rate of participation. This may require the services of a third-party marketing firm or, if done in-house, new software functionality to handle DR recruitment, enrollment, and customer management as well as demand response program management. In addition, utilities will need functionality provided by some meter data management systems (MDMS): management of communications to field devices, tracking of devices and their relationships to customers and premises, and provisioning of devices upon installation. The new software will have to be able to scale, allow multiple users, and interface with the call center, an integrated voice response unit, and the internet. It will also need to interface with the billing system, MDMS, the demand response equipment installation company, and various demand response communication systems.

Rocky Mountain Power will also need to re-examine how customer service is provided to customers during deployment and after the advanced metering system is completed. The call center will need to be able to effectively work with customers to take advantage of more detailed information on energy use and spending and how to apply it to the customer concerns. This includes performing customer education needed to increase the understanding of smart metering and to reduce the fear and distrust of the changes.

Call center representatives must also have a strong understanding of the end-to-end business process and changes. Once the systems and processes are implemented, representatives must be prepared to answer and handle a complicated set of questions and issues. This requires representatives to have training and access to the applications and information to provide quality responses.

Metered Data Management

The smart grid results in a paradigm shift regarding metering data. Today, the meter reading system creates monthly files of meter reads and submits them to the billing system. With the smart grid, Rocky Mountain Power becomes a de facto communications company that handles millions of data transactions every day. With 1.8 million meters, just the simple transactions involved in the meter-to-cash function are completely transformed. When the numerous other functions are considered (meter provisioning, outage management, demand response events, etc.) the potential enormity of the challenge becomes clear.

To illustrate, every day the advanced metering system operations team must support:

- More than 4,000 meter exchanges per day during deployment
- More than 2,000 customer moves per day (based on 25% yearly turnover)
- 10,000 missing reads per day (99.5% daily read success)
- 20 meter failures per day (0.5% annual failure rate)
- 10,000 data changes per day
- More than 45,000,000 meter reads per day (assuming one-hour interval data)

One certainty about the Rocky Mountain Power smart grid is that applications and data uses will evolve and change over time. The solutions to support smart grid initiatives must not only accommodate, but thrive on such change. By planning for the full range of functionality from the beginning and selecting the solutions with the right architecture, Rocky Mountain Power can ensure that it not only meets today's broad requirements, but it can also meet the new requirements that will develop down the road.

Distributed Generation

Distributed generation, the installation of photovoltaic systems, fuel cells and other on-site electricity generating systems at customer premises, has the potential to change the dynamics of operating an electrical distribution system. Electrical distribution systems have historically been operated as a “one-way” delivery system moving the required energy from the distribution substation to the end-use customer. As more distributed generation sources appear on the grid, the distribution system must be modified to operate with significant “two-way” energy flows.

Without the appropriate smart grid technologies in place, distributed generation will be a disruptive technology that will impact the distribution system. Standard protection systems, including sectionalizers and fuses, will not be able to provide the proper protection schemes required to maintain the reliability of the system. The smart grid will require the installation of multiple protection devices that have bi-directional measurement capability and built-in analytics allowing them to respond to and isolate faults while protecting the system from stability issues related to end-of-line generation sources. As the number of distributed systems increase, the need for a smart grid will become more evident.

Distributed generation requires that electrical energy is measured in both directions. Energy delivered and energy received by the electric utility must be measured to provide the appropriate billing charges and credits for energy consumed and energy produced by the customer. To

accurately measure both quantities, bi-directional metering must be installed at each location where distributed generation systems exist. Meters capable of measuring energy in a bi-directional manner cost significantly more than standard one-way measurement meters.

Plug-In Electric Vehicles

Plug-in electric vehicles are expected to become more widely accepted as the technology advances and the purchase price become more competitive with gasoline vehicles. It is commonly understood that widespread adoption of plug-in electric vehicles will have a large impact on the electrical distribution system. To ensure that these vehicles do not adversely impact the distribution and transmission system or to the customer's home premises wiring, development of interoperability standards will be required along with necessary changes to electric price tariffs, electric service schedules and building codes. As mass scale introduction of electric vehicles occurs, the whole definition of on-peak and off-peak energy usage will change.

Regulatory Considerations

The deployment of a smart grid system introduces several regulatory considerations which must be addressed in order to ensure customers realize the full benefits of the system and that the utility is not penalized as a result of its investment in smart grid technologies or is disincentivized from encouraging its customers to fully utilize the capabilities of the system.

Chief among these considerations is cost recovery of the utility's investment in smart grid technologies. Rocky Mountain Power estimates that a fully deployed smart grid system across its six state service territory would cost nearly \$1.5 billion. This is a significant investment which would assuredly result in rate increases for customers in all six states in which the Company provides service. As discussed previously, the implementation of smart grid deviates from the least cost/adequate service operational model currently employed. While Rocky Mountain Power has not fully analyzed customer rate impacts, it is likely that full smart grid deployment would result in higher rates that otherwise would be in effect if smart grid technologies had not been fully deployed. Given this dynamic, it is essential that Rocky Mountain Power receive adequate assurance from the states in which smart grid technologies are to be implemented that deployment of smart grid is consistent with the policies of that state. Given the magnitude of smart grid investment, in order to avoid considerable financial harm, Rocky Mountain Power should be allowed to recover its prudently incurred costs in the deployment of smart grid technologies.

Related to the concept of cost recovery is how current assets rendered obsolete by the implementation of smart grid technologies are treated. Rocky Mountain Power believes that utilities should be allowed to recover the stranded costs of assets rendered obsolete. Otherwise, a utility would be disincentivized from investing in smart grid technologies which would replace assets and systems currently in service as the remaining costs would, in effect, be disallowed rate recovery, resulting in financial harm to the utility.

With the deployment of smart grid, rate structures that place a greater portion of the recovery of fixed costs in non-volumetric fixed charges will be essential. One of the primary intentions of

smart grid technologies is to enable both the utility and its customers to reduce peak demand and overall electric energy usage. Rate structures which are designed to recover a significant portion of fixed costs through volumetric energy charges are at odds with the objectives of the smart grid, as utilities are incentivized to encourage their customers to use more energy, thereby improving the utility's recovery of its fixed costs. With the implementation of smart grid technologies, rate structures which are designed to recover fixed costs through fixed charges will need to be implemented to allow a utility an opportunity to recover its fixed costs (a significant portion of which would be smart grid investment) and to fully realize the peak demand management and energy consumption reduction objectives of the smart grid.

In addition to rate structures which facilitate the recovery of fixed utility costs, complementary rate structures which encourage customers to use energy more efficiently and at the optimal times during the day will be required with the deployment of smart grid. Smart grid technologies provide the infrastructure by which customers are able to more effectively manage their energy usage, but contribute little towards motivating the customer to use electric energy more efficiently. As discussed in the demand response section of this report, rate designs such as time of use rates, critical peak pricing and peak time rebate structures are a necessary component of smart grid implementation in order to realize the full benefits made available by smart grid technologies.

Smart Grid Economic Review

Each of the components identified for Rocky Mountain Power's smart grid have identified costs and quantifiable benefits that were used to determine the rough potential of investing in those technologies. Whereas there does not exist any proven costs or savings for all of the components, there does exist qualified estimates that can be used to gauge costs and enough theoretical data established for savings opportunities on which a suitable analysis can be built to gauge the relative potential of various alternatives. Many of the benefits are highly variable and dependent on external factors such as values of the forward capacity and energy markets, percentage of the customer base participating in dynamic pricing programs and the energy conservation achieved by those customers. A conservative approach was used in all aspects to protect the integrity of the estimates. Cost and benefit estimates of a Rocky Mountain Power smart grid are provided in confidential Attachment A. As actual and time proven data becomes available, the cost and savings assumptions will need to be updated to maintain a current assessment of the potential for investment options.

Benefits and Savings

The benefits of the smart grid can be categorized into two major areas: Company and consumer-based benefits. Company-based benefits are those benefits that are measured as a direct reduction in Company expenses such as operational and system losses. System losses reduce the need for added generation and off-system energy purchases and are categorized into generation savings.

Consumer-based benefits are directly attributed to changes in consumer energy-use behavior and are unproven benefits with questionable sustainability. These benefits are expected to occur through pricing structures that encourage both conservation during peak usage hours and changes

in usage patterns that result in a shift towards the morning and late evening hours. Without specific time-of-use and critical peak pricing structures, consumers are unlikely to have the incentive to make the behavioral changes required to bring about the benefits of a smart grid. Recommendations or models for time-of-use pricing structures are very complex and will require significant levels of study and debate to arrive at the proper design. Thus, pricing models will remain outside the scope of this report.

Measurement of consumer-based benefits can only be estimated as a reduction in generation requirements and measured by the associated marginal pricing. Additionally, consumer-based benefits could be estimated as a reduction in capital requirements for electrical infrastructure expansion and replacement. However, these savings are only temporary in nature as customer growth drives infrastructure investments.

Many analyses of smart grid benefits categorize some of the savings into “societal benefits” with the caveat that any decrease in outage time, generation or greenhouse gas emissions or other efficiency measures will benefit society as a whole with cleaner air, more reliable electric service, increased production times and other qualitative benefits. These societal benefits are difficult, if not impossible, to quantify with any degree of accuracy. For this reason, and the purposes of this report, these benefits will not be included in the analysis.

Advanced Metering System (AMS)

The major risks for deploying AMS at this time are vendor selection, home area network protocol and interoperability of components. Additionally, commission approval of new and revised time-varying rate structures and customer participation in these rates is a key component for success.

As with any new technology, employee training and business process changes must occur to gain the expected benefit. Technology specific training has been identified and included within the individual technology cost calculations. Costs for business process changes have not been fully determined but a reasonable estimate had been included for an accurate picture of the cost of smart grid. The benefits of the AMS results from the reduction in operating costs associated with manual meter reading, field collections activities and customer call handling resulting from erroneous and estimated meter readings.

Additionally, the costs associated with the accelerated depreciation of the current metering assets will need to be continually calculated and modified as the system is installed. Several areas within Rocky Mountain Power have recently been converted to automated meter reading systems and others may be in the future where practical. The accelerated cost of depreciation for those systems will be higher than in areas with older metering systems. The cost of accelerated depreciation has not been included in this analysis.

Demand Response (DR)

The AMS considered in this analysis is the enabler for a price responsive DR program such as time-of-use (TOU) and critical peak pricing (CPP). A CPP pricing program is implemented with a TOU tariff as a base. A TOU tariff generally has two sets of pricing on a daily basis: the on-

peak price per kWh and an off-peak price per kWh. The critical peak hours are usually kept to within four to six hours that coincide with a utility's daily peak demand hours. For Rocky Mountain Power, this would be in the summer afternoon/early evening.

In addition to the TOU tariff a CPP rider would be included. The CPP rate would be a change to the on peak energy price for the day a critical peak pricing event is called. For the CPP scenarios in this analysis, 10 CPP event days per summer are assumed. Generally, the critical peak days are expected to coincide with heat waves on weekdays, when customer loads are the highest.

In order to give customers time to prepare for the curtailment, CPP event days could be called 24 hours in advance. Notification to customers would be through devices placed in customers' homes and businesses as well as through email, texting and social media channels.

The enactment of TOU and CPP rates structures would require regulatory and/or legislative support in all Company jurisdictions and be supportive of:

- 1) mandatory TOU and CPP for residential and small commercial customers, and
- 2) changes in the current manner in which utility costs are recovered. A shift to time-based pricing would require a decoupling of volumetric sales from the recovery of utility costs.

Absent this shift in environment, the benefits assumed in this case for DR are unlikely to be realized. The benefit assumptions would need to be revisited and will likely result in higher costs and lower overall benefits for this investment.

Three scenarios were evaluated to identify one option to include in the economic analysis. The three scenarios are described below.

For all scenarios, the majority of the load response to CPP events would be from customers with central electric air conditioning and heat pumps. Either through an automated response, or customer manual adjustment, thermostat settings would be raised during CPP events reducing the coincident demand of air conditioning on the system until the event ended. Customers with window air conditioning units could manually adjust their temperature settings as well. Other responses expected would be reducing lighting and plug loads. Customers could also delay operating dish washers, clothes washers, dryers and electric oven/range cooking and turn down electric water heaters manually or with a timer.

In all scenarios, there are ongoing costs such as customer education, CPP event notification and software licensing and/or maintenance. Additional recurring costs include costs associated with load reduction evaluation, customer churn and growth and the replacement of control and notification equipment.

The benefits in each scenario consist of demand and energy reduction during the CPP events, along with the cost of additional energy use (higher than normal) after a CPP event due to loads that are shifted (delaying dishwasher usage and air conditioner take-back) rather than simply reduced (lighting, plug loads).

The benefits quantified include two sources: avoided capacity costs and energy cost savings. The avoided capacity costs represent the avoided peak megawatts multiplied by the expected value of the forward capacity market. The energy costs savings represent the lower cost of purchasing capacity during off-peak hours as compared to on-peak hours.

In developing the assumed response rates, costs and benefits for the three scenarios it became apparent that the data available on which to base the assumptions and calculations was limited. Participation in nearly all TOU rates for residential and small commercial customers in operation today are voluntary and the data available from smart grid enabled demand response pilot programs, while informative, is insufficient to accurately predict results on a larger scale, across multiple jurisdictions, and in a low retail cost environment.

Scenario 1- Mandatory TOU/ CPP

This type of rate structure is expected to encourage energy usage away from the daily peak load periods. Additional demand reduction could be achieved under this scenario with occasional CPP events, triggering higher prices, which are more reflective of the costs associated with meeting critical peak demand. The CPP tariff would apply to all residential and commercial customers. All customers would be given a basic CPP event indicator device that has three color-coded indications of relative kWh pricing, representing off-peak (cheapest pricing), on-peak pricing, and critical peak pricing. Signaling to the device would be through the smart grid's communication system into the home. Only one-way communication to the device would be necessary. Customers could choose to sign up for day-ahead notification through email, texting and social media channels.

Customers could also choose to purchase a more robust notification system like an in-home display (IHD) that gives the customer actual kWh pricing, in addition to notification of CPP events. Another option for customers is the purchase of devices to help automate their response to CPP events such as a programmable communicating thermostat or a home automation system. These two types of devices would automatically respond to CPP event notifications and reduce customer energy use to a pre-set level determined by each customer, providing the greatest opportunity for demand response and energy use reductions. To help improve response to CPP events, Rocky Mountain Power would offer a coupon to customers for upgrading to an IHD, a communicating thermostat, or a home automation system. Most of the costs for this CPP program would be in the initial roll out of the tariff, purchase and distribution of basic CPP indicators, notification and control systems, equipment coupons and customer education. A majority of these costs would be incurred through the first two years of the tariff implementation. Ongoing costs would consist of consumer education to maintain persistence of response during events, customer growth, assisting with the costs of replacement equipment due to customer movements and equipment failures, and the evaluation of the resulting load reduction.

Scenario 2 - CPP Opt-Out

This scenario is similar to Scenario 1. All customers would be put on the TOU and CPP rates as a default tariff. Customers would have the ability to opt-out of the CPP part of the tariff and only be on the TOU rate. This rate would have an off-peak period rate higher than the TOU rate with the CPP component in order to incent customers to stay on the CPP rate. With the exception of the marketing strategy, all of the other features in Scenario 1 would be the same in Scenario 2. It is expected that customer participation would stabilize during first two years of the tariff implementation.

Scenario 3 – CPP Opt-In

For this scenario, all customers would also be on a TOU tariff to encourage energy usage away from the daily peak load periods. Rocky Mountain Power would market the CPP tariff to customers. The incentive for customers to participate would be a CPP event indicator that also indicates the daily off-peak and on-peak hours, as well as the CPP events. In addition, the off-peak rate would be lower for this tariff than for the default TOU tariff. To help customers enhance their load reduction response, a communicating programmable thermostat or a basic IHD would be offered to participating customers, as well as a coupon to upgrade to more sophisticated IHD's or a home automation system. The utility would send a signal to the thermostat or home automation system initiating an automated response to the CPP event based on each customer's desired response to events. For example, a customer with a programmable communicating thermostat could choose to have their temperature setting raised by five degrees in response to CPP events. It is expected that, with focused marketing and communication, it would take about 4 years to build the customer participation to the levels predicted in the financial analysis. In addition to the costs in Scenarios 1 and 2, this scenario would have higher marketing costs associated with customer acquisition and the cost of the thermostat or IHD provided as an incentive.

To maximize the benefits of demand response in this review the costs and benefits of Scenario 1, mandatory TOU with a CPP component, will be used. Scenario 1 provides the highest value with the lowest assumed implementation cost and highest assumed demand response from customers. The voluntary nature of Scenarios 2 and 3 increases initial and ongoing marketing costs while in many cases also resulting in diminishing value from participants, many of whom are likely participating because the on-peak and off-peak pricing schedules align closely with normal usage patterns.

Under all three scenarios, the review suggests that if the enabling advanced metering and associated communications were in place, the deployment of demand response on a broader scale than is pursued today would be beneficial. It is important to note that demand response benefits are dependent upon realizing anticipated customer participation rates. And as discussed earlier, Rocky Mountain Power believes insufficient data exists at this time to accurately predict wide spread customer reaction to TOU and CPP rate structures.

Also, adjustments were made to the costs and benefits of demand response for the residential and small commercial load management programs currently in place and operated by Rocky

Mountain Power today. The costs of these programs were netted out of the cost and benefits of the broader demand response applications envisioned in a smart grid enabled environment. Whereas demand response is responsible for 72% of the total smart grid benefit, the economic analysis is highly dependent upon the assumptions made for customer participation and retention and future energy costs. Any variance in these assumptions will greatly impact the financial calculations.

Customer Education

There is a very limited amount of experience or data currently available on which to assess the requirements for customer education as advanced metering and smart grid technologies are delivered and customer interaction with the technology increases. To arrive at a suitable estimate for customer education costs a review of various utility state filings for advanced metering deployment was conducted. Of those filings reviewed, only Oncor Electric Delivery Company's filing included a line item for customer education. Their advanced meter deployment includes a \$15.1 million comprehensive customer education program called "SMART TEXAS - rethinking energy" that will educate retail electric customers about the benefits that can be achieved through the use of an advanced meter. Oncor's plan includes a Mobile Experience Center (a hands-on educational tool that will travel throughout Oncor's service territory in advance of the deployment), educational door hangers, and newspaper, billboard and movie theater advertisements.

To properly account for customer education programs throughout Rocky Mountain Power's service territory, we have included a conservative cost of \$12 million for this purpose. This value was derived based on a lower customer count and a larger geographical service territory as compared to Oncor.

Distribution Management Systems (DMS)

Rocky Mountain Power has a history of managing its distribution systems for optimal power factor and voltage profile, reduced line losses and increased system efficiency. This attention to managing the distribution system has required that numerous capacitor banks and voltage regulators be installed over the lifetime of the distribution system. Costs to migrate to smart grid has been mitigated as the existing line equipment will require that only the control panel be upgraded to allow for the required two-way communications. In addition to the existing line equipment and to create a smoother, leveled voltage profile, additional capacitor banks will be installed and controlled by the DMS. These additional voltage regulators and capacitor banks may, to a minor extent, further reduce the line losses on the system resulting in less required generation. The ability for the capacitor banks to automatically report malfunctions will reduce.

The addition of fault circuit indicators and automated field switching devices will provide for additional operational benefits from reduced capacitor inspections and reductions in manual switching orders. The ability to proactively respond to outages on the system will provide operational benefits in the form of reduced outage calls to the call center, a reduction in the number trouble tickets issued and better management of field crews during the outage.

Cost and Benefits Summary

The economics of the Rocky Mountain Power smart grid project were evaluated over twenty-five years in order to cover implementation and the twenty-year expected life of the system. The economics include refresh rates for computer hardware, software and communications equipment and the remaining value of transmission and distributions assets installed under this program. The costs and benefits in 2010 dollars associated with each of the technologies defined for the Rocky Mountain Power smart grid are detailed in confidential Attachment A. The costs and benefits are escalated based on the projected inflation rate except for energy savings which are valued based on projected power costs.

When reviewing this analysis it is important to remember the technology dependencies as discussed previously in the report. For example, the savings associated with demand-side management cannot be achieved without the investment in information technology, metering/distribution wide-area network and the advanced metering system.

Smart Grid Implementation

Smart grid technologies are currently in a state of constant development and evolution. Such circumstances lead to a healthy level of uncertainty regarding the benefits made available by smart grid implementation and the associated costs of deployment. Rocky Mountain Power expects that over time, both the benefits to be achieved by smart grid and the costs associated with deployment and continuing operation will become more established and reliable. Given the current state of flux in the smart grid arena, it is difficult for Rocky Mountain Power to identify technologies that it believes might be cost effective and available for implementation in its Utah service territory over the next ten years. Market developments might make it such that many or all of the technologies discussed herein would be prudent investments in Utah over the next ten years or so. However, over the next ten years, Rocky Mountain Power has no plans to implement any of the smart grid technologies discussed herein at this time.

Conclusion

While smart grid technologies do show promise for future improvements in the operation and management of the transmission and distribution systems, the present economics to implement a comprehensive smart grid system throughout the Rocky Mountain Power territory are substantial. Modification of consumer behavior would be central to realizing many benefits. Changes in usage and improved conservation have the potential to dramatically transform the electric industry with distributed generation and increased renewable generation.

Most of the benefits associated with demand response are unproven and based on optimistic assumptions regarding the number of customers who will change their energy usage and questions surrounding the sustainability of any consumer behavior change remain unanswered. To mitigate the risks of smart grid implementation to both Rocky Mountain Power and its customers, the Company believes it is necessary to allow additional time for smart grid technologies to more fully mature, i.e. allow time for technology leaders to emerge and ensure

that system interoperability can be verified. Additional time is also needed to evaluate customer response to demand response programs which are being piloted across the country. The Company believes that valuable insight can be gained by analyzing the results of early adopter smart grid deployments.

Rocky Mountain Power will continue to monitor the activities throughout the nation as more advanced metering and other smart grid related projects are developed. This will allow for more precise estimates for both costs and benefits. With large scale deployments progressing in California, Texas and Ontario and a myriad of pilots throughout the country, the market leaders will become self-evident within the next few years and will demonstrate if sustained demand response for large-scale roll-outs is supported by the precedent pilot programs.