

EXISTING STORAGE FACILITIES

Community Water Company currently has two water storage tanks to provide equalization and emergency storage for the system. Table 3-3 provides a summary of these facilities.

Table 3-3
Community Water Company Storage Facilities

Tank Identifier	Location	Volume
WTP #1	Below WTP	423,000
Lookout Lodge*	Lookout Lodge	40,000
	Total	463,000

*The Lookout Lodge storage tank is not on the water system inventory with UDDW.

It should be noted that the Lookout Lodge Tank and Lookout Lodge Pump Station both do not appear on the water system inventory with the State, a matter which came to light in the recent Sanitary Survey of CWC's system. CWC entered into a correction plan with the UDDW with respect to the Lookout Lodge Tank in 2015.