

Public Water System Bacterial Summary Report

Lakeview Water Company PWS ID: UTAH29024 Rating: Approved 05/23/1989 Status: Active

Contacts	Site Information	Site Updates	Political Districts
Type: Administrative Contact Name: RAY BOWDEN Office: 801-745-2639 Emergency: Email: info@lakeviewwatercorp.com	Legal Contact: LAKEVIEW WATER CO. Address: PO BOX 314 , HUNTSVILLE, UT 84317 Phone: 801-745-2639 County: WEBER COUNTY System Type: Community Certification Required: SS Total Population: 350	Last Inventory Update: 08/26/2022 Last Surveyor Update: 08/31/2021 Surveyor: JOSEPH P HUIISH Operating Period: 1/1 - 12/31 Last IPS Update: 10/12/2022 14:10:00	Representative: 8 Senate: 19 Water Usage Information per ERC Total Ips Points: 30

ROUTINE BACTERIOLOGICAL SAMPLING REQUIREMENTS

Sample Required	Schedule Begin	Schedule End	Operation Begin	Operation End
1/Monthly/Routine	12-01-2014		1/1	12/31

TOTAL COLIFORM SAMPLE HISTORY

Month	Routine Sampling			Repeat Sampling			Triggered Sampling			Assessment Sampling		
	# Samples	TC+	Ecoli+	# Samples	TC+	Ecoli+	# Samples	TC+	Ecoli+	# Samples	TC+	Ecoli+
Sep-21	1	0	0	0	0	0	0	0	0	0	0	0
Oct-21	1	1	0	4	4	0	1	0	0	0	0	0
Nov-21	5	0	0	4	0	0	0	0	0	0	0	0
Dec-21	1	0	0	0	0	0	0	0	0	0	0	0
Jan-22	1	0	0	0	0	0	0	0	0	0	0	0
Feb-22	1	0	0	0	0	0	0	0	0	0	0	0
Mar-22	1	0	0	0	0	0	0	0	0	0	0	0
Apr-22	1	0	0	0	0	0	0	0	0	0	0	0
May-22	1	0	0	0	0	0	0	0	0	0	0	0
Jun-22	1	0	0	0	0	0	0	0	0	0	0	0
Jul-22	1	0	0	0	0	0	0	0	0	0	0	0
Aug-22	1	0	0	0	0	0	0	0	0	0	0	0
Sep-22	1	0	0	0	0	0	0	0	0	0	0	0
Oct-22	0	0	0	0	0	0	0	0	0	0	0	0
Last sample taken 09/26/2022 from WEBER BASIN WATER QUALITY LAB (NP)												

LIST OF SOURCES

ID	Source Name	Status	Source Type	Water Type	Period of Operation
WS001	MITCHELL WELL (EAST WELL)	Active	Well	Groundwater	1/1 - 12/31
WS004	STODDARD WELL (WELL 3)	Proposed	Well	Groundwater	
WS005	BOWDEN WELL	Active	Well	Groundwater	1/1 - 12/31
Total Sources: 5 View Abandoned Sources					

Public Water System IPS Report

Lakeview Water Company

PWS ID: UTAH29024

Rating: Approved

05/23/1989

Status: Active

Contacts

Type: Administrative Contact
 Name: RAY BOWDEN
 Office: 801-745-2639
 Emergency:
 Email: info@lakeviewwatercorp.com

Site Information

Legal Contact: LAKEVIEW WATER CO.
 Address: PO BOX 314 , HUNTSVILLE,
 UT 84317
 Phone: 801-745-2639
 County: WEBER COUNTY
 System Type: Community
 Certification Required: SS
 Total Population: 350

Site Updates

Last Inventory Update: 08/26/2022
 Last Surveyor Update: 08/31/2021
 Surveyor: JOSEPH P HUIISH
 Operating Period: 1/1 - 12/31
 Last IPS Update: 10/12/2022 14:10:00

Political Districts

Representative: 8
 Senate: 19

Water Usage Information per ERC

Total Ips Points: 30

IPS SUMMARY			Total IPS Points: 30
Admin & Physical Facilities	Quality & Monitoring	Significant Deficiency Violations	
30	0	0	

PHYSICAL FACILITY POINTS								Total Pts: 30
Facility	Facility Name	Status	Points Effective	Details				
DS001	UTAH29024 DISTRIBUTION SYSTEM	A	15	Hide Details (1)				
	Code	Description	Severity	Comments	Determined Date	Pending	Assessed	
	M007	CCC-LACKS ON-GOING ENFORCEMENT IMPLEMENTATION	MIN	records exist but are sporadic, they need to be updated and kept on file	08/31/2021	0	15	
ST001	RESERVOIR #1	A	15	Hide Details (1)				
	Code	Description	Severity	Comments	Determined Date	Pending	Assessed	
	V021	STORAGE TANK ROOF OR SIDEWALLS SHOW SIGNS OF MILD OR MODERATE DETERIORATION	MIN	MILD ON WALLS	11/05/2018	0	15	
WS002	PETERSON WELL (WEST WELL)	I	0	Hide Details (3)				
	Code	Description	Severity	Comments	Determined Date	Pending	Assessed	
	SL01	WELL THAT PUMPS DIRECTLY TO DISTRIBUTION LACKS A MEANS TO RELEASE TRAPPED AIR	MIN	pumps directly to DS001, ST003 is inactive, and its vents do not apply.	08/07/2012	5		
	S024	NO CHECK VALVE ON WELL DISCHARGE PIPING	MIN	foot pump valve does not count as check valve on discharge piping	08/07/2012	5		
	S026	NO FLOW METER ON WELL DISCHARGE PIPING	MIN		07/12/2006	5		

SIGNIFICANT DEFICIENCY VIOLATIONS

Total Pts: 0

ID	Violation	Code	Deficiency	Determined	Points Effective
----	-----------	------	------------	------------	------------------

LEAD COPPER MONITORING AND QUALITY VIOLATIONS

Total Pts: 0

Violation No.	Period	Code	Description/Name	Points Effective
---------------	--------	------	------------------	------------------

CHEMICAL MONITORING RULE VIOLATIONS

Total Pts: 0

Facility	Violation No	Period	Code	Violation Type	Analyte Group	Determined	Seasonality	Points Effective
----------	--------------	--------	------	----------------	---------------	------------	-------------	------------------

TREATMENT VIOLATIONS

Total Pts: 0

Facility	Violation No	Period	Code	Violation Type	Analyte Group	Determined	Points Effective
----------	--------------	--------	------	----------------	---------------	------------	------------------

MICROBIAL RULE VIOLATIONS

Total Pts: 0

Date Range Start: 10/01/2021

Determine Date	Compliance Period	Code	Violation Type	Return To Compliance	Points Effective
----------------	-------------------	------	----------------	----------------------	------------------

OPERATOR CERTIFICATION

Type	Level Required	Highest Certificate
------	----------------	---------------------

Distribution	Small System	Small System
--------------	--------------	--------------

Treatment

CONSUMER CONFIDENCE REPORT

Total Effective Points: 0

Violation No.	Period	Code	Description/Name	Points Effective
---------------	--------	------	------------------	------------------

PUBLIC NOTIFICATION VIOLATIONS

Total Pts: 0

Violation No.	Date	Code	Description/Name	Points Effective
---------------	------	------	------------------	------------------

IPS COMPLIANCE SCHEDULES

Type	Required Activities	Severity	Created	Due
Revised Total Coliform Rule	LVL1 TTT MULTIPLE TC+		10/25/2021	11/24/2021

Public Water System Water Monitoring Report

Lakeview Water Company PWS ID: UTAH29024 Rating: Approved 05/23/1989 Status: Active

Contacts Type: Administrative Contact Name: RAY BOWDEN Office: 801-745-2639 Emergency: Email: info@lakeviewwatercorp.com	Site Information Legal Contact: LAKEVIEW WATER CO. Address: PO BOX 314 , HUNTSVILLE, UT 84317 Phone: 801-745-2639 County: WEBER COUNTY System Type: Community Certification Required: SS Total Population: 350	Site Updates Last Inventory Update: 08/26/2022 Last Surveyor Update: 08/31/2021 Surveyor: JOSEPH P HUIISH Operating Period: 1/1 - 12/31 Last IPS Update: 10/12/2022 14:10:00	Political Districts Representative: 8 Senate: 19 Water Usage Information per ERC Total Ips Points: 30
--	---	--	--

BACTERIOLOGICAL MONITORING

Sample Count	Type	Frequency	Schedule Begin	Schedule End	Analyte Name
1	Routine	Monthly	12/01/2014		COLIFORM (TCR)

DISINFECTION BYPRODUCT STAGE 2 MONITORING

Sample Count	Type	Frequency	Sample Label

OTHER DISTRIBUTION MONITORING

Analyte Name	ID	Sample Count	Type	Frequency	Last Sampled	Next Sample Due
LEAD AND COPPER	DS001	5	Routine	3 Years	09/2020	06/01/2023-09/30/2023
ASBESTOS	DS001	1	Routine	9 Years	03/2018	01/01/2020 - 12/31/2028

CHLORINE RESIDUAL MONITORING

ID	Facility Name	Sample Count	Type	Frequency	Last Sampled	Next Sample Due

MONITORING REQUIREMENTS BY FACILITY

ID	Name	Facility Details				
WS001	MITCHELL WELL (EAST WELL)	Hide Details				
	Name	Sample Count	Type	Frequency	Last Sample	Next Sample Due
	ARSENIC	1	Routine	Yearly	12/14/2021	01/01/2022 - 12/31/2022
	INORGANICS & METALS	1	Routine	3 Years	06/11/2019	01/01/2020 - 12/31/2022
	NITRATE	1	Routine	Yearly	12/14/2021	01/01/2022 - 12/31/2022
	PESTICIDES	1	Routine	3 Years	06/11/2019	01/01/2020 - 12/31/2022
	RADS - COMPLIANCE	1	Routine	6 Years	06/11/2019	01/01/2020 - 12/31/2025
	SULFATE,SODIUM,TDS	1	Routine	3 Years	06/11/2019	01/01/2020 - 12/31/2022
	VOLATILE ORGANICS	1	Routine	3 Years	06/11/2019	01/01/2020 - 12/31/2022
WS005	BOWDEN WELL	Hide Details				
	Name	Sample Count	Type	Frequency	Last Sample	Next Sample Due
	ARSENIC	1	Routine	Yearly	12/14/2021	01/01/2022 - 12/31/2022
	COMBINED URANIUM	1	Routine	3 Years	06/11/2019	01/01/2020 - 12/31/2022
	INORGANICS & METALS	1	Routine	3 Years	06/11/2019	01/01/2020 - 12/31/2022
	NITRATE	1	Routine	Yearly	12/14/2021	01/01/2022 - 12/31/2022
	PESTICIDES	1	Routine	3 Years	06/11/2019	01/01/2020 - 12/31/2022
	RADS - COMPLIANCE	1	Routine	3 Years	06/11/2019	01/01/2020 - 12/31/2022
	SULFATE,SODIUM,TDS	1	Routine	3 Years	06/11/2019	01/01/2020 - 12/31/2022
	VOLATILE ORGANICS	1	Routine	Yearly	12/14/2021	01/01/2022 - 12/31/2022

GROUPED SOURCE SAMPLING STATIONS

Sample Group ID	Sample Group	Facility Details			

OPEN COMPLIANCE SCHEDULES

Type	Required Activities	Severity	Created	Due
Revised Total Coliform Rule	LVL1 TTT MULTIPLE TC+		10/25/2021	11/24/2021

Public Water System Population and Connections Report

Lakeview Water Company

PWS ID: UTAH29024

Rating: Approved

05/23/1989

Status: Active

Contacts

Type: Administrative Contact
 Name: RAY BOWDEN
 Office: 801-745-2639
 Emergency:
 Email: info@lakeviewwatercorp.com

Site Information

Legal Contact: LAKEVIEW WATER CO.
 Address: PO BOX 314 , HUNTSVILLE,
 UT 84317
 Phone: 801-745-2639
 County: WEBER COUNTY
 System Type: Community
 Certification Required: SS
 Total Population: 350

Site Updates

Last Inventory Update: 08/26/2022
 Last Surveyor Update: 08/31/2021
 Surveyor: JOSEPH P HUIISH
 Operating Period: 1/1 - 12/31
 Last IPS Update: 10/12/2022 14:10:00

Political Districts

Representative: 8
 Senate: 19

Water Usage Information per ERC

Total Ips Points: 30

POPULATION REPORT

Begin Date	End Date	Type Code	Population
1/1	12/31	Residential	350

SERVICE CONNECTIONS

Type	Meter Type	Meter Size	Number of Connections
Residential	Metered	0	178
Industrial	Unknown	0	1
Total Service Connections: 179			